



Procurement Hub – Ottawa Office,  
Station 9N086, 9th Floor,  
200 Kent Street,  
Ottawa, Ontario K1A 0E6

**March 4, 2022**

**ADDENDUM N° 3**

Subject : **Invitation to Tender n° 30001782**

Title : North Atlantic Fisheries Centre Aquarium Monitoring System

Location : 80 East White Hills Road, St. John's, NL

Closing Date : **March 8, 2022 at 14 h EST (Eastern Standard Time)**

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum #3** is issued to answer the following questions submitted:

**Questions and Answers**

Q1. *For the Dissolved Oxygen Monitor, is it possible to provide alternative sensors? And if the controller accepts only two sensors, would it be acceptable to provide twice the amount of controllers?*

A1. Any alternative sensor(s) would be approved provided all requirements of the drawings/specifications and listed equipment are met. Equipment shop drawings will be reviewed for compliance with drawings and specifications after contract award. The addition power connection for each controller would have to be accommodated as well as the additional communication connection back to the PLC. Additional requirements for PLC inputs would also have to be accommodated. This would be the contractor's responsibility.

***All other terms and conditions remain the same.***

Regards,

**Mazen Obeid**

Agent d'approvisionnement et des contrats  
Centre d'approvisionnement, Services du matériel et des acquisitions  
Pêches et Océans Canada  
200, rue Kent, 9N086  
Ottawa (Ontario) K1A 0E6  
Courriel : [Mazen.Obeid@dfo-mpo.gc.ca](mailto:Mazen.Obeid@dfo-mpo.gc.ca)