



**RETURN BIDS TO /
RETOURNER LES SOUMISSIONS Á:**

**Parks Canada Agency, Bid Receiving Unit
National Contracting Services**

BID FAX : 1-855-983-1808

Bid Email / Courriel de soumission:
soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

Amendment #1

INVITATION TO TENDER

Proposal to: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office :

Parks Canada Agency
National Contracting Services
Cornwall, Ontario, K6H 6S2

Title-Sujet Resurfacing of access road at Fort St. Joseph National Historic Site		
Solicitation No. - No. de l'invitation 5P468-21-0212/A		Date: March 8, 2022
GETS Reference No. – No de référence de SEAG PW-22-00987042		Client Ref. No. – No. de réf du client. n/a
Solicitation Closes – L'invitation prend fin :		
at – à 2:00 PM	on – le March 15, 2022	Time Zone - Fuseau horaire HAE - EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Sheldon Lalonde sheldon.lalonde@pc.gc.ca		
Telephone No. - No de téléphone 343-585-3836		Fax No. – No de FAX: 1-855-983-1808
Destination of Goods, Services, and Construction: Destinations des biens, services et construction :		
See Herein – Voir aux présentes		

**TO BE COMPLETED BY THE BIDDER
À ÊTRE COMPLÉTÉ PAR LE SOUMISSIONNAIRE**

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

INVITATION TO TENDER

AMENDMENT #1

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

1) Questions and Answers:

Q1: What is the width of the road?

Answer: Road width approximately 7.00m.

Q2: How much maintenance is expected?

Answer: Approximately 20-hours of prep work prior to commence Bituminous Surface Treatment work. Prep work must be discussed with Parks Canada prior to starting work. All work should be supported by daily log i.e. record of man and equipment hours of work for billing purpose.

Q3: Are one or two layers expected on the road?

Answer: Single layer of surface treatment is expected on the road.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.