



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Box/Boîte de Réception des
Soumissions**

1st Floor/1^{ère} étage, Suite 1212

100-1045 Main Street

Moncton

New Brunswick

E1C 1H1

Bid Fax: (506) 851-6759

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Acquisitions NB/PEI (Moncton Office) – Bureau

d'acquisitions N.-B./Î.-P.-É. (Moncton)

1045 Main Street / 1045, rue Main

Moncton

New Bruns

E1C 1H1

Title - Sujet Phase2-Site Revitalization, Shediac	
Solicitation No. - N° de l'invitation EC015-222245/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EC015-222245	Date 2022-03-21
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-004-6180	
File No. - N° de dossier PWJ-1-44178 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Daylight Saving Time ADT on - le 2022-03-31 Heure Avancée de l'Atlantique HAA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Johnston (PWJ), Edward	Buyer Id - Id de l'acheteur pwj004
Telephone No. - N° de téléphone (506) 343-6382 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. two (2) is raised to include the following Addendum No. two (2).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

QUESTIONS AND ANSWERS

Q3. For the Gabions, as per Item 2.12.1 in Metal Fabrications section of specs, the intent is to have the steel portions powder coated only and no paint on stone correct?

A3. That is correct.

Q4. Again for Gabions, as per Item 3.8.6 in Metal Fabrications section of specs, for the stone it notes 'locally-sourced round stone, 75mm diameter (average).' , which we assume means river rock, but is there a certain colour or supplier to be carried?

A4. Gabion stone should be river rock. The stone should match aggregate used in exposed aggregate paving ('Weeks' stone from Sussex, NB, or approved equal).

Q5. For Asphalt, there seems to be only detail for patching the road (5/L402) with only a few areas showing to be removed on L100. With all the new curb locations along with removals of existing wiring. That said, please confirm what is expected for asphalt/curb: leave as much existing curb/patches as possible or remove full sections of curb with new paving within Limit of Work (and confirm extent). Attached below is a quick sketch of curb to be removed (pink, as per L100), curb that will need to be removed (yellow) and approx trenching line (in red).

A5. Refer to L-100 (Issued for Addendum) for revised limits of curb and asphalt removals.

Q6 – a. For 'prefabricated shed', there are quite a few small questions as follows:

a. Is there a specific manufacturer or pictures of an existing structure to better clarify design intent/look? This might help answer most of the next questions.

A6- a. The shed used as the basis for design is the 14' x 20' 'Studio Shed' by Old Hickory Buildings, with custom configuration of door and window locations, and the addition of an interior partition as indicated in drawings.

Q6 – b. If stamped shop drawing for the structure are provided for pre-fab wall panels and ceiling system and assembled on site would this be acceptable?

A6 – b. Yes

Q6 – c. Does the shed need to have a wood floor or is intent to use slab as floor (and fasten structure directly to slab).

A6 – c. The intent is to use the slab as the floor and fasten the structure to the slab.

Q6 – d. Drawings show metal roof and siding (black), but specs indicate 'engineered wood product' (Item 2.1.4.1) for siding, please clarify intent.

Solicitation No. - N° de l'invitation

EC015-222245/A

Client Ref. No. - N° de réf. du client

R.114246.001

Amd. No. - N° de la modif.

02

File No. - N° du dossier

PWJ-1-44178

Buyer ID - Id de l'acheteur

PWJ004

CCC No./N° CCC - FMS No./N° VME

A6 – d. Engineered siding may be LP Smart Panel or approved equal. The engineered siding is manufactured for exterior use and treated with manufacturer's proprietary process to resist fungal decay and termite damage.

Q6 – e. Door Grade: Item 2.1.1.5 only indicates 'solid wood', but is this to have commercial steel frame? Please elaborate.

A6 – e. A wood or steel frame is acceptable.

Q6 – f. Window: Is this to be vinyl? Please confirm.

A6 – f. A vinyl window is acceptable.