







Addendum Addenda

No./No 1

Project Description / Description de projet M50 AEP Emergency Shower / M50 Douche d'urgence AEP		
Project No./No de projet 5803	Departmental Representative / représentant ministériel Allan Mackenzie	Date 6-Apr-2022
Solicitation No./N° de sollicitation 21-58118		
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		
Nota: Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.		






Item No	Description
1	<p>Drawing 5803-M01 New Work Notes, Delete note 11:</p> <p>11. NEW EMERGENCY SHOWER ASSEMBLY. STANDARD OF ACCEPTANCE: HUGES SAFETY. MODEL` EXP-18GS/75G C/W OPTIFLEX BODY SPRAY. PROVIDE NEW 38DN DRAIN TUBING AND CONNECT TO 75DN SANITARY PIPING LOCATED IN CEILING SPACE ON GROUND FLOOR AT INLET TO P-TRAP. SECURE SHOWER TO FLOOR WITH 4- 3/8" Ø GALVANIZED THREADED RODS MINIMUM EMBEDMENT 75mm. STANDARD OF ACCEPTANCE: MANUFACTURER: HILTI , PART : HIT-RE 500-SD</p>
2	<p>Drawing 5803-M01, New Work Notes, Change Note 19 to:</p> <p>19. NEW EMERGENCY SHOWER WILL REQUIRE EXCESSIVE HANDLING TO GET SHOWER FROM HALLWAY TO ROOM 289B INCLUDING ACCESSING ADJOINING LAB IN ROOM 295. ACCESSING EXISTING LAB TO BE STRICTLY COORDINATE WITH NRC. NEW EMERGENCY SHOWER STANDARD OF ACCEPTANCE: MANUFACTURER: HUGHES, MODEL SD32K45G C/W EYE/FACE WASH, SCREENS AND SUMP. SECURE SHOWER TO FLOOR WITH 4- 3/8" Ø GALVANIZED THREADED RODS MINIMUM EMBEDMENT 75mm. STANDARD OF ACCEPTANCE: MANUFACTURER: HILTI, PART: HIT-RE 500-SD. PROVIDE NEW DRAIN TUBING AND CONNECT TO 75DN SANITARY PIPING LOCATED IN CEILING SPACE ON GROUND FLOOR AT INLET TO P-TRAP , PATCH AND FINISH ALL SURFACES AFFECTED BY THE WORK TO MATCH EXISTING ADJACENT.</p>

Mandatory Site Visit Attendance / Visite de chantier obligatoire

Project Description / Description de projet			M50 AEP Emergency Shower	Project No./No de projet	5803	Closing Date	April 13, 2022	Closing time	2:00 PM			
Solicitation No./N° de sollicitation		21-58118		Project No./No de projet		5803	1st Showing	March 30, 2022	Showing Time	9:00 AM		
Departmental Representative / représentant			Allan Mackenzie	Signature		Alternate/Questions deadline		April 4, 2022	Addendum Deadline	April 6, 2022	2nd Showing	March 31, 2022
COMPANY/COMPAGNIE			NAME/NOM	SIGNATURE	PHONE/TELEPHONE	EMAIL/COURRIEL						
30-Mar-22												
9:00am												
TPH Plumbing & Heating	Sylvain Bergeron		613-914-4350			kevinmneil@tphinc.ca						
Fred Trotter Construction Ltd.	Lomas Lakra		613-745-8688			bids@trotter.ca						
Premium Construction	Sabbi Kalsi		613-301-6005			sabbi@premium-construction.ca						
9:30am												
Alejandro Sanchez	Argca Associates Inc.		613-981-8233			asanchez@argcaassociates.com						
James Knight	GK Plumbing & Heating Inc.		613-241-5000			info@gkplumbingandheatinginc.ca						
Justin Gauthier	GK Plumbing & Heating Inc.		613-241-5000			info@gkplumbingandheatinginc.ca						
Victor Hoyos	Argca Associates Inc.		613-255-5403			vhoyos@argcaassociates.com						
10:00am												

Mandatory Site Visit Attendance / Visite de chantier obligatoire

Project Description / Description de projet		M50 AEP Emergency Shower		Closing Date	April 13, 2022	Closing time	2:00 PM
Solicitation No./N° de sollicitation		21-58118		Project No./No de projet	5803	1st Showing	March 30, 2022
Departmental Representative / représentant		Allan Mackenzie		Signature		2nd Showing	March 31, 2022
				Alternate/Questions deadline	April 4, 2022	Addendum Deadline	April 6, 2022

COMPANY/COMPAGNIE	NAME/NOM	SIGNATURE	PHONE/TELEPHONE	EMAIL/COURRIEL
31-Mar-22				
9:00am				
Climate Works	Michelle Witt		613-838-9989 Ext 105	mwitt@climateworks.ca
Terlin Construction Ltd.	Nastasha Amo		613-621-2779	nastasha.amo@terlin.ca
Kenbay Plumbing Ltd.	Phil Bourdeau		613-850-4779	kenbayplumbing@hotmail.ca
3V Mechanical	Louis Marion		613-402-9446	louis@3vmechanical.ca
Baxtec Mechanical	Graham Finn		613-738-7450	gfinn@baxtec.com
9:30am				
10:00am				

