

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada**

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

Request For a Standing Offer Demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

Canada, as represented by the Minister of Public Works and Government Services Canada, hereby requests a Standing Offer on behalf of the Identified Users herein.

Le Canada, représenté par le ministre des Travaux Publics et Services Gouvernementaux Canada, autorise par la présente, une offre à commandes au nom des utilisateurs identifiés énumérés ci-après.

Comments - Commentaires

Vendor/Firm Name and Address**Raison sociale et adresse du fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet RISO Asphalt Greenwood	
Solicitation No. - N° de l'invitation W6899-220085/B	Date 2022-04-13
Client Reference No. - N° de référence du client W6899-22-0085	GETS Ref. No. - N° de réf. de SEAG PW-\$HAL-502-11510
File No. - N° de dossier HAL-1-87218 (502)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Daylight Saving Time ADT on - le 2022-04-28 Heure Avancée de l'Atlantique HAA	
Delivery Required - Livraison exigée See Herein – Voir ci-inclus	
Address Enquiries to: - Adresser toutes questions à: Parsons, Richard	Buyer Id - Id de l'acheteur hal502
Telephone No. - N° de téléphone (902)399-8427 ()	FAX No. - N° de FAX (902)496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: REAL PROPERTY OPERATIONS DET GREENWOOD 14 WING GREENWOOD PO BOX STN MAIN GREENWOOD NOVA SCOTIA B0P 1R0 CANADA	
Security - Sécurité This request for a Standing Offer includes provisions for security. Cette Demande d'offre à commandes comprend des dispositions en matière de sécurité.	

Instructions: See Herein

Instructions: Voir aux présentes

Vendor/Firm Name and Address	
Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone	
Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)	
Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

TABLE OF CONTENTS

PART 1 - GENERAL INFORMATION	3
1.1 INTRODUCTION	3
1.2 SUMMARY	3
1.3 SECURITY REQUIREMENTS	4
1.4 DEBRIEFINGS	4
1.5 ANTICIPATED MIGRATION TO AN E-PROCUREMENT SOLUTION (EPS).....	4
PART 2 - OFFEROR INSTRUCTIONS	4
2.1 STANDARD INSTRUCTIONS, CLAUSES AND CONDITIONS.....	4
2.2 SUBMISSION OF OFFERS	4
2.3 FORMER PUBLIC SERVANT	5
2.4 ENQUIRIES - REQUEST FOR STANDING OFFERS.....	6
2.5 APPLICABLE LAWS	7
2.6 BID CHALLENGE AND RECOURSE MECHANISMS	7
PART 3 - OFFER PREPARATION INSTRUCTIONS.....	7
3.1 OFFER PREPARATION INSTRUCTIONS.....	7
PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION	9
4.1 EVALUATION PROCEDURES	9
4.2 BASIS OF SELECTION.....	9
PART 5 - CERTIFICATIONS AND ADDITIONAL INFORMATION	9
5.1 CERTIFICATIONS REQUIRED WITH THE OFFER.....	9
5.2 CERTIFICATIONS PRECEDENT TO THE ISSUANCE OF A STANDING OFFER AND ADDITIONAL INFORMATION.....	11
PART 6 - SECURITY, FINANCIAL AND INSURANCE REQUIREMENTS	12
6.1 SECURITY REQUIREMENTS	12
6.2 INSURANCE REQUIREMENTS.....	12
PART 7 - STANDING OFFER AND RESULTING CONTRACT CLAUSES	12
A. STANDING OFFER	12
7.1 OFFER	12
7.2 SECURITY REQUIREMENTS	13
7.3 STANDARD CLAUSES AND CONDITIONS.....	13
7.4 TERM OF STANDING OFFER.....	14
7.5 AUTHORITIES	14
7.6 PROACTIVE DISCLOSURE OF CONTRACTS WITH FORMER PUBLIC SERVANTS.....	14
7.7 IDENTIFIED USERS	15
7.8 CALL-UP INSTRUMENT	15
7.9 LIMITATION OF CALL-UPS.....	15
7.10 FINANCIAL LIMITATION	15
7.11 PRIORITY OF DOCUMENTS.....	16
7.12 CERTIFICATIONS AND ADDITIONAL INFORMATION	16
7.13 APPLICABLE LAWS	16
7.14 TRANSITION TO AN E-PROCUREMENT SOLUTION (EPS).....	16
B. RESULTING CONTRACT CLAUSES	17
7.1 STATEMENT OF WORK.....	17
7.2 STANDARD CLAUSES AND CONDITIONS.....	17
7.3 TERM OF CONTRACT	17
7.4 PROACTIVE DISCLOSURE OF CONTRACTS WITH FORMER PUBLIC SERVANTS.....	17

7.5	PAYMENT	17
7.6	INVOICING INSTRUCTIONS	18
7.7	INSURANCE – SPECIFIC REQUIREMENTS	18
7.8	DISPUTE RESOLUTION	18
ANNEX "A"		20
	STATEMENT OF WORK	20
ANNEX "B"		21
	BASIS OF PAYMENT	21
ANNEX "C"		23
	SECURITY REQUIREMENTS CHECK LIST	23
SEE ATTACHED.....		23
ANNEX "D"		24
	INSURANCE REQUIREMENTS.....	24
ANNEX "E" TO PART 3 OF THE REQUEST FOR STANDING OFFERS		26
	ELECTRONIC PAYMENT INSTRUMENTS	26
ANNEX "F"		27
	STANDING OFFER REPORTING FORM	27
ANNEX "G"		28
	INTEGRITY PROVISIONS – LIST OF DIRECTORS	28

SACC Manual clause M9043T (2007-05-25), Reissue of Request for Standing Offers

This request for standing offers (RFSO) cancels and supersedes previous RFSO number W6899-220085/A dated March 25, 2022 with a closing of April 14, 2022 at 2:00 PM ADT.

PART 1 - GENERAL INFORMATION

1.1 Introduction

The Request for Standing Offers (RFSO) is divided into seven parts plus attachments and annexes, as follows:

- | | |
|--------|---|
| Part 1 | General Information: provides a general description of the requirement; |
| Part 2 | Offeror Instructions: provides the instructions applicable to the clauses and conditions of the RFSO; |
| Part 3 | Offer Preparation Instructions: provides offerors with instructions on how to prepare their offer to address the evaluation criteria specified; |
| Part 4 | Evaluation Procedures and Basis of Selection: indicates how the evaluation will be conducted, the evaluation criteria which must be addressed in the offer, and the basis of selection; |
| Part 5 | Certifications and Additional Information: includes the certifications and additional information to be provided; |
| Part 6 | Security, Financial and Insurance Requirements: includes specific requirements that must be addressed by offerors; and |
| Part 7 | 7A, Standing Offer, and 7B, Resulting Contract Clauses:

7A, includes the Standing Offer containing the offer from the Offeror and the applicable clauses and conditions;

7B, includes the clauses and conditions which will apply to any contract resulting from a call-up made pursuant to the Standing Offer. |

The Annexes include the Statement of Work, the Basis of Payment, the Security Requirements Checklist, the Standing Offer Reporting Form, the Insurance Requirements, the electronic payment instructions and the Integrity Provisions – Board of Directors List.

1.2 Summary

- 1.2.1 The Department of National Defence has a requirement for a Regional Individual Standing Offer (RISO) that includes but is not limited to the supply of all material, equipment, labour and transportation to repair or replace defective asphalt and curbing at 14 Wing Greenwood, Camp Aldershot, Yarmouth Armouries and Middleton Armouries located in Nova Scotia, as fully detailed in Annex A. The period of the standing offer will be from approximately May 1, 2022 to December 31, 2022.
- 1.2.2 This RFSO allows offerors to use the epost Connect service provided by Canada Post Corporation to transmit their offers electronically. Offerors must refer to Part 2 of the RFSO entitled Offeror Instructions and Part 3 of the RFSO entitled Offer Preparation Instructions, for further information on using this method.

- 1.2.3 This requirement is subject to the COVID-19 Vaccination Policy for Supplier Personnel. Failure to complete and provide the COVID-19 Vaccination Requirement Certification as part of the offer will render the offer non-responsive.

1.3 Security Requirements

There are security requirements associated with the requirement of the Standing Offer. For additional information, see Part 6 - Security, Financial and Insurance Requirements, and Part 7 - Standing Offer and Resulting Contract Clauses. For more information on personnel and organization security screening or security clauses, offerors should refer to the [Contract Security Program](http://www.tpsgc-pwgsc.gc.ca/esc-src/introduction-eng.html) of Public Works and Government Services Canada (<http://www.tpsgc-pwgsc.gc.ca/esc-src/introduction-eng.html>) website.

1.4 Debriefings

Offerors may request a debriefing on the results of the request for standing offers process. Offerors should make the request to the Standing Offer Authority within 15 working days of receipt of the results of the request for standing offers process. The debriefing may be in writing, by telephone or in person.

1.5 Anticipated migration to an e-Procurement Solution (EPS)

Canada is currently developing an online EPS for faster and more convenient ordering of goods and services. In support of the anticipated transition to this system and how it may impact any resulting Standing Offer that is issued under this solicitation, refer to 7.15 Transition to an e-Procurement Solution (EPS).

The Government of Canada's [press release](#) provides additional information.

PART 2 - OFFEROR INSTRUCTIONS

2.1 Standard Instructions, Clauses and Conditions

All instructions, clauses and conditions identified in the Request for Standing Offers (RFSO) by number, date and title are set out in the [Standard Acquisition Clauses and Conditions Manual](https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual) (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>) issued by Public Works and Government Services Canada.

Offerors who submit an offer agree to be bound by the instructions, clauses and conditions of the RFSO and accept the clauses and conditions of the Standing Offer and resulting contract(s).

The [2006](#) (2020-05-28) Standard Instructions - Request for Standing Offers - Goods or Services - Competitive Requirements, are incorporated by reference into and form part of the RFSO.

2.2 Submission of Offers

Offers must be submitted only to the Public Works and Government Services Canada (PWGSC) Bid Receiving Unit specified below by the date and time indicated on page 1 of the RFSO:

Bid Receiving Unit
Public Works and Government Services Canada
1713 Bedford Row,
Halifax, N.S.
B3J 1T3

Note: For bidders choosing to submit using epost Connect, the email address is:

TPSGC.RARceptionSoumissionsNE-ARBidReceivingNS.PWGSC@tpsgc-pwgsc.gc.ca

Note: Offers will not be accepted if emailed directly to this email address. This email address is to be used to open an epost Connect conversation, as detailed in Standard Instruction [2006](#), or to send offers through an epost Connect message if the bidder is using its own licensing agreement for epost Connect."

Facsimile number: (902) 496-5016

2.3 Former Public Servant

Contracts awarded to former public servants (FPS) in receipt of a pension or of a lump sum payment must bear the closest public scrutiny, and reflect fairness in the spending of public funds. In order to comply with Treasury Board policies and directives on contracts awarded to FPS, offerors must provide the information required below before the issuance of a standing offer. If the answer to the questions and, as applicable the information required have not been received by the time the evaluation of offers is completed, Canada will inform the Offeror of a time frame within which to provide the information. Failure to comply with Canada's request and meet the requirement within the prescribed time frame will render the offer non-responsive.

Definitions

For the purposes of this clause,

"former public servant" is any former member of a department as defined in the Financial Administration Act R.S., 1985, c. F-11, a former member of the Canadian Armed Forces or a former member of the Royal Canadian Mounted Police. A former public servant may be:

- a. an individual;
- b. an individual who has incorporated;
- c. a partnership made of former public servants; or
- d. a sole proprietorship or entity where the affected individual has a controlling or major interest in the entity.

"lump sum payment period" means the period measured in weeks of salary, for which payment has been made to facilitate the transition to retirement or to other employment as a result of the implementation of various programs to reduce the size of the Public Service. The lump sum payment period does not include the period of severance pay, which is measured in a like manner.

"pension" means a pension or annual allowance paid under the Public Service Superannuation Act (PSSA), R.S., 1985, c. P-36, and any increases paid pursuant to the Supplementary Retirement Benefits Act, R.S., 1985, c. S-24 as it affects the PSSA. It does not include pensions payable pursuant to the Canadian Forces Superannuation Act, R.S., 1985, c. C-17, the Defence Services Pension Continuation Act, 1970, c. D-3, the Royal Canadian Mounted Police Pension Continuation Act, 1970, c. R-10, and the Royal Canadian Mounted Police Superannuation Act, R.S., 1985, c. R-11, the Members of Parliament Retiring Allowances Act, R.S. 1985, c. M-5, and that portion of pension payable to the Canada Pension Plan Act, R.S., 1985, c. C-8.

Former Public Servant in Receipt of a Pension

As per the above definitions, is the Offeror a FPS in receipt of a pension? **YES () NO ()**

If so, the Offeror must provide the following information, for all FPS in receipt of a pension, as applicable:

- a. name of former public servant;
- b. date of termination of employment or retirement from the Public Service.

By providing this information, Offerors agree that the successful Offeror's status, with respect to being a former public servant in receipt of a pension, will be reported on departmental websites as part of the published proactive disclosure reports in accordance with Contracting Policy Notice: 2012-2 and the Guidelines on the Proactive Disclosure of Contracts.

Work Force Adjustment Directive

Is the Offeror a FPS who received a lump sum payment pursuant to the terms of the Work Force Adjustment Directive? **YES () NO ()**

If so, the Offeror must provide the following information:

- a. name of former public servant;
- b. conditions of the lump sum payment incentive;
- c. date of termination of employment;
- d. amount of lump sum payment;
- e. rate of pay on which lump sum payment is based;
- f. period of lump sum payment including start date, end date and number of weeks;
- g. number and amount (professional fees) of other contracts subject to the restrictions of a work force adjustment program.

For all contracts awarded during the lump sum payment period, the total amount of fees that may be paid to a FPS who received a lump sum payment is \$5,000, including Applicable Taxes.

2.4 Enquiries - Request for Standing Offers

All enquiries must be submitted in writing to the Standing Offer Authority no later than **five (5)** calendar days before the Request for Standing Offers (RFSO) closing date. Enquiries received after that time may not be answered.

Offerors should reference as accurately as possible the numbered item of the RFSO to which the enquiry relates. Care should be taken by offerors to explain each question in sufficient detail in order to enable Canada to provide an accurate answer. Technical enquiries that are of a proprietary nature must be clearly marked "proprietary" at each relevant item. Items identified as "proprietary" will be treated as such except where Canada determines that the enquiry is not of a proprietary nature. Canada may edit the question(s) or may request that offerors do so, so that the proprietary nature of the question(s) is eliminated, and the enquiry can be answered to all offerors. Enquiries not submitted in a form that can be distributed to all offerors may not be answered by Canada.

2.5 Applicable Laws

The Standing Offer and any contract resulting from the Standing Offer must be interpreted and governed, and the relations between the parties determined, by the laws in force in Nova Scotia.

Offerors may, at their discretion, substitute the applicable laws of a Canadian province or territory of their choice without affecting the validity of their offer, by deleting the name of the Canadian province or territory specified and inserting the name of the Canadian province or territory of their choice. If no change is made, it acknowledges that the applicable laws specified are acceptable to the offerors.

2.6 Bid Challenge and Recourse Mechanisms

- (a) Several mechanisms are available to potential offerors to challenge aspects of the procurement process up to and including contract award.
- (b) Canada encourages offerors to first bring their concerns to the attention of the Contracting Authority. Canada's [Buy and Sell](#) website, under the heading "[Bid Challenge and Recourse Mechanisms](#)" contains information on potential complaint bodies such as:
 - Office of the Procurement Ombudsman (OPO)
 - Canadian International Trade Tribunal (CITT)
- (c) Offerors should note that there are **strict deadlines** for filing complaints, and the time periods vary depending on the complaint body in question. Offerors should therefore act quickly when they want to challenge any aspect of the procurement process.

PART 3 - OFFER PREPARATION INSTRUCTIONS

3.1 Offer Preparation Instructions

- If the Offeror chooses to submit its offer electronically, Canada requests that the Offeror submits its offer in accordance with section 08 of the 2006 standard instructions. The epost Connect system has a limit of 1GB per single message posted and a limit of 20GB per conversation. The offer must be gathered per section and separated as follows:

Section I: Technical Offer
Section II: Financial Offer
Section III: Certifications

- If the Offeror chooses to submit its offer in hard copies, Canada requests that the Offeror provides its offer in separately bound sections as follows:

Section I: Technical Offer (1 hard copy)

Section II: Financial Offer (1 hard copy)

Section III: Certifications (1 hard copy)

If there is a discrepancy between the wording of the soft copy on electronic media and the hard copy, the wording of the hard copy will have priority over the wording of the soft copy.

- If the Offeror is simultaneously providing copies of its offer using multiple acceptable delivery methods, and if there is a discrepancy between the wording of any of these copies and the electronic

copy provided through epost Connect service, the wording of the electronic copy provided through epost Connect service will have priority over the wording of the other copies.

Prices must appear in the financial offer only. No prices must be indicated in any other section of the offer.

Canada requests that offerors follow the format instructions described below in the preparation of hard copy of their offer:

- (a) use 8.5 x 11 inch (216 mm x 279 mm) paper;
- (b) use a numbering system that corresponds to the RFSO.

In April 2006, Canada issued a policy directing federal departments and agencies to take the necessary steps to incorporate environmental considerations into the procurement process [Policy on Green Procurement](https://www.tbs-sct.gc.ca/pol/doc-eng.aspx?id=32573) (<https://www.tbs-sct.gc.ca/pol/doc-eng.aspx?id=32573>). To assist Canada in reaching its objectives, Offerors should:

- 1) Include all environmental certification(s) relevant to your organization (e.g. ISO 14001, Leadership in Energy and Environmental Design (LEED), Carbon Disclosure Project, etc.)
- 2) Include all environmental certification(s) or Environmental Product Declaration(s) (EPD) specific to your product/service (e.g. Forest Stewardship Council (FSC), ENERGYSTAR, etc.)
- 3) Unless otherwise noted, Offerors are encouraged to submit offers electronically. If hard copies are required, Offerors should:
 - a. use 8.5 x 11 inch (216 mm x 279 mm) paper containing fibre certified as originating from a sustainably-managed forest and containing minimum 30% recycled content; and
 - b. use an environmentally-preferable format including black and white printing instead of colour printing, printing double sided/duplex, using staples or clips instead of cerlox, duotangs or binders.

Section I: Technical Offer

In their technical offer, offerors should explain and demonstrate how they propose to meet the requirements and how they will carry out the Work.

Section II: Financial Offer

Offerors must submit their financial offer in accordance with Annex B, Basis of Payment.

3.1.1 Electronic Payment of Invoices - Offer

If you are willing to accept payment of invoices by Electronic Payment Instruments, complete Annex "E" Electronic Payment Instruments, to identify which ones are accepted.

If Annex "E" Electronic Payment Instruments is not completed, it will be considered as if Electronic Payment Instruments are not being accepted for payment of invoices.

Acceptance of Electronic Payment Instruments will not be considered as an evaluation criterion.

3.1.2 Exchange Rate Fluctuation

[C3011T](#) (2013-11-06), Exchange Rate Fluctuation

Section III: Certifications Offerors must submit the certifications and additional information required under Part 5.

PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION

4.1 Evaluation Procedures

- (a) Offers will be assessed in accordance with the entire requirement of the Request for Standing Offers including the technical and financial evaluation criteria.
- (b) An evaluation team composed of representatives of Canada will evaluate the offers.

4.1.1 Technical Evaluation

It is mandatory that all bidders submit **FIRM prices/rate** for ALL items in the cost form, including no cost items. The FIRM prices/rates will stand for the entire period of the standing offer.

4.1.2 Financial Evaluation

4.1.2.1 Evaluation of Price

SACC Manual Clause [M0220T](#) (2016-01-28), Evaluation of Price

4.2 Basis of Selection

An offer must comply with the requirements of the Request for Standing Offers to be declared responsive. The responsive offer with the lowest evaluated price will be recommended for issuance of a standing offer.

PART 5 – CERTIFICATIONS AND ADDITIONAL INFORMATION

Offerors must provide the required certifications and additional information to be issued a standing offer.

The certifications provided by offerors to Canada are subject to verification by Canada at all times. Unless specified otherwise, Canada will declare an offer non-responsive, will have the right to set-aside a standing offer, or will declare a contractor in default if any certification made by the Offeror is found to be untrue whether made knowingly or unknowingly during the offer evaluation period, during the Standing Offer period, or during the contract period.

The Standing Offer Authority will have the right to ask for additional information to verify the Offeror's certifications. Failure to comply and to cooperate with any request or requirement imposed by the Standing Offer Authority will render the offer non-responsive, result in the setting aside of the Standing Offer or constitute a default under the Contract.

5.1 Certifications Required with the Offer

Offerors must submit the following duly completed certifications as part of their offer.

5.1.1 Integrity Provisions - Declaration of Convicted Offences

In accordance with the Integrity Provisions of the Standard Instructions, all offerors must provide with their offer, **if applicable**, the declaration form available on the [Forms for the Integrity Regime](http://www.tpsgc-pwgsc.gc.ca/ci-if/declaration-eng.html) website (<http://www.tpsgc-pwgsc.gc.ca/ci-if/declaration-eng.html>), to be given further consideration in the procurement process.

5.1.2 Additional Certifications Required with the Offer

5.1.2.3 COVID-19 vaccination requirement certification

In accordance with the COVID-19 Vaccination Policy for Supplier Personnel, all offerors must provide with their offer, the COVID-19 Vaccination Requirement Certification attached to this RFSO, to be given further consideration in this procurement process. This Certification is incorporated into, and forms a binding part of any resulting Contract.

COVID-19 Vaccination Requirement Certification

I, _____ (first and last name), as the representative of _____ (name of business) pursuant to _____ (insert solicitation number), warrant and certify that all personnel that _____ (name of business) will provide on call-up(s) issued against the Standing Offer resulting from this Request for Standing Offers who access federal government workplaces where they may come into contact with public servants will be:

- a. fully vaccinated against COVID-19;
- b. for personnel that are unable to be vaccinated due to a certified medical contraindication, religion or other prohibited grounds of discrimination under the Canadian Human Rights Act, subject to accommodation and mitigation measures that have been presented to and approved by Canada; or
- c. partially vaccinated against COVID-19 for a period of up to 10 weeks from the date of their first dose and subject to temporary measures that have been presented to and approved by Canada, immediately after which period the personnel will meet the conditions of (a) or (b) or will no longer access federal government workplaces where they may come into contact with public servants under this Contract;

until such time that Canada indicates that the vaccination requirements of the COVID-19 Vaccination Policy for Supplier Personnel are no longer in effect.

I certify that all personnel provided by _____ (name of business) have been notified of the vaccination requirements of the Government of Canada's COVID-19 Vaccination Policy for Supplier Personnel, and that the _____ (name of business) has certified to their compliance with this requirement.

I certify that the information provided is true as of the date indicated below and will continue to be true for the duration of the Standing Offer and any resulting call-ups (contracts). I understand that the certifications provided to Canada are subject to verification at all times. I also understand that Canada will declare an Offeror or contractor in default, if a certification is found to be untrue, whether made knowingly or unknowingly, during the period of the Standing Offer or call-up (contract). Canada reserves the right to

ask for additional information to verify the certifications. Failure to comply with any request or requirement imposed by Canada will constitute a default under the Standing Offer and call-up (contract).

Signature: _____

Date: _____

Optional

For data purposes only, initial below if your business already has its own mandatory vaccination policy or requirements for employees in place. Initialing below is not a substitute for completing the mandatory certification above.

Initials: _____

Information you provide on this Certification Form and in accordance with the Government of Canada's COVID-19 Vaccination Policy for Supplier Personnel will be protected, used, stored and disclosed in accordance with the Privacy Act. Please note that you have a right to access and correct any information on your file, and you have a right to file a complaint with the Office of the Privacy Commissioner regarding the handling of your personal information. These rights also apply to all individuals who are deemed to be personnel for the purpose for any resulting Contract and who require access to federal government workplaces where they may come into contact with public servants.

5.2 Certifications Precedent to the Issuance of a Standing Offer and Additional Information

The certifications and additional information listed below should be submitted with the offer, but may be submitted afterwards. If any of these required certifications or additional information is not completed and submitted as requested, the Standing Offer Authority will inform the Offeror of a time frame within which to provide the information. Failure to provide the certifications or the additional information listed below within the time frame provided will render the offer non-responsive.

5.2.1 Integrity Provisions – Required Documentation

In accordance with the section titled Information to be provided when bidding, contracting or entering into a real property agreement of the [Ineligibility and Suspension Policy](http://www.tpsgc-pwgsc.gc.ca/ci-if/politique-policy-eng.html) (<http://www.tpsgc-pwgsc.gc.ca/ci-if/politique-policy-eng.html>), the Offeror must provide the required documentation, as applicable, to be given further consideration in the procurement process.

5.2.2 Federal Contractors Program for Employment Equity - Standing Offer Certification

By submitting an offer, the Offeror certifies that the Offeror, and any of the Offeror's members if the Offeror is a Joint Venture, is not named on the Federal Contractors Program (FCP) for employment equity "FCP Limited Eligibility to Bid" list) available at the bottom of the page of the [Employment and Social Development Canada-Labour's](https://www.canada.ca/en/employment-social-development/canada-labour's) website (<https://www.canada.ca/en/employment-social-development/programs/employment-equity/federal-contractor-program.html#s4>).

Canada will have the right to declare an offer non-responsive, or to set-aside a Standing Offer, if the Offeror, or any member of the Offeror if the Offeror is a Joint Venture, appears on the "FCP Limited Eligibility to Bid" list at the time of issuing of a Standing Offer or during the period of the Standing Offer.

PART 6 - SECURITY, FINANCIAL AND INSURANCE REQUIREMENTS

6.1 Security Requirements

1. Before issuance of a standing offer, the following conditions must be met:
 - (a) the Offeror must hold a valid organization security clearance as indicated in Part 7A - Standing Offer;
 - (b) the Offeror's proposed individuals requiring access to classified or protected information, assets or sensitive work sites must meet the security requirements as indicated in Part 7A - Standing Offer;
 - (c) the Offeror must provide the name of all individuals who will require access to classified or protected information, assets or sensitive work sites;
2. Offerors are reminded to obtain the required security clearance promptly. Any delay in the issuance of a standing offer to allow the successful Offeror to obtain the required clearance will be at the entire discretion of the Standing Offer Authority.
3. For additional information on security requirements, offerors should refer to the [Contract Security Program](http://www.tpsgc-pwgsc.gc.ca/esc-src/introduction-eng.html) of Public Works and Government Services Canada (<http://www.tpsgc-pwgsc.gc.ca/esc-src/introduction-eng.html>) website.

6.2 Insurance Requirements

The Contractor must comply with the insurance requirements specified in Annex D. The Contractor must maintain the required insurance coverage for the duration of the Contract. Compliance with the insurance requirements does not release the Contractor from or reduce its liability under the Contract.

The Contractor is responsible for deciding if additional insurance coverage is necessary to fulfill its obligation under the Contract and to ensure compliance with any applicable law. Any additional insurance coverage is at the Contractor's expense, and for its own benefit and protection.

The Contractor must forward to the Contracting Authority within ten (10) days after the date of award of the Contract, a Certificate of Insurance evidencing the insurance coverage and confirming that the insurance policy complying with the requirements is in force. For Canadian-based Contractors, coverage must be placed with an Insurer licensed to carry out business in Canada, however, for Foreign-based Contractors, coverage must be placed with an Insurer with an A.M. Best Rating no less than "A-". The Contractor must, if requested by the Contracting Authority, forward to Canada a certified true copy of all applicable insurance policies.

PART 7 - STANDING OFFER AND RESULTING CONTRACT CLAUSES

A. STANDING OFFER

7.1 Offer

- 7.1.1 The Offeror offers to perform the Work in accordance with the Statement of Work at Annex "A".

7.2 Security Requirements

SECURITY REQUIREMENT FOR CANADIAN SUPPLIER:

PWGSC FILE No. W6899-220085

1. The Contractor/Offeror must, at all times during the performance of the Contract/Standing Offer, hold a valid Designated Organization Screening (DOS), issued by the Contract Security Program (CSP), Public Works and Government Services Canada (PWGSC).
2. The Contractor/Offeror personnel requiring access to sensitive site(s) must EACH hold a valid RELIABILITY STATUS, granted or approved by the CSP, PWGSC.
3. Subcontracts which contain security requirements are NOT to be awarded without the prior written permission of the CSP, PWGSC.
4. The Contractor/Offeror must comply with the provisions of the:
 - a) Security Requirements Check List and security guide (if applicable), attached at Annex C;
 - b) *Contract Security Manual* (Latest Edition).

7.3 Standard Clauses and Conditions

All clauses and conditions identified in the Standing Offer and resulting contract(s) by number, date and title are set out in the [Standard Acquisition Clauses and Conditions Manual](https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual) (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>) issued by Public Works and Government Services Canada.

7.3.1 General Conditions

2005 (2017-06-21) General Conditions - Standing Offers - Goods or Services, apply to and form part of the Standing Offer.

7.3.2 Standing Offers Reporting

The Offeror must compile and maintain records on its provision of goods and services to Canada under contracts resulting from the Standing Offer. This data must include all purchases done by Canada, including those acquired and paid for by Canada acquisition cards.

The Offeror must provide this data in accordance with the reporting requirements detailed in Annex "A". If some data is not available, the reason must be indicated in the report. If no goods or services is provided during a given period, the Offeror must provide a "nil" report.

The data must be submitted on a quarterly basis to the Standing Offer Authority.

The quarterly reporting periods are defined as follows:

- first quarter: April 1 to June 30
- second quarter: July 1 to September 30
- third quarter: October 1 to December 31
- fourth quarter: January 1 to March 31

The data must be submitted to the Standing Offer Authority no later than 30 calendar days after the end of the reporting period.

7.4 Term of Standing Offer

7.4.1 Period of the Standing Offer

The period for making call-ups against the Standing Offer is from May 1, 2022 to December 31, 2022.

7.4.2 Delivery Points

Delivery of the requirement will be made to delivery point(s) specified at Annex "A" of the Standing Offer.

7.5 Authorities

7.5.1 Standing Offer Authority

The Standing Offer Authority is:

Name: Richard Parsons
Title: Supply Specialist
Public Works and Government Services Canada
Acquisitions Branch
Address: 1713 Bedford Row, Halifax, NS, B3J 1T3

Telephone: (902)399-8427
Facsimile: (902)496-5016
E-mail address: richard.parsons@pwgsc-tpsgc.gc.ca

The Standing Offer Authority is responsible for the establishment of the Standing Offer, its administration and its revision, if applicable. Upon the making of a call-up, as Contracting Authority, he is responsible for any contractual issues relating to individual call-ups made against the Standing Offer by any Identified User.

7.5.2 Project Authority

The Project Authority for the Standing Offer is identified in the call-up against the Standing Offer.

The Project Authority is the representative of the department or agency for whom the Work will be carried out pursuant to a call-up under the Standing Offer and is responsible for all the technical content of the Work under the resulting Contract.

7.5.3 Offeror's Representative (To be filled out by offeror)

Name: _____
Title: _____
Organization: _____
Address: _____

Telephone: ____ - ____ - ____
Facsimile: ____ - ____ - ____
E-mail address: _____

7.6 Proactive Disclosure of Contracts with Former Public Servants

By providing information on its status, with respect to being a former public servant in receipt of a [Public Service Superannuation Act](#) (PSSA) pension, the Contractor has agreed that this information will be reported on departmental websites as part of the published proactive disclosure reports, in accordance with [Contracting Policy Notice: 2012-2](#) of the Treasury Board Secretariat of Canada.

7.7 Identified Users

The Identified User authorized to make call-ups against the Standing Offer is: **The Department of National Defence, 14 Wing Greenwood.**

7.8 Call-up Instrument

The Work will be authorized or confirmed by the Identified User(s) using the duly completed forms or their equivalents as identified in paragraphs 2 and 3 below, or by using Canada acquisition cards (Visa or MasterCard) for low dollar value requirements.

1. Call-ups must be made by Identified Users' authorized representatives under the Standing Offer and must be for goods or services or combination of goods and services included in the Standing Offer at the prices and in accordance with the terms and conditions specified in the Standing Offer.
2. Any of the following forms could be used which are available through [PWGSC Forms Catalogue](#) website:
 - PWGSC-TPSGC 942 Call-up Against a Standing Offer
 - PWGSC-TPGSC 942-2 Call-up Against a Standing Offer - Multiple Delivery
 - PWGSC-TPSGC 944 Call-up Against Multiple Standing Offers (English version)
 - PWGSC-TPSGC 945 Commande subséquente à plusieurs offres à commandes (French version)

or

3. An equivalent form or electronic call-up document which contains at a minimum the following information:
 - standing offer number;
 - statement that incorporates the terms and conditions of the Standing Offer;
 - description and unit price for each line item;
 - total value of the call-up;
 - point of delivery;
 - confirmation that funds are available under section 32 of the Financial Administration Act;
 - confirmation that the user is an Identified User under the Standing Offer with authority to enter into a contract.

7.9 Limitation of Call-ups

Individual call-ups against the Standing Offer must not exceed \$60,000.00 (Applicable Taxes included).

7.10 Financial Limitation

The total cost to Canada resulting from call ups against the Standing Offer must not exceed the sum of \$____ (completed at award) (Applicable Taxes excluded) unless otherwise authorized in writing by the Standing Offer Authority. The Offeror must not perform any work or services or supply any articles in response to call ups which would cause the total cost to Canada to exceed the said sum, unless an increase is so authorized.

The Offeror must notify the Standing Offer Authority as to the adequacy of this sum when 75 percent of this amount has been committed, or 3 months before the expiry date of the Standing Offer, whichever comes first. However, if at any time, the Offeror considers that the said sum may be exceeded, the Offeror must promptly notify the Standing Offer Authority.

7.11 Priority of Documents

If there is a discrepancy between the wording of any documents that appear on the list, the wording of the document that first appears on the list has priority over the wording of any document that subsequently appears on the list.

- a) the call up against the Standing Offer, including any annexes;
- b) the articles of the Standing Offer;
- c) the general conditions 2005 (2017-06-21), General Conditions - Standing Offers - Goods or Services
- d) the general conditions 2010C (2021-12-02) General conditions - Services (medium complexity);
- e) Annex A, Statement of Work;
- f) Annex B, Basis of Payment;
- g) Annex C, Security Requirements Check List;
- h) Annex D, Insurance Requirements;
- i) the Offeror's offer dated _____ (*insert date of offer*)

7.12 Certifications and Additional Information

7.12.1 Compliance

Unless specified otherwise, the continuous compliance with the certifications provided by the Offeror with its offer or precedent to issuance of the Standing Offer (SO), and the ongoing cooperation in providing additional information are conditions of issuance of the SO and failure to comply will constitute the Offeror in default. Certifications are subject to verification by Canada during the entire period of the SO and of any resulting contract that would continue beyond the period of the SO.

7.13 Applicable Laws

The Standing Offer and any contract resulting from the Standing Offer must be interpreted and governed, and the relations between the parties determined, by the laws in force in Nova Scotia.

7.14 Transition to an e-Procurement Solution (EPS)

During the period of the Standing Offer, Canada may transition to an EPS for more efficient processing and management of individual call-ups for any or all of the SO's applicable goods and services. Canada reserves the right, at its sole discretion, to make the use of the new e-procurement solution mandatory.

Canada agrees to provide the Offeror with at least a three-month notice to allow for any measures necessary for the integration of the Offer into the EPS. The notice will include a detailed information package indicating the requirements, as well as any applicable guidance and support.

If the Offeror chooses not to offer their goods or services through the e-procurement solution, the Standing Offer may be set aside by Canada.

7.15 COVID-19 vaccination requirement certification compliance – Standing Offers

Canada will have the right to declare an offer non-responsive, or to set-aside a Standing Offer, if the COVID-19 Vaccination Requirement Certification is or becomes untrue or if the Offeror fails to comply with such Certification during the period of any resulting Contract (call-up).

Canada will also have the right to terminate any resulting Call-up for default if the COVID-19 Vaccination Requirement Certification is or becomes untrue or if the Contractor fails to comply with such Certification during the period of the Contract (call-up).

B. RESULTING CONTRACT CLAUSES

The following clauses and conditions apply to and form part of any contract resulting from a call-up against the Standing Offer.

7.1 Statement of Work

The Contractor must perform the Work described in the call-up against the Standing Offer.

7.2 Standard Clauses and Conditions

7.2.1 General Conditions

[2010C](#) (2021-12-02), General Conditions - Services (Medium Complexity) apply to and form part of the Contract.

7.2.2 Supplemental General Conditions

Compliance with on-site measures, standing orders, policies, and rules

The Contractor must comply and ensure that its employees and subcontractors comply with all security measures, standing orders, policies or other rules in force at the site where the Work is performed.

7.3 Term of Contract

7.3.1 Period of the Contract

The Work must be completed in accordance with the call-up against the Standing Offer.

7.3.2 Delivery Date

Delivery must be completed in accordance with the call-up against the Standing Offer.

7.4 Proactive Disclosure of Contracts with Former Public Servants

By providing information on its status, with respect to being a former public servant in receipt of a *Public Service Superannuation Act* (PSSA) pension, the Contractor has agreed that this information will be reported on departmental websites as part of the published proactive disclosure reports, in accordance with Contracting Policy Notice: 2012-2 of the Treasury Board Secretariat of Canada.

7.5 Payment

7.5.1 Basis of Payment

In consideration of the Contractor satisfactorily completing all of its obligations under the Contract, the Contractor will be paid a firm price, as specified in Annex B. Customs duties are excluded and Applicable Taxes are extra.

Canada will not pay the Contractor for any design changes, modifications or interpretations of the Work, unless they have been approved, in writing, by the Contracting Authority before their incorporation into the Work.

7.5.2 Limitation of Price

SACC Manual clause C6000C (2017-08-17) Limitation of Price

7.5.3 Single Payment

SACC Manual clause H1000C (2008-05-12), Single Payment

7.5.4 Electronic Payment of Invoices – Call-up

The Contractor accepts to be paid using any of the following Electronic Payment Instrument(s):

- a. Visa Acquisition Card;
- b. MasterCard Acquisition Card;
- c. Direct Deposit (Domestic and International);
- d. Electronic Data Interchange (EDI);
- e. Wire Transfer (International Only);

7.6 Invoicing Instructions

1. The Contractor must submit invoices in accordance with the section entitled "Invoice Submission" of the general conditions. Invoices cannot be submitted until all work identified in the invoice is completed.
2. Invoices must be distributed as follows:
 - a. The original and one (1) copy must be forwarded to the address shown on page 1 of the Contract for certification and payment.

7.7 Insurance – Specific Requirements

The Contractor must comply with the insurance requirements specified in Annex D. The Contractor must maintain the required insurance coverage for the duration of the Contract. Compliance with the insurance requirements does not release the Contractor from or reduce its liability under the Contract.

The Contractor is responsible for deciding if additional insurance coverage is necessary to fulfill its obligation under the Contract and to ensure compliance with any applicable law. Any additional insurance coverage is at the Contractor's expense, and for its own benefit and protection.

The Contractor must forward to the Contracting Authority within ten (10) days after the date of award of the Contract, a Certificate of Insurance evidencing the insurance coverage and confirming that the insurance policy complying with the requirements is in force. For Canadian-based Contractors, coverage must be placed with an Insurer licensed to carry out business in Canada, however, for Foreign-based Contractors, coverage must be placed with an Insurer with an A.M. Best Rating no less than "A-". The Contractor must, if requested by the Contracting Authority, forward to Canada a certified true copy of all applicable insurance policies.

7.8 Dispute Resolution

- (a) The parties agree to maintain open and honest communication about the Work throughout and after the performance of the contract.
- (b) The parties agree to consult and co-operate with each other in the furtherance of the contract and promptly notify the other party or parties and attempt to resolve problems or differences that may arise.

- (c) If the parties cannot resolve a dispute through consultation and cooperation, the parties agree to consult a neutral third party offering alternative dispute resolution services to attempt to address the dispute.

- (d) Options of alternative dispute resolution services can be found on Canada's Buy and Sell website under the heading "Dispute Resolution".

Solicitation No. - N° de l'invitation
W6899-220085/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
File No. - N° du dossier

Buyer ID - Id de l'acheteur
Hal 502
CCC No./N° CCC - FMS No./N° VME

ANNEX "A"

STATEMENT OF WORK

(see Attachment)

ANNEX "B"

BASIS OF PAYMENT

All prices are in Canadian dollars, Goods and Services Tax or the Harmonized Sales Tax excluded, Canadian Customs Duties Taxes included.

Canada will not pay the Contractor for any design changes, modifications or interpretations of the Work, unless they have been approved, in writing, by the Contracting Authority before their incorporation into the Work.

Bidders must quote on all of the items and be willing to provide service to all locations. Otherwise, your offer will be deemed non-responsive. Only one standing offer will be issued.

	DESCRIPTION	UNIT OF MEASURE	ESTIMATED QUANTITY	PRICE PER UNIT	TOTAL
A	Old Asphalt Removal <i>removed</i>	m2	225	\$	\$
B	Common Excavation <i>removed</i>	m2	225	\$	\$
C	Hand Laid Asphalt/Tack <i>in place</i>	tonne	750	\$	\$
D	Spreader Laid Asphalt/Tack <i>in place</i>	tonne	1500	\$	\$
E	Supply Class "A" Gravel <i>FOB Greenwood, NS</i>	tonne	300	\$	\$
F	Supply Class "A" Gravel <i>in place</i>	tonne	300	\$	\$
G	Portland Concrete Curbing Placed by Machine <i>in place including 300 mm compacted base</i>	LM	750	\$	\$
H	Hand Formed Concrete Curbing <i>per meter including 300mm compact base</i>	meter	125	\$	\$
I	Raising Existing Manhole Covers & Catch Grates <i>per cover or grates in place</i>	cover	7	\$	\$
J	Concrete Milling and Replace with Asphalt	m ³	50	\$	\$
K	Asphalt Milling and Replace with Asphalt <i>cubed min width .5m</i>	m ³	25	\$	\$
L	Asphalt Milling and Replace with Asphalt <i>min width 1.8m</i>	m ³	25	\$	\$
M	Concrete Milling	m ³	50	\$	\$
N	Asphalt Saw Cutting	feet/in	1000	\$	\$
O	Arrows <i>white to match existing / single</i>	each	20	\$	\$
P	Crosswalks <i>White 200mm Wide Lanes c/w hatch markings</i>	m	1000	\$	\$
Q	Stop Bars <i>white 600m wide</i>	m	400	\$	\$
R	Center Lines and Lane Lines <i>100mm wide c/w glass beads per meter single solid & dashed white</i>	m	30,000	\$	\$

Solicitation No. - N° de l'invitation
W6899-220085/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
File No. - N° du dossier

Buyer ID - Id de l'acheteur
Hal 502
CCC No./N° CCC - FMS No./N° VME

S	Parking Lines & Hatchings <i>White 120 mm wide</i>	m	1000	\$	\$
T	Handicap Parking <i>Handicap Symbol</i>	each	5	\$	\$

Estimated Total (GST/HST Excluded) \$ _____

End of Basis of Payment

Solicitation No. - N° de l'invitation
W6899-220085/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
File No. - N° du dossier

Buyer ID - Id de l'acheteur
Hal 502
CCC No./N° CCC - FMS No./N° VME

ANNEX "C"

SECURITY REQUIREMENTS CHECK LIST

See attached.

ANNEX "D"

INSURANCE REQUIREMENTS

1. The Contractor must obtain Commercial General Liability Insurance, and maintain it in force throughout the duration of the Contract, in an amount usual for a contract of this nature, but for not less than \$2,000,000 per accident or occurrence and in the annual aggregate.

2. The Commercial General Liability policy must include the following:

a. Additional Insured: Canada is added as an additional insured, but only with respect to liability arising out of the Contractor's performance of the Contract. The interest of Canada should read as follows: Canada, as represented by Public Works and Government Services Canada.

b. Bodily Injury and Property Damage to third parties arising out of the operations of the Contractor.

c. Products and Completed Operations: Coverage for bodily injury or property damage arising out of goods or products manufactured, sold, handled, or distributed by the Contractor and/or arising out of operations that have been completed by the Contractor.

d. Personal Injury: While not limited to, the coverage must include Violation of Privacy, Libel and Slander, False Arrest, Detention or Imprisonment and Defamation of Character.

e. Cross Liability/Separation of Insureds: Without increasing the limit of liability, the policy must protect all insured parties to the full extent of coverage provided. Further, the policy must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.

f. Blanket Contractual Liability: The policy must, on a blanket basis or by specific reference to the Contract, extend to assumed liabilities with respect to contractual provisions.

g. Employees and, if applicable, Volunteers must be included as Additional Insured.

h. Employers' Liability (or confirmation that all employees are covered by Worker's compensation (WSIB) or similar program)

i. Broad Form Property Damage including Completed Operations: Expands the Property Damage coverage to include certain losses that would otherwise be excluded by the standard care, custody or control exclusion found in a standard policy.

j. Notice of Cancellation: The Insurer will endeavour to provide the Contracting Authority thirty (30) days written notice of policy cancellation.

k. If the policy is written on a claims-made basis, coverage must be in place for a period of at least 12 months after the completion or termination of the Contract.

l. Owners' or Contractors' Protective Liability: Covers the damages that the Contractor becomes legally obligated to pay arising out of the operations of a subcontractor.

m. Non-Owned Automobile Liability - Coverage for suits against the Contractor resulting

from the use of hired or non-owned vehicles.

n. Sudden and Accidental Pollution Liability (minimum 120 hours): To protect the Contractor for liabilities arising from damages caused by accidental pollution incidents.

ANNEX “E” to PART 3 OF THE REQUEST FOR STANDING OFFERS

ELECTRONIC PAYMENT INSTRUMENTS

The Offeror accepts to be paid by any of the following Electronic Payment Instrument(s):

- ☐ VISA Acquisition Card;
- ☐ MasterCard Acquisition Card;
- ☐ Direct Deposit (Domestic and International);
- ☐ Electronic Data Interchange (EDI);
- ☐ Wire Transfer (International Only);

ANNEX "F"

Standing Offer Reporting Form

Please fax to the Standing offer authority named herein.

Please use the Standing Offer number in the Subject line and clearly indicate:

- The standing offer number for which data is submitted;
- The period for which the data has been accumulated (start date to end date);
- The Department with whom the standing offer was arranged;
- The start date and the end date for the standing offer; and
- The total spend to date, by government department.

Standing Offer		(Insert Standing Offer #)	Start Date of SO (DD/MM/YYYY)	End Date of SO (DD/MM/YYYY)	
Total Value to Date (\$)		Total Value for Reporting Period (\$)	Start Reporting Period (DD/MM/YYYY)	End Reporting Period (DD/MM/YYYY)	
Department Requesting	Order Number	Work Description	Date of Order	Date of Delivery	Value of Order (not including HST)

ANNEX "G"

INTEGRITY PROVISIONS – LIST OF DIRECTORS

Please provide list of names of the following entities, according to the ownership nature of the company

1. For a Corporation - each current member of the Bidder's Board of Directors;

2. For a Partnership, General Partnership or Limited Partnership - the names of all current partners;

3. For a Sole Proprietorship or an individual doing business under a firm name - the name of the sole proprietor or individual;

4. In the case of a joint venture - For a Joint Venture - the names of all current members of the Joint venture;

5. For an individual - the full name of the person

DEPARTMENT OF NATIONAL DEFENCE



SPECIFICATION

ASPHALT PAVEMENT REPAIRS

2022

14 WING GREENWOOD,

GREENWOOD, NS

JOB NO. L-G111-9900/1135

2022-02-03

National Defence	List of Contents	Section	00000
14 Wing Greenwood N.S		Page 1	
Job No.L-G111-9900/1135		2022-02-03	

<u>Section</u>	<u>Title</u>	<u>Pages</u>
<u>Division 01 - General Requirements</u>		
01001	Summary of Work	2
01005	General Instructions	7
01410	Testing Laboratory Services	2
01545	Safety Requirements	2
01546	Fire Safety Requirements	3
01547	Hazardous Material	3
01560	Environmental Protection	3
01562	Environmental Protection Sedimentation Control	1
01563	Environmental Protection Refueling Vehicles	3
01570	Traffic Control	3
01600	Material and Equipment	1
01710	Cleaning	2
<u>Division 02 - Site work</u>		
02070	Site work Demolition and Removal	3
02223	Excavating, Trenching and Backfilling	9
02512	Hot Mix Asphalt Concrete	10
02580	Pavement Marking	3
02631	Manhole, Catch Basin and Valve Box Adjustments	4
02921	Topsoil and Finish Grading	6
02938	Sodding	4
<u>Division 03 - Concrete</u>		
03055	Concrete Cutting Portland Cement Concrete	2
03100	Formwork	2
03302	Cast-in-Place Concrete	2

National Defence	Summary of Work	Section 01001
14 Wing Greenwood N.S.		Page 1
Job No.L-G111-9900/1135		20-02-03

<u>1</u>	<u>Site Visit</u>	.1	Before submitting a Tender, the Contractor may visit the site and acquaint himself/herself with all ascertainable conditions that may affect the work.
<u>2</u>	<u>Location of Site</u>	.1	Canadian Forces Base 14 Wing Greenwood is located 150 km west of Halifax and 4 km south of Highway 101 near Kingston, Kings County, NS.
		.2	Camp Aldershot is located 50 km east of Canadian Forces Base Greenwood and 5 km north of Highway 101 near Kentville, Kings County, NS.
		.3	Middleton Armouries is located 12 km west of Canadian Forces Base Greenwood and 2 km south of Highway 101 near Middleton, Annapolis County, NS.
		.4	Yarmouth Armouries is located at 84 Parade Street, Yarmouth, NS.
<u>3</u>	<u>Description of Work</u>	.1	Work under this Standing Offer comprises the provision of all labour, material and equipment required to complete the work in accordance with the specifications for this project.
		.2	Work of this Standing Offer is located in an area where normal working hours are: .1 0730 to 1600 hours, Monday to Friday inclusive.
		.3	Specified work is to be carried out at the following location: .1 Operations Area, Domestic Area, Married Quarter Area, the Runways and Taxi-ways at 14 Wing Greenwood, Camp Aldershot and Middleton Armouries in the Province of NS. .2 14 Wing Greenwood is also responsible for maintaining a site on Stronach Mountain ASR Tower, Brickton Beacon near Middleton, Parker Road Beacon near Alyesford, Cloud Lake Air Cadet Camp, Granville Rifle Range near Annapolis Royal, Barrington Radar Tower Site and the Yarmouth Armouries. Requests for work
3	Description of Work	.3	(Cont'd)
		.2	(Cont'd)
	(Cont'd)		at these sites will require quotes and

Engineer's approval prior to any Work being performed.

- .4 In general terms, the work includes the following:
 - .1 Old asphalt removal and disposal.
 - .2 Common excavation, removal and disposal.
 - .3 Placing hot mixed asphalt complete with tack/coat and compaction by hand method.
 - .4 Placing hot mixed asphalt complete with tack/prime coat and compaction by spreader method.
 - .5 Placing Portland Cement Concrete Curbing complete with form work.
 - .6 Placing Hot Mixed Asphalt curbing complete with tack coat.
 - .7 Placing granular base courses (Class A gravel) complete with compaction to specified densities.
 - .8 Placing granular sub-base courses (Class B or C gravel) complete with compaction to specified densities.
 - .9 Scarifying, grading, placing granular materials (Class A), sweeping pavements and compacting road shoulders.
 - .10 Raising existing manholes, catch basins, water valve boxes and appurtenances effected by changing grades due to placement of Asphalt
 - .11 Placing form lumber for sidewalks.
 - .12 Placing topsoil.
 - .13 Placing sod.
 - .14 Repainting of pavement markings disturbed as a result of Work performed.
 - .15 Milling of asphalt surfaces.
 - .16 Milling of Portland Cement Concrete surfaces.
 - .17 Saw cutting of asphalt surfaces.

END

- | | | | |
|---|----------------------------|----|---|
| 1 | <u>Description of Work</u> | .1 | The Work under this Standing Offer comprises the furnishing of all necessary requirements for the completion of the Work as specified and/or shown in the following specification sections. |
| 2 | <u>References</u> | .1 | National Building Code of Canada (NBC) 2010 including all amendments up to tender closing date. |
| 3 | <u>Codes</u> | .1 | Perform work in accordance with the National Building Code (NBC) and National Fire Code (NFC) and/or any other code of provincial or local application provided that in any case of conflict or discrepancy, the more stringent requirements will govern. |
| | | .2 | Meet or exceed requirements of:
.1 Contract documents.
.2 Specified standards, codes and referenced documents. |
| | | .3 | References made to Domestic, national and International standards in this specification are to be considered an integral part thereof and to be read in conjunction with those specifications. |
| | | .4 | Obtain all written information from the described sources for references made to catalogues, detailed drawings or similar related data as published by Manufacturers and /or suppliers. |
| | | .5 | Trade names used in this specification are not necessarily restrictive unless specifically noted. |
| | | .6 | Workmanship to be of a uniformly high quality and in strict accordance with the best trade practices as interpreted by the Engineer. |
| | | .7 | Mediocre or inferior workmanship to be replaced by work of first class quality without cost to DND when so ordered by Engineer. |
| | | .8 | Conform to latest revisions and amendments of dated reference standards and be fully familiar with their contents and requirements. |
-

- 3 Codes
(Cont'd)
- .9 In the event of conflict in standards the most stringent standard to apply.
- 4 Documents Required
- .1 Maintain at job site, one copy each of following:
- .1 Specifications.
 - .2 Addenda.
 - .3 Change orders.
 - .4 Other modifications to Contract.
 - .5 Copy of approved work schedule.
 - .6 Manufacturers' installation and application instructions.
 - .7 Standards listed in Part 1 of Specification Sections under Reference Standards.
- 5 Work Schedule
- .1 Prior to Work commencement, the Contractor to arrange for an on-site meeting with the Engineer, to program starting dates, work schedules, and contract procedures for performing the work of this Contract.
- .2 Interim reviews of work progress based on work schedule and Requisitions against the Standing Offer will be conducted as decided by Engineer.
- .3 When Work schedule on Requisitions against the Standing Offer Agreement has been approved by Engineer take necessary measures to complete work within scheduled time.
- .4 Do not change schedules without Engineer's approval.
- 6 Briefing Requirements
- .1 Receive briefing from Wing Security Officer regarding Wing Security Regulations and restrictions.
- .2 Receive briefing from Wing Fire Chief regarding Wing Fire Safety Regulations and restrictions.
- .3 Receive briefing from Wing Air Traffic Control Officer regarding aircraft safety, travel to and across restricted areas and radio communications.
-

.3 Supply such devices as straight edges and templates required to facilitate Engineer's inspection of work.

- | | | |
|--|----|--|
| <u>10 Cutting,
and Patching</u> | .1 | Execute cutting (including excavation), fitting and patching required to make work fit properly. |
| | .2 | Where new work connects with existing and where existing work is altered, cut, patch and make good to match existing work. |
| | .3 | Make cuts with clean, true, smooth edges. Make patches inconspicuous in final assembly. |
| <u>11 Existing
Services</u> | .1 | Submit schedule to and obtain approval from Engineer for any shut-down or closure of active service or facility. Adhere to approved schedule and provide notice to affected parties. |
| | .2 | Where unknown services are encountered, immediately advise Engineer and confirm findings in writing. |
| <u>12 Alterations,
Additions or
Repairs to
Operations
Facilities</u> | .1 | Execute work with least possible interference or disturbance to operational facilities. Arrange with Engineer to facilitate execution of work. |
| | .2 | Provide temporary dust screens, covers, barriers, warning signs and any other safety, damage or contamination prevention devices required in locations where work is located in or adjacent to areas used by DND personnel. |
| | .3 | In the event that the work of this Contract affects Wing operations and /or equipment, Contractor is responsible for notification to Engineer, prior to any Work being performed. |
| <u>13 Additional
Drawings</u> | .1 | Engineer may furnish additional drawings to assist proper execution of work. These drawings will be issued for clarification only. Such drawings shall have same meaning and intent as if they were included with plans referred to in Contract documents. |
-

<u>14 Sanitary Facilities</u>	.1	Provide sanitary facilities in accordance with governing regulations and ordinances.
<u>15 Building Smoking Environment</u>	.1	Comply with smoking restrictions.
<u>16 Temporary Facilities</u>	.1	DND can provide, free of charge, temporary electric power and water for construction purposes.
	.2	Engineer to determine delivery points and quantitative limits. Engineer's written permission is required before any connection is made. Connect to existing power supply in accordance with Canadian Electrical Code.
	.3	Provide at no cost to DND, all equipment and temporary lines to bring these services to project site.
	.4	Supply of temporary services to Contractor is subject to DND requirements and may be discontinued by DND site representative at any time without notice, without acceptance of any liability for damage or delay caused by such withdrawal of temporary services.
	.5	Remove temporary facilities from site when directed by Engineer.
<u>17 Delivery and Storage</u>	.1	Provide secure temporary storage facilities for materials and equipment.
	.2	Deliver, store and maintain materials with manufacture's labels and seals intact.
	.3	Store materials in accordance with supplier's instructions and 14 Wing Standing Orders. Wing HAZMAT Co-ordinator Ext 5792 Mr A Pearson to approve storage and proper labelling of containers for items to be stored on DND sites.
	.4	Storage to be in areas with Engineer's approval and stored in a manner not detrimental to contaminating the Environment in the event of spills. Contractor to provide sufficient spill control materials at storage

- | | | |
|-------------------------------------|-----|---|
| 17 Delivery and Storage
(Cont'd) | .4 | (Cont'd)
site in event of spills for materials being stored. |
| | .5 | Provide and maintain dry storage. Items such as drums containing liquid asphalt to have secondary containment as part of their storage requirements. Storage to be in the area approved by Engineer. |
| | .6 | Maintain storage facilities premises in a neat and tidy condition at all times. |
| | .7 | Remove storage when directed by Engineer and soonest on completion of Work to be performed on the Standing Offer Agreement. |
| | .8 | Storage site subject to inspection by Wing Hazmat co-ordinator. All observations of improper storage to be rectified soonest to the direction of the Hazmat co-ordinator or Contractor's storage areas will not be permitted on DND property. |
| 17 Airport Requirements | .9 | Do not disrupt airport operations except as permitted by Engineer. |
| | .10 | Provide barricades and lights as directed. |
| | .11 | Active Areas: In areas of airport not closed to aircraft traffic:
.1 Obtain Engineer's approval on scheduling of work.
.2 Control movement of equipment and personnel as directed by Engineer.
.3 Provide competent flag person at locations designated by Engineer to relay signals from airport traffic control tower to equipment and personnel wishing to cross live traffic areas.
.4 Signals from airport traffic control tower to be obeyed instantly. |
| | .12 | Unserviceable Areas: Mark off areas made unserviceable for aircraft by work of this Contract by providing plainly visible danger markings by day and red lights by night. Open flames and inflammable fuels not permitted. |
| | .13 | Park equipment not in use and stockpile materials so that their tops are below a 50 to 1 ratio from ends of usable landing strip and below 20 to 1 ratio from sides of aircraft |
-

National Defence	General Instructions	Section	01005
14 Wing Greenwood N.S		Page 7	
Job No.L-G111-9900/1135		2022-02-03	

17 Airport	.13	(Cont'd)
Requirements		traffic areas. Where directed, mark tops with
(Cont'd)		red lights.

3 Contractor's
Responsibilities
(Cont'd)

- .3 Where materials are specified to be tested,
and if decided by Engineer to test proposed
materials deliver representative samples in
required quantity to testing laboratory.
- .4 Pay costs for uncovering and making good work
that is covered before required inspection or
testing is completed and approved by Engineer.

- | | | |
|---------------------------------------|----|--|
| <u>1 Construction Safety Measures</u> | .1 | Observe construction safety measures required by Canadian Labour Code, Provincial Government Regulations, Workers' Compensation Board and municipal statutes and authorities. |
| | .2 | In event of conflict or discrepancy between any provisions of above authorities, Engineer will approve direction as to which requirements shall govern. |
| | .3 | The Contractor to comply with all standing orders or other regulations in force on the site where work is to performed. |
| | .4 | Contractor created hazards to be marked with warning signs and barriers. |
| | .5 | All protective devices, barriers, boarding and the like to be maintained in good order until completion of the work under this contract, or until removal is ordered by the Engineer. |
| | .6 | Supply and erect signs and warning devices as specified in Part D, Signs and Devices of manual titled Uniform Traffic Control Guide of Canada distributed by Roads and Transportation Association of Canada. |
| | .7 | Place signs and other devices in locations as recommended by said manual and/or where directed by Engineer. |
| | .8 | Meet with Engineer prior to commencement of Work to prepare list of signs and other devices required to perform Work. |
| | .9 | Continually maintain traffic control devices in use by:
.1 Checking signs daily for legibility, damage, suitability and location installed. Clean, repair or replace to ensure clarity and reflectance are maintained.
.2 Remove or cover signs which do not apply to conditions existing from day to day. |
| <u>2. Protection</u> | .1 | Prevent damage to buildings, landscaping, curbs, sidewalks, trees, fences and adjacent property. |
| | .2 | Work areas to be cleaned up daily. |
| | .3 | Removed materials to be disposed of daily. |
-

2. Protection
(Cont'd)
- .4 Keep vehicular traffic off newly repaired areas until pavement or installations have set or cured to within standard requirements.
 - .5 Comply with requirements of Acts, Regulations and By-laws in force for regulation of traffic or use of any roadway upon or over which it is necessary to carry out work or haul materials or equipment.
 - .6 When working on a travelled way:
 - .1 Place equipment in such a position as to prevent a minimum of interference and hazard to travelling public.
 - .2 Keep equipment units as close together as working conditions permit and preferably on same side of travelled way.as possible
 - .3 Do not leave equipment on travelled way overnight.
 - .4 Contractor is responsible for the security of Equipment and is at no times to leave the vehicle while the equipment is operating or engine running.
 - .7 Do not close any lanes of traffic without approval of Engineer. Prior to re-routing traffic erect suitable signage and devices to Engineer's approval.
 - .8 Provide means of temporary detours around construction work in a manner authorized and approved by Engineer. Surfaces to be maintained to ensure a smooth riding surface.
 - .9 Provide flagman and traffic control devices in accordance with Provincial regulations and Nova Scotia safety Council recommendations.

PART 1 - GENERAL

1.1 Fire Department Briefing .1 Engineer will coordinate arrangements for the contractor to be briefed on Fire Safety at their pre-work conference by Fire Chief before any work is commenced.

1.2 Reporting Fires .1 Know the location of nearest fire alarm box and telephone, including the emergency phone number.

.2 Report immediately all fire incidents to the Fire Department as follows:

.1 activate nearest fire alarm box; or

.2 telephone.

.3 Person activating fire alarm box will remain at the box to direct Fire Department to scene of fire.

.4 When reporting a fire by telephone, give location of fire, name or number of building and be prepared to verify the location.

1.3 Fire Extinguishers .1 Supply fire extinguishers, as scaled by Fire Chief, necessary to protect, the work in progress and the contractors physical plant on site.

1.4 Blockage of Roadways .1 Advise Fire Chief of any work that would impede fire apparatus response. This includes violation of minimum overhead clearance, as prescribed by fire chief, erecting of barricades and the digging of trenches.

1.5 Smoking Precautions .1 Observe at all times smoking regulations.

1.6 Rubbish and Waste Materials .1 Rubbish and waste materials are to be kept to a minimum.

.2 The burning of rubbish is prohibited.

END

1.6 Rubbish and
Waste Materials
(Cont'd)

- .3 Removal:
 - .1 Remove all rubbish from the work site at the end of the work day or shift or as directed.
- .4 Storage:
 - .1 Store oily waste in approved receptacles to ensure maximum cleanliness and safety.
 - .2 Deposit greasy or oily rags and materials subject to spontaneous combustion in an approved receptacles and remove as required in 1.8.3.1.

1.7 Flammable and
Combustible Liquids

- .1 The handling, storage and use of flammable and combustible liquids are to be governed by the current National Fire Code of Canada.
 - .2 Flammable and combustible liquids such as gasoline, kerosene and naphtha will be kept for ready use in quantities not exceeding 45 litres provided they are stored in approved safety cans bearing the Underwriter's Laboratory of Canada or Factory Mutual seal of approval. Storage of quantities of flammable and combustible liquids exceeding 45 litres for work purposes, requires the permission of the Fire Chief.
 - .3 Transfer of flammable and combustible liquids is prohibited within buildings or jetties.
 - .4 Transfer of flammable and combustible liquids will not be carried out in the vicinity of open flames or any type of heat-producing devices.
 - .5 Flammable liquids having a flash point below 38°C such as naphtha or gasoline will not be used as solvents or cleaning agents.
 - .6 Flammable and combustible waste liquids, for disposal, will be stored in approved containers located in a safe ventilated area. Quantities are to be kept to a minimum and the Fire Department is to be notified when disposal is required.
-

1.8 Questions and/or Clarification	.1 Direct any questions or clarification on Fire Safety in addition to above requirements to_ Fire Chief.
--	---

1.9 Fire Inspection	.1 Site inspections by Fire Chief will be coordinated through Engineer.
	.2 Allow Fire Chief unrestricted access to the work site.
	.3 Co-operate with the Fire Chief during routine fire safety inspection of the work site.
	.4 Immediately remedy all unsafe fire situations observed by the Fire Chief.

- 1 General
- .1 Contractors and their personnel to read and be familiar with this section and its requirements.
 - .2 Contractor to post, in a noticeable location on job site, the following names and emergency telephone numbers:
 - .1 14 Wing Greenwood:
 - .1 Wing Fire Chief (WFC) - Local 5473.
 - .2 Engineer's delegated representative Local 1531.
 - .3 911.
 - .3 Work with hazardous materials to be done by workers who are thoroughly educated to the risks and handling procedures involved with the material and are trained in safe work practices.
 - .4 Encounters with material suspected of being hazardous and not previously identified are to be reported to Engineer immediately, and work in this area of project halted until direction is received from Engineer.
 - .5 Contractors are to comply with regulations and procedures or Federal, Provincial and local area environmental protection agency when dealing with hazardous materials.
 - .6 Inquiries regarding Hazardous Materials can be directed to Engineer.
- 2 Reference Standards
- .1 NFC-2005 - National Fire Code of Canada 2005.
 - .2 CLC-Part IV - Canada Labour Code.
 - .3 WHMIS - Workplace Hazardous Materials Information System (Federal Legislation Bill C-70).
 - .4 Hazardous Products Act.
 - .5 Hazardous Materials Information Review Act.
 - .6 Occupational Health and Safety Regulations.
 - .7 Regulations and standards currently in force for products not covered under WHMIS legislation, designed for the regulation of
-

- 2 Reference Standards (Cont'd) .7 (Cont'd)
specific categories of products such as but not limited to:
.1 Explosives Act.
.2 Atomic Energy Control Act.
.3 Pest Control Products Act.
- 3 Documentation .1 Where Contractor supplied materials or chemicals are of a hazardous nature, provide Engineer with two copies of Material Safety Data Sheet (MSDS) for each hazardous product.
.1 Hazardous products that do not have a Material Safety Data Sheet are not permitted on DND property.
.2 Information (MSDS) on known or suspected hazardous materials on site can be obtained through Engineer from the Hazardous Materials Coordinator.
- 4 Signs and Notices .1 Contractor to make available a copy of the Material Safety Data Sheet for each product on site, for the information of site workers and visitors to the site.
.1 Site workers to familiarize themselves with the Material Safety Data Sheet for each product.
.2 Signs and/or notices for safety and instruction to be in both official languages, or commonly understood WHMIS symbols, and to be posted in prominent locations around area of work.
- 5 Worker Safety .1 Workers involved with hazardous materials on jobsite to be equipped with all necessary personal protective equipment (PPE) required by Labour Canada and/or Provincial Labour Department.
- 6 Indemnity .1 Contractor accepts liability and indemnifies the Department of National Defence and its employees in the event of injury or damage resulting from the use of or exposure to hazardous materials.
-

- 7 Compliance .1 In event of conflict between the requirements referred to throughout this section and in paragraph 2 - Reference Standards, the more stringent requirement to govern.
- 8 Delivery and Storage .1 In addition to requirements of Section 01005 - General Instructions, deliver and store hazardous materials to the following:
.1 Incompatible substances and chemicals to be kept segregated at all times.
.2 Contractor can obtain clarification and identification of subject substances and chemicals through Engineer from Base Hazardous Materials Coordinator.
- 9 Spills and Leaks .1 Notify Wing Fire Department and Engineer at 14 Wing CFB Greenwood immediately in the event of a spill or leak. Wing Fire Chief will coordinate and direct clean-up.
.2 Prevent injury to personnel until responsible authorities arrive and implement procedures necessary to contain and secure spill area.
.3 Spills and leaks resulting from Contractor neglect or mishandling to be cleaned up at Contractor's expense.
- 10 Clean-up .1 Additional requirements to Section 01710 - Cleaning are listed below:
.1 All hazardous material waste to be stored in containers as recommended by manufacturer of hazardous material and removed from site at end of each work day.
.2 Disposal of waste material to be in accordance with the Department of the Environment regulations and to be off DND property at approved dump sites for materials to be disposed of.

-
- 1 Fires .1 Fires and burning of rubbish on site not permitted.
- 2 Disposal of Wastes .1 Do not bury rubbish and waste materials on site.
- .2 Do not dispose of waste or volatile materials, such as mineral spirits, oil or paint thinner into waterways, storm or sanitary sewers.
- .3 Disposal of wastes to be at approved dump sites for intended materials.
- 3 Pollution Control .1 Maintain temporary erosion and pollution control features installed under this contract.
- .2 Control emissions from equipment and plant to local authorities emission requirements.
- .3 Prevent sandblasting and other extraneous materials from contaminating air beyond application area, by providing temporary enclosures when directed by Engineer.
- .4 Cover or wet down dry materials and rubbish to prevent blowing dust.
- .5 Remove rubbish from site daily to prevent blowing debris.
- .6 Provide dust control for temporary and permanent access and haul routes, located near airfield, within base, or near residential areas.
- .7 Prevent silt from entering watercourses and/or drainage structures. Provide silt screens when directed by Engineer.
- .8 Provide silt and erosion control devices in accordance with Nova Scotia Department of Environments "Handbook for Construction Sites" and as determined by Engineer.
-

4.0 Equipment &
Fueling

- .1 All Equipment to be used on site to be inspected by Engineer to ascertain condition of equipment in regards to petroleum product leakage. Equipment not in good repair to be refused on site until leaks have been repaired to the satisfaction of Engineer.
- .2 Refueling of equipment to be performed in a location approved by Engineer, and to be a minimum of 30 metres from a watercourse or storm drainage inlet such as a catch basin grating.
- .3 Refueling to be performed on a hardstand where possible and on ground that is uniformly level in grade.
- .4 Contractor to report all petroleum spills regardless of size to Engineer and Wing Environment Office. Spills exceeding 75 litres to be reported to the Provincial Department of Environment through Engineer.
- .5 Contractor to maintain on site a spill control kit being a minimum of a shovel, a 45 gallon container, and absorbent materials of sufficient quantities for the petroleum products being used by the equipment on site. Quantities to be determined by Wing Hazmat Co-ordinator Mr A Pearson at Ext 5792.
- .6 Contractor to receive briefing by Wing Hazmat Co-ordinator in regards to spills on work sites.
- .7 Contractor is responsible to pay costs for spill clean-ups.
- .8 Contractor to perform clean-ups soonest and as directed by Engineer.
- .9 Equipment parked overnight or on DND property to to be parked in location as directed by Engineer and to have metal drip pans secured in place & placed beneath equipment to protect against petroleum products contaminating the soils. Protection provided to be to Engineer's approval.
- .10 Contractor storage of petroleum products to be in location and manner as approved by Wing Hazmat Co-ordinator containers properly marked in accordance with WHMIS legislation. Wing Hazmat Co-ordinator to provide direction in briefing to Contractor.

National Defence	Environmental	Section 01560
14 Wing Greenwood N.S	Protection	Page 3
Job No.L-G111-9900/1135		2022-02-03

4.0 Equipment & Fueling (Cont'd)	.11 Petroleum products stored on DND property to be removed immediately on completion of the Work of a Project.
--	---

National Defence	Environmental Protection	Section	01563
14 Wing Greenwood N.S	Sedimentation Control	Page	1
Job No.L-G111-9900/1135			2000-02-03

- 1 References
- .1 Nova Scotia Provincial Department of
Environment's "Handbook for Construction
Sites" most recent edition.

1 Refueling

- .1 Refueling of equipment at 14 Wing Greenwood to be performed in locations as directed by Engineer.
 - .2 Do not refuel equipment within 30 metres of any watercourse or storm water catch basin unless protection against spills is in place and location is approved by Engineer.
 - .3 Use petroleum containers approved for products with no spill fill spouts for dispensing fuels. The sure pour nozzle to have self closing valve, prevent any flow of fuel until the nozzle is inserted into the receiving container. On removal from the receiving container the slide valve closes to eliminate any fuel spill. Nozzle to be equipped with its own automatic vent eliminating the need for the user to open or close air inlets on the pouring container.
 - .4 Nozzle to support the weight of the pouring container. Nozzles to automatically stop the flow when the receiving container becomes full. The nozzle to be such that it reduces evaporative losses of volatile organic compounds during the fuel transfer.
 - .5 All spills of hydrocarbon based products such as gasoline, kerosene, naptha, lubricating oils, engine oils, greases and de-icing fluids or antifreeze no matter how large or small to be reported to Engineer.
 - .6 Oil changes in the field or on DND land are not permitted.
 - .7 Refueling to be performed on level surfaces, PCC Portland cement concrete or HMA surfaces when approved by the Engineer unless otherwise directed.
 - .8 Contractor to have drip pans sized for amounts of product to be recovered and customized to fit under pieces of equipment to perform maintenance to equipment while maintaining equipment on property. Drip Pans to be used whenever leaving equipment on site or parking overnight when not in use.
 - .9 Parking of equipment on site to be on level ground in locations approved by Engineer. Equipment with leaks to be removed from site when so ordered by Engineer.
-

- 2 Spill Control Kits.1 Contractor to have at the work site a spill control kit consisting of the following minimum types of equipment:
- .1 a spaded shovel;
 - .2 a stable broom;
 - .3 a broad nosed shovel;
 - .4 a container(s) suitable, compatible to and of sufficient size to contain petroleum products being used with equipment;
 - .5 Absorbents;
 - .6 rags;
 - .7 metal container for soiled rags;
 - .8 Booms when working next to a watercourse that will traverse the width of the watercourse by two times; and
 - .9 Spill control kit to be inspected and approved by Wing Environment Office prior to Work commencing. Spill control kits to be available to Contractor employees at all areas where Work of the Contract is being performed and at all times during the course of the Contract.
 - .10 Contractor employees to be trained in the use of the spill control kit and the equipment they contain.
-
- 3 Spills .1 Disposal of spilled materials to be off DND property and at approve locations for materials to be disposed of.
- .2 When parking of equipment on site, the equipment is to be secured from entry, inspected for leaks and the ground protected from leaks.
 - .3 Contractor to protect all wells, catch basins, drywells, drains and watercourses from contamination in event of a spill.
 - .4 All equipment to be used for the Work of the Contract to be inspected by the Engineer for leaks. Equipment not in good repair to be removed/repaired when directed by Engineer.
 - .5 Spills in excess of 74 litres to be reported immediately to the Wing Environment Officer and the Nova Scotia Provincial Department of the Environment.
 - .6 For spills occurring the Contractor to immediately remove as much or all of the contaminated soils created by the spill from Work of the Contractor as possible.

National Defence	Environmental Protection	Section	01563
14 Wing Greenwood N.S	Refueling Vehicles	Page	3
Job No. L-G111-9900/1135			2022-02-03

- | | | | |
|---|----------|----|--|
| 3 | Spills | .7 | Contaminated soils/materials to be placed in |
| | (Cont'd) | | containers compatible to the contaminants. |
| | | .8 | Any remaining clean-up to be performed at no |
| | | | extra cost to DND. Clean-ups to be to the |
| | | | Engineer's satisfaction. |

<u>1</u>	<u>References</u>	.1	Uniform Traffic Control Devices for Canada, (UTCD) January 1976 (distributed by Transportation Association of Canada).
<u>2</u>	<u>Protection of Public Traffic</u>	.1	Comply with requirements of Acts, Regulations and By-Laws in force for regulation of traffic or use of roadways upon or over which it is necessary to carry out work or haul materials or equipment.
		.2	When working on travelled way: <ul style="list-style-type: none"> .1 Place equipment in position to present minimum of interference and hazard to travelling public. .2 Keep equipment units as close together as working conditions will permit and preferably on same side of travelled way. .3 Do not leave equipment on travelled way overnight.
		.3	Do not close any lanes of road or highway without approval of Engineer. Before re-routing traffic erect suitable signs and devices in accordance with instructions contained in Part D of UTCD.
		.4	Keep travelled way well graded, free of pot holes and of sufficient width that required number of lanes of traffic may pass. <ul style="list-style-type: none"> .1 Provide minimum 7 m wide temporary roadway for traffic in two-way sections through work and on detours. .2 Provide minimum 5 m wide temporary roadway for traffic in one-way sections through work and on detours.
		.5	As indicated, or if directed by Engineer, provide graveled detours or temporary roads to facilitate passage of traffic around restricted construction area.
<u>3</u>	<u>Informational and Warning Devices</u>	.1	Provide and maintain signs, flashing warning lights and other devices required to indicate construction activities or other temporary and unusual conditions resulting from project work which may require road user response.
		.2	Supply and erect signs, delineators, barricades and miscellaneous warning devices as specified in Part D, Temporary Conditions Signs and Devices, of UTCD manual.

- 3
Informational and Warning Devices
(Cont'd)

.3
Place signs and other devices in locations recommended in UTCD manual.
- .4

Meet with Engineer prior to commencement of work to prepare list of signs and other devices required for project. If situation on site changes, revise list to approval of Engineer.
- .5

Continually maintain traffic control devices in use by:

.1
Checking signs daily for legibility, damage, suitability and location. Clean, repair or replace to ensure clarity and reflectance.

.2
Removing or covering signs which do not apply to conditions existing from day to day.

4
Control of Public Traffic

.1
Provide flag persons, trained in accordance with, and properly equipped as specified in, UTCD manual in following situations:

.1
When public traffic is required to pass working vehicles or equipment which may block all or part of travelled roadway.

.2
When it is necessary to institute one-way traffic system through construction area or other blockage where traffic volumes are heavy, approach speeds are high and traffic signal system is not in use.

.3
When workers or equipment are employed on travelled way over brow of hills, around sharp curves or at other locations where oncoming traffic would not otherwise have adequate warning.

.4
Where temporary protection is required while other traffic control devices are being erected or taken down.

.5
For emergency protection when other traffic control devices are not readily available.

.6
In situations where complete protection for workmen, working equipment and public traffic is not provided by other traffic control devices.

.7
At each end of restricted sections where pilot cars are required.

.8
Delays to public traffic due to contractor's operators not to exceed 15 min.

National Defence	Traffic Control	Section	01570
14 Wing Greenwood N.S		Page 1	
Job No.L-G111-9900/1135		2022-02-03	

5 Operational

- Requirements
- .1 Maintain existing conditions for traffic throughout period of contract except that, when required for construction under contract and when measures have been taken as specified herein and approved by Engineer to protect and control public traffic, existing conditions may be restricted.
 - .2 Maintain existing conditions for traffic crossing right-of-way containing work.
 - .3 Maintain existing conditions for traffic crossing right-of-way containing work except that, when required for construction under this Contract and when measures have been taken as specified herein and approved by Engineer to protect and control public traffic, existing conditions for cross traffic may be restricted.

- 1 General .1 Use new material and equipment unless otherwise specified.
- .2 Within 7 days of written request by Engineer, submit following information for materials and equipment proposed for supply:
- .1 name and address of manufacturer,
- .2 trade name, model and catalogue number,
- .3 performance, descriptive and test data,
- .4 manufacturer's installation or application instructions,
- .5 evidence of arrangements to procure.
- .3 Use products of one manufacturer for material and equipment of same type or classification unless otherwise specified.
- 2 Manufacturers .1 Unless otherwise specified, comply with_
- Instructions manufacturer's latest printed instructions for materials and installation methods.
- .2 Notify Engineer in writing of any conflict between these specifications and manufacturers instructions. Engineer will designate which document is to be followed.
- 3 Conformance .1 When material or equipment is specified by standard or performance specifications, upon request of Engineer, obtain from manufacturer an independent testing laboratory report, stating that material or equipment meets or exceeds specified requirements.

- | | | | |
|----------|-----------------------------|----|--|
| <u>1</u> | <u>General</u> | .1 | Conduct cleaning and disposal operations daily and to comply with local ordinances and anti- pollution laws. |
| | | .2 | Store volatile waste in covered metal containers, and remove from premises at end of each working day. |
| | | .3 | At all times be extremely cautious that no debris or other hazardous impediments are left lying in locations that cause unsafe conditions. |
| | | .4 | On completion of the Work of this contract all materials, equipment and debris to be left clean, neat and in a safe condition to the complete satisfaction of the Engineer. |
| <u>2</u> | <u>Materials</u> | .1 | Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer. |
| <u>3</u> | <u>Cleaning During Work</u> | .1 | Provide on-site containers for collection of materials, and debris daily and resulting from Work of this Contract.
.1 On-site containers to be equipped with secure lids to prevent debris from being wind carried. |
| | | .2 | Contractor to be responsible for preventing FOD (Foreign Object Damage) from debris resulting from work of this contract. This is terminology used in an Airport environment and pertains to debris being wind carried and/or deposited on active runways and taxiways within the Aerodrome. |
| | | .3 | Dispose of waste materials and debris when directed by Engineer and at approved dump site for material to be disposed of off DND property. |
| | | .4 | Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems. |
| | | .5 | Contractor to ensure that clean-up of debris resulting from milling work is completed daily and to the satisfaction of the Engineer. |

- 4 Final Cleaning .1 Clean lighting reflectors, lenses, and other lighting surfaces contaminated by the Work being completed under this contract.
- .2 Broom clean paved surfaces; rake clean other surfaces of grounds. Contractor to be vigilant in clean-up of debris from millings.
- .3 Advise Engineer on completion of each clean-up.

PART 1 - GENERAL

- | | | |
|--|----|---|
| <u>1.1 Protection</u> | .1 | Protect existing items designated to remain and materials designated for salvage. In event of damage, immediately replace such items or make repairs to approval of Engineer and at no additional cost to Engineer. |
| | .2 | Protect surrounding surfaces from damage due to work of this section. Make good such damage to satisfaction of Engineer and at no additional cost. |
| <u>1.2 Environmental Conditions</u> | .1 | Provide adequate nuisance dust protection, masks and ear protection to operator. |
| | .2 | Provide adequate ventilation adjacent to work area. |
| <u>1.3 Concrete Cutting</u> | .1 | Contractor to cut asphalt concrete where required using jackhammer unless approved otherwise by Engineer. |
| | .2 | Conduct cutting operations during periods scheduled by Engineer to reduce noise to Building and MQ occupants. |
| <u>1.4 Contractor's Responsibilities</u> | .1 | Furnish labour and facilities to: |
| | .1 | Provide access to work requiring cutting. |
| | .2 | Make good work disturbed by Cutting. |
| | .3 | Provide storage on site for cutting specialists equipment and tools. |
-

PART 2 - PRODUCTS

- 2.1 Equipment .1 Impact hammers: lightweight not exceeding 23 kg in mass. If powered by compressed air use air line oil trap.
- .2 Arrange with Engineer when required for provision of water and electricity for use during wet-cutting operations are required.

PART 3 - EXECUTION

- 3.1 Preparation .1 Inspect site and verify with Engineer items designated for removal and items to be preserved for each area of Work.
- .2 Locate and protect utility lines. Preserve in operating condition active utilities traversing site.
- .3 Notify utility companies before starting demolition.
- .4 Do not commence work until all electrical and mechanical services likely to be encountered in the process of the cut have been identified and disconnected.
- .5 Define exactly, outline of area to be cut and removed, and mark with indelible lines. All quantities and thicknesses to be determined with and provided to Engineer in writing.
- .6 Advise Engineer prior to commencing cutting.
- .7 Engineer to approve areas, quantities, thicknesses and type of cutting method to be used or identified prior to any cutting.
- 3.2 Removals .1 Remove items identified in scope and as required to carry out work of this contract.
- .2 Do not disturb adjacent items designated to remain in place.
-

3.3 Cutting,
General

- .1 Cut to depth required for repair.
- .2 Cut surfaces to be smooth, plane and parallel unless otherwise specified.
- .3 Remove all debris and clean surfaces of loose material.
- .4 Where complete section cannot be removed by cutting or milling alone, use light jackhammering or other chipping tools to avoid damaging surrounding areas and loss of bond in remaining concrete.
- .5 Remove all asphaltic concrete required to perform work specified and as approved by Engineer.

3.4 Disposal of
Material

- .1 Dispose of materials not designated for salvage or re-use in work, at approved locations for materials to be disposed of, off DND property.

3.5 Restoration

- .1 Upon completion of work, remove debris, trim surfaces and leave work site clean.
- .2 Reinstate areas and existing works outside areas of demolition disturbed as a result of this contract to conditions that existed prior to commencement of work.

PART 1 - GENERAL

- 1.1 Definitions .1 Rock excavation: excavation of material from solid masses of igneous, sedimentary or metamorphic rock which, prior to its removal, was integral with its parent mass, and boulders or rock fragments having individual volume in excess of 1 m³.
- .2 Common excavation: excavation of materials of whatever nature, which are not included under definitions of rock excavation including dense tills, hardpan, frozen materials and partially cemented materials which can be ripped and excavated with heavy construction equipment.
- .3 Topsoil: material capable of supporting good vegetative growth and suitable for use in top dressing, landscaping and seeding.
- 1.2 Protection of Existing Features .1 Existing buried utilities and structures:
- .1 Engineer to process CE Work Clearance Request for each site in accordance with CE Standard Operating Procedures prior to commencement of any work of this contract.
- .2 Contractor to maintain copies of the approved clearance request on site during work of this contract.
- .3 Prior to commencing any excavation work, notify applicable owner or authorities, establish location and state of use of buried utilities and structures. Clearly mark such locations to prevent disturbance during work.
- .4 Confirm locations of buried utilities by careful hand excavated test holes.
- .5 Maintain and protect from damage, water, sewer, electric, telephone and other utilities and structures encountered. Obtain direction of Engineer before moving or otherwise disturbing utilities or structures.
- .6 Advise Engineer to re-route existing lines in area of excavation. Costs for such work will be paid by Engineer.
- .7 Record location of maintained, re-routed and abandoned underground lines to Section 01720 - Project Record Documents.
- .2 Existing buildings and surface features:
- .1 Conduct, with Engineer, condition survey of existing buildings, trees and other plants, lawns, fencing, service poles, wires, rail

1.2 Protection of Existing Features
(Cont'd)

- .2 (Cont'd)
- .1 (Cont'd)
- tracks and paving, survey bench marks and monuments which may be affected by work.
- .2 Protect existing buildings and surface features which may be affected by work from damage while work is in progress and repair damage resulting from work.
- .3 Where excavation necessitates root or branch cutting, do so only as approved by Engineer.

1.3 Shoring, Bracing and Underpinning

- .1 Comply with Section 01545 - Safety Requirements and applicable local regulations and to protect existing features.
- .2 Engage services of qualified professional engineer who is registered in Canada province or territory in which work is to be carried out to design and inspect cofferdams, shoring, bracing and underpinning required for work.
- .3 At least 1 week prior to commencing work, submit design and supporting data.
- .4 Design and supporting data submitted to bear the stamp and signature of qualified professional engineer registered in Canada in the Province of Nova Scotia.
- .5 Professional engineer responsible for design of temporary structures to submit proof of insurance coverage for professional liability except where engineer is employee of contractor, in which case contractor shall submit proof that work by professional engineer is included in contractor's insurance coverage.

1.4 Inspection .1

- Immediately following Contract award and prior to commencing work, inform Engineer of proposed source of fill materials and provide access for inspection and sampling.
-

PART 2 - PRODUCTS

- 2.1 Fill Materials .1 Type 1 fill:
- .1 Class "A" gravel to Nova Scotia
Department of Transportation Specification
dated January 1980 (revised March 1, 1991),
Division 3, Section 6.

<u>Sieve Designation</u>	<u>% Passing</u>
20 000	100
14 000	50-85
5 000	20-50
160	0-10
80	0-7

- .2 Type 2 fill:
- .1 Class "C" gravel to Nova Scotia
Department of Transportation Specification
dated January 1980 (revised January 4, 1990),
Division 3, Section 4.

<u>Sieve Designation</u>	<u>% Passing</u>
56 000	100
28 000	60-80
5 000	25-45
160	0-10

- .3 Type 3 fill:
- .1 Selected material from excavation
approved by Engineer for use intended,
unfrozen and free from rocks larger than 75
mm, cinders, ashes, sods, refuse or other
deleterious materials.
- .4 Type 4 fill:
- .1 Selected material from an excavation
outside the project parameters, approved by
Engineer for use intended, unfrozen and free
from rocks larger than 75 mm, cinders, ashes,
sods, refuse or other deleterious materials.
Material to be practically free from silt or
clay with 50% passing a 14 000 sieve.

- 2.2 Bedding and Surround Material .1 Granular material to following requirements:
- .1 Crushed or screened stone, gravel or
sand consisting of hard durable particles free
from clay lumps, cementation, organic
material, frozen material and other
deleterious materials.

- 2.2 Bedding and Surround Material (Cont'd)
- .1 (Cont'd)
- .2 Gradations to be within limits specified when tested to ASTM C 136-95a and ASTM C 117-95. Sieve sizes to CAN/CGSB-8.1-88.

Sieve Designation	% Passing
12.5 mm	100
9.5 mm	-
4.75 mm	80-100
2.00 mm	50-90
0.425 mm	10-50
0.180 mm	-
0.075 mm	0-10

PART 3 - EXECUTION

- 3.1 Site Preparation
- .1 Remove obstructions, ice and snow, from surfaces to be excavated within limits indicated.
- .2 Cut pavement or sidewalk neatly along limits of proposed excavation in order that surface may break evenly and cleanly.

- 3.2 Stripping of Topsoil
- .1 Do not handle topsoil while in wet or frozen condition or in any manner in which soil structure is adversely affected.
- .2 Commence topsoil stripping of areas as indicated as directed by Engineer after area has been cleared of brush weeds and grasses and removed from site.
- .3 Strip topsoil to depths as indicated as directed by Engineer. Avoid mixing topsoil with subsoil.
- .4 Stockpile in locations as indicated directed by Engineer. Stockpile height not to exceed 2 m.
- .5 Dispose of unused topsoil to location as indicated as directed by Engineer off site.

- 3.3 Stockpiling
- .1 Stockpile fill materials in areas designated by Engineer. Stockpile granular materials in manner to prevent segregation.

- | | | |
|-----------------------------|----|--|
| 3.3 Stockpiling
(Cont'd) | .2 | Protect fill materials from contamination. |
|-----------------------------|----|--|
-
- | | | |
|---|----|--|
| 3.4 Cofferdams,
Shoring, Bracing
and Underpinning | .1 | Construct temporary works to depths, heights and locations as indicated or directed by_ Engineer approved by Engineer. |
| | .2 | During backfill operation: <ul style="list-style-type: none"> .1 Unless otherwise indicated or directed by Engineer Consultant, remove sheeting and shoring from excavations. .2 Do not remove bracing until backfilling has reached respective levels of such bracing. .3 Pull sheeting in increments that will ensure compacted backfill is maintained at an elevation at least 500 mm above toe of sheeting. |
| | .3 | When sheeting is required to remain in place, cut off tops at elevations indicated or directed by Engineer Consultant. |
| | .4 | Upon completion of substructure construction: <ul style="list-style-type: none"> .1 Remove cofferdams, shoring and bracing. .2 Remove excess materials from site and restore water courses to conditions indicated or as directed by Engineer Consultant. |
| | .5 | Obtain permit from authority having jurisdiction for temporary diversion of water course. |
-
- | | | |
|----------------|----|--|
| 3.5 Dewatering | .1 | Keep excavations free of water while work is in progress. |
| | .2 | Protect open excavations against flooding and damage due to surface run-off. |
| | .3 | Dispose of water in a manner not detrimental to public and private property, or any portion of work completed or under construction. |
| | .4 | Submit for Engineer's review approval details of proposed dewatering methods, such as dikes or well points. |
| | .5 | Provide flocculation tanks, settling basins, or other treatment facilities to remove suspended solids or other materials before |

- 3.5 Dewatering .5 (Cont'd)
(Cont'd) discharging to storm sewers, water courses or drainage areas.
- 3.6 Excavation .1 Advise Engineering advance of excavation operations to enable original cross sections to be taken.
- .2 Excavate to lines, grades, elevations and dimensions indicated as directed by Engineer.
- .3 Remove concrete masonry paving walks demolished foundations and rubble and other obstructions encountered during excavation.
- .4 Excavation must not interfere with normal 45° splay of bearing from bottom of any footing.
- .5 Do not disturb soil within branch spread of trees or shrubs that are to remain. If excavating through roots, excavate by hand and cut roots with sharp axe or saw. Seal cuts with approved tree wound dressing.
- .6 For trench excavation, unless otherwise authorized by Engineer in writing, do not excavate more than 30 m of trench in advance of installation operations and do not leave open more than 15 m at end of day's operation.
- .7 Dispose of surplus and unsuitable excavated material in approved location on site off site.
- .8 Do not obstruct flow of surface drainage or natural watercourses.
- .9 Earth bottoms of excavations to be undisturbed soil, level, free from loose, soft or organic matter.
- .10 Notify Engineer when soil at bottom of excavation appears unsuitable and proceed as directed by Engineer.
- .11 Obtain Engineer approval of completed excavation.
- .12 Remove unsuitable material from trench bottom to extent and depth directed by Engineer.
-

- 3.6 Excavation
(Cont'd)
- .13 Where required due to unauthorized over-excavation, correct as follows:
- .1 Fill under bearing surfaces and footings with concrete specified for footings fill concrete.
 - .2 Fill under other areas with Type 2 fill compacted to minimum of 95% in accordance with Section - 02501 - Corrected Maximum Dry Density.
- .14 Hand trim, make firm and remove loose material and debris from excavations. Where material at bottom of excavation is disturbed, compact foundation soil to density at least equal to undisturbed soil. Clean out rock seams and fill with concrete mortar or grout to approval of Engineer.
- 3.7 Fill Types and
Compaction
- .1 Use fill of types as indicated or specified below. Compaction densities are percentages of maximum densities obtained from ASTM D 698-91 ASTM D 1557-91.
- .1 Exterior side of perimeter walls: Use Type 3 fill to subgrade level. Compact to 95% in accordance with Section 02501 - Corrected Maximum Dry Density.
 - .2 Within building area: use Type 2 to underside of base course for floor slabs. Compact to 98% in accordance with Section 02501 - Corrected Maximum Dry Density.
 - .3 Under concrete slabs: provide 150 mm compacted thickness base course of Type 1 fill topped with shearmat filler as indicated to underside of slab. Compact base course to 100% in accordance with Section 02501 - Corrected Maximum Dry Density.
 - .4 Retaining walls: use Type 2 fill to subgrade level on high side for minimum 500 mm from wall and compact to 95% in accordance with Section 02501 - Corrected Maximum Dry Density. Use Type 3 fill compacted to 95% in accordance with Section 02501 - Corrected Maximum Dry Density.
 - .5 Underground services:
 - .1 Install bedding and surround materials.
 - .2 Sanitary and storm sewer pipe and conduit protective cover: cradle half diameter of pipe or conduit using 150 mm depth of Type 1 fill. After pipe or conduit is in place, cover with 300 mm depth of Type 1 fill.
-

- 3.7 Fill Types and Compaction (Cont'd)
- .1 (Cont'd)
- .5 Underground services:(Cont'd)
- .3 Cable and cable duct bedding and immediate protective cover: cover bottom of trench with 150 mm of Type 1 fill. After cables and ducts are in place, side fill ducts with sand up to top of ducts. Tamp around ducts with hand tampers and cover to level of treated planking with 150 mm of same material.
- .4 Fill above protective cover: in areas within buildings and where paving and walks occur, fill remainder of trench with Type 1 fill. In other areas, fill to subgrade level using Type 3 fill.
- .5 Compaction: compact bedding and immediate protective cover to 80% minimum density. In areas within buildings and where paving and walks occur, compact remainder of fill to at least 95% density. In other areas compact remainder of fill to at least 85% density.
- .6 Notify Engineer 3 days prior to backfilling of trenches for electrical services.

- 3.8 Backfilling
- .1 Do not proceed with backfilling operations until Engineer has inspected and approved installations.
- .2 Areas to be backfilled to be free from debris, snow, ice, water and frozen ground.
- .3 Do not use backfill material which is frozen or contains ice, snow or debris.
- .4 Backfilling around installations.
- .1 Place bedding and surround material as specified.
- .2 Do not backfill around or over cast-in-place concrete within 24 h after placing.
- .3 Place layers simultaneously on both sides of installed work to equalize loading. Difference not to exceed 1 m.
- .4 Where temporary unbalanced earth pressures are liable to develop on walls or other structures:
- .1 Permit concrete to cure for minimum 14 days or until it has sufficient strength to withstand earth and compaction pressure and approval obtained from Engineer:
-

- 3.8 Backfilling (Cont'd)
- .4 (Cont'd)
- .2 If approved by Engineer erect bracing or shoring to counteract unbalance, and leave in place until removal is approved by Engineer.
- .5 Place material by hand under, around and over installations until 300 mm of cover is provided. Dumping material directly on installations will not be permitted.
- .5 Install drainage filter system in backfill as directed by Engineer.
- .6 Place backfill material in uniform layers not exceeding 150 mm compacted thickness up to grades indicated. Compact each layer before placing succeeding layer.
- 3.9 Inspection and Testing
- .1 Testing of materials and compaction will be carried out by testing laboratory designated by Engineer. Frequency of tests will be determined by Engineer.
- .2 Engineer will pay costs for inspection and testing in accordance with Section 01410 - Testing Laboratory Services.
- 3.10 Restoration
- .1 Upon completion of work, remove surplus materials and debris, trim slopes, and correct defects noted by Engineer.
- .2 Replace topsoil as directed by Engineer.
- .3 Reinstate pavement and sidewalks lawns to condition and elevation which existed before excavation.
- .4 Clean and reinstate areas affected by work as directed by Engineer.

PART 1 - GENERAL

- 1.1 References .1 Nova Scotia Department of Transportation Specification dated January 1980 including all amendments.
- .2 Nova Scotia Department of the Environment's "Handbook for Construction Sites".
- .3 Asphalt in Pavement Maintenance (The Asphalt Institute) March 1993 Manual Series No 16 (MS-16) Edition.
- 1.2 Material Certification .1 Submit manufacturer's test data and certification that Hot Mixed Asphalt Concrete meets requirements of this section.
- 1.3 Delivery .1 Furnish copies of freight and way bills for asphalt cement as shipments are received and only when requested by Engineer.
- 1.4 Protection .1 Keep vehicular traffic off newly paved areas until paving surface temperature has cooled below 38°C. Do not permit stationary loads on pavement for 24 hours after placement.
- .2 Arrange paving schedule so as not to interfere with normal operations in the immediate area.
- .3 Work to be performed within the time window stated on the requisition unless otherwise directed.
- 1.5 Definitions .1 **Engineer:** the Wing Construction Engineer Officer and/or the delegated representative. The delegated project manager for this Standing Offer Agreement is Mr. J McMaster at 902-765-1494 Ext 1531.
- .2 **Old Asphalt and Concrete Removal:** to include the cutting, removal and disposal of defective asphalt and Portland cement concrete surfaces in place.
-

1.5 Definitions (Cont'd)	.3	Common Excavation: to include the excavation, removal and disposal of the granular base courses and all material below the asphalt.
	.4	Asphalt/Tack Coat: to include the supply, application of tack/prime coat, placement of HMAC, and compaction of Asphalt to 98 % of the Marshall Test Specimen Density. The Type of mix to be as specified by Engineer.
	.5	Gravel in place: to include the supply, placement and compaction of the gravel to 98 % of Standard Proctor Density.
	.6	HMAC: Hot Mixed Asphaltic Concrete.
	.7	PCC: Portland Cement Concrete.
1.6 Measurement for Payment	.1	Contractor to provide Engineer with service slips defining item and quantities of work performed daily.
	.2	Pricing to be in accordance with the Contract documents.
	.3	Advise Engineer soonest when quantities and/or dollar values are 75 % expended.
1.7 Requisitioning Services	.1	The services to be performed to include the furnishing of all labour, material, and equipment on an as and when required basis for the repair of defective pavement both asphalt and concrete surfaces at 14 Wing Canadian Forces Base Greenwood, Camp Aldershot and Middleton Armouries in the Province of Nova Scotia.
	.2	Services to be requisitioned against the Standing Offer Agreement on PWCGS Form 942 (Requisition against a Standing Offer Agreement)
	.3	Requisitions to identify the following: <ul style="list-style-type: none"> .1 Area of Work. .2 Schedule of Work. .3 Scope of Work to be performed. .4 Estimated cost of Work.
	.4	Invoicing to be submitted for each Requisition and to reflect the Requisition number assigned.

PART 2 - PRODUCTS

- 2.1 Materials .1 Mixture Type B, C, and D as described in Division 4, Section 4 of the Province of Nova Scotia Department of Transportation Specification dated 1 January 1980.
- .2 Granular Materials: Class "A" and "C" gravels as described in Division 3, Section 6 and Section 4 of the Province of Nova Scotia Department of Transportation Specification dated 1 January 1980.
- .3 Tack/Prime Coat: RC 70 or RS-1 to the Province of Nova Scotia Department of Transportation Specification dated 1 January 1980. Contractor to submit MSDS sheets for these products to Engineer including alternatives. Upon request by Engineer, submit manufacturer's test data and certification that asphalt tack/prime coat material meets requirements of this section.
- .4 Asphalt Concrete Curbs and Gutters: to Division 4 Section 3 of the Province of Nova Scotia Department of Transportation Specification dated 1 January 1980.
- .5 PCC Curb and Gutter: to Division 5 Section 16 of the Province of Nova Scotia Department of Transportation Specification dated 1 January 1980.
- 2.2 HMAC Mixing .1 Mix aggregates and asphalt cement in proportions to meet following criteria based on Standard Marshall Test procedure ASTM D 1559-89 with compactive effort of 50 blows on each face of specimen:
- .1 Stability: 4.5 kN.
- .2 Flow index: 2.0 - 4.0 minimum.
- .3 Air Voids: 3 - 5% corrected for volume of asphalt absorbed into aggregates to ASTM D 3203-94.
- .4 Minimum percentage void in mineral aggregate of 15%.
- .5 Asphalt cement: to CAN/CGSB-16.3-M90, grade 85-100.
-

- 2.3 Equipment .1 Rollers, general: sufficient number of rollers of type and weight to obtain specified density of compacted mix. All thicknesses identified in this section are compacted thicknesses.
- .2 Vibratory Rollers:
.1 Maximum amplitude of vibration (machine setting): 0.5 mm for lifts less than 40 mm thick.
- .3 Haul trucks: of adequate size, speed and condition to ensure orderly and continuous operation and as follows:
.1 Boxes with tight metal bottoms.
.2 Covers of sufficient size and weight to completely cover and protect asphalt mix when truck fully loaded.
.3 In cool weather or for long hauls, insulate entire contact area of each truck box.
.4 Trucks which cannot be weighed in a single operation on scales supplied will not be accepted.
- .4 Hand tools:
.1 Lutes or rakes with covered teeth for spreading and finishing operations.
.2 Tamping irons having mass not less than 12 kg and a bearing area not exceeding 310cm² for compacting material inaccessible to roller. Mechanical compaction equipment, when approved by Engineer, to be used instead of tamping irons wherever possible.
.3 Straight edges, 4.5 m in length, to test finished surface.
- .5 Milling Machine: capable of milling a minimum of 500 mm width and 50 mm depth in one pass. To be specifically designed for Portland cement concrete milling. Performance of a test strip for milling to be made prior to work commencing and prior to equipment being approved for use.
-

PART 3 - EXECUTION

- 3.1 Plant and Mixing Requirements .1 To ASTM D 995-88 - Specification for Requirements for Mixing Plants for Hot Mixed, Hot Laid, Bituminous Paving Mixtures.
- 3.2 Milling .1 Mill surfaces in locations as directed and where marked by Project Manager.
- .2 The depths and widths of milling is dependent on the condition of the Asphalt in place and is to be as directed by Engineer.
- .3 Paverlane joints and transverse cracks to be milled to a minimum width of 500 mm. Engineer to inspect milled trench and Contractor to remove additional widths of deteriorated asphalt until sound material is found. All Work to be as approved and directed by Engineer
- .4 All milled asphalt or Portland cement concrete to be removed and disposed of as directed by Engineer. Disposal of milled asphalt on DND property to be in locations with gravel hardstands to upgrade their surfaces. Grading of milled materials to be performed by others unless otherwise directed by Engineer.
- .5 All milled asphalt or Portland cement concrete identified to be disposed of off DND property to be at an approved dumpsite for materials being disposed of. Provide Engineer with letter from applicable municipal unit approving such a disposal.
- .6 Do NOT place tack coat or new asphalt until milled surfaces, joint or crack has been cleaned, inspected and approved by Engineer.
- 3.3 Old HMAC and PCC Removals .1 Cut and remove asphalt from areas as directed by the Project Manager.
- .2 Use approved method to cut asphalt.
- .3 Prevent damage to asphalt and concrete surfaces to remain.
-

- | | | |
|--|----|--|
| 3.3 Old HMAC and
PCC Removals
(Cont'd) | .4 | Prevent excessive disturbance to granular base courses. |
| | .5 | Remove and dispose of old asphalt off site as directed by Engineer. |
| 3.4 Common
Excavation | .1 | Excavate granular base courses to suitable depths as determined by Engineer. |
| | .2 | Remove unsuitable subgrade materials to depths as directed by Engineer. |
| | .3 | Remove large rocks, boulders and cobbles that have worked into the granular base courses. |
| | .4 | Avoid undermining of the granular base courses for existing asphalt to remain. |
| | .5 | Remove and dispose of old asphalt and Portland cement concrete off DND property at site approved for subject materials. |
| 3.5 Granular
Material Placement | .1 | Granular Base Courses:
.1 Compact subgrade, granular sub-base and granular base where applicable and/or directed by Engineer to 98 % Standard Proctor Density.
.2 Place and compact granular courses in lifts of 150 mm maximum compacted thickness. |
| 3.6 Tack Coat
Application | .1 | Prior to laying mix, clean surfaces of loose and foreign material. |
| | .2 | Obtain Engineer's approval of surface before applying asphalt tack coat. |
| | .3 | Dilute asphalt emulsion with water at 1:1 ratio for application. Mix thoroughly by pumping or other method approved by Engineer. |
| | .4 | Apply tack coat evenly to pavement surface at rate as directed by Engineer, but do not exceed 0.7 L/m ² . |
| | .5 | Apply only on dry surface. |
| | .6 | Paint contact surfaces of curbs, gutters, headers, manholes and like structures with thin, uniform coat of asphalt tack coat material. |

3.6 Tack Coat Application (Cont'd)

- .7 Do not apply asphalt tack coat when air temperature is less than 5°C or when rain is forecast within 2 h of application.
- .8 Apply tack coat only to surfaces that are expected to be overlayed on same day.
- .9 Evenly distribute localized excessive deposits of tack coat by brooming.
- .10 Where traffic is to be maintained, treat no more than one half of width of surface in one application.
- .11 Keep traffic off tacked areas until tack coat has set as directed by Engineer.
- .12 Re-tack contaminated or disturbed areas as directed by Engineer.
- .13 Permit tack coat to set before placing asphalt paving.

3.7 Transportation of Mix

- .1 Transport mix to job site in vehicles cleaned of foreign material.
- .2 Paint or spray truck beds with light oil, limewater, soap or detergent solution, at least once a day or as required. Elevate truck bed and thoroughly drain. No excess solution will be permitted.
- .3 Schedule delivery of material for placing in daylight, unless Engineer approves artificial light.
- .4 Deliver material to paver at a uniform rate and in an amount within capacity of paving and compacting equipment.
- .5 Deliver loads continuously in covered vehicles and immediately spread and compact. Deliver and place mixes at a temperature within range as directed by Engineer, but not less than 135°C.

3.8 Placing

- .1 Place asphalt concrete in compacted lifts of thickness as follows:
 - .1 For areas to be asphalted; Use Type C mix, 50 mm layers of compacted thickness

3.8 Placing
(Cont'd)

- .1 (Cont'd)
 - .1 (Cont'd)
unless otherwise directed by Engineer. Place other mixture types when directed by Engineer.
 - .2 Use spreader applications when directed by Engineer. Spreader applications can involve overlays and or sidewalk repairs.
- .2 Placing conditions:
 - .1 Place asphalt mixtures only when base or previous course is dry and air temperature is above 5°C.
 - .2 Minimum 135°C mix temperature required when spreading.
 - .3 Maximum 160°C mix temperature permitted at any time.
 - .4 When temperature of surface on which material is to be placed falls below 10°C, provide extra rollers as necessary to obtain required compaction before cooling.
 - .5 Do not place hot-mix asphalt when pools of standing water exist on surface to be paved, during rain, or when surface is damp.
 - .6 Place asphalt concrete in compacted layers not exceeding 50 mm.
- .3 Where possible do tapering and levelling where required in lower lifts.
- .4 Distribute material uniformly. Do not broadcast material.
- .5 During spreading operation, thoroughly loosen and uniformly distribute material by lutes or covered rakes. Reject material that has formed into lumps and does not break down readily.
- .6 After placing and before rolling, check surface with templates and straight edges and correct irregularities.
- .7 Provide heating equipment to keep hand tools free from asphalt. Avoid high temperatures which may burn material. Do not use tools at a higher temperature than temperature of mix being placed.
- .8 If segregation occurs, immediately suspend spreading operation until cause is determined and corrected.
- .9 Do not throw surplus material on freshly screeded surfaces.

- 3.8 Placing
(Cont'd)
- .10 When hand spreading is used:
- .1 Approved wood or steel forms, rigidly supported to assure correct grade and cross section, may be used. Use measuring blocks and intermediate strips to aid in obtaining required cross-section.
 - .2 Use forms where sidewalk overlays are requested.
 - .3 Forms to remain in place unless otherwise directed by engineer.
- 3.9 Compacting
- .1 Roll asphalt continuously to a density not less than 98% Standard Proctor density obtained with Marshall specimens prepared in accordance with ASTM D 1559-89 from samples of mix being used.
- .2 General:
- .1 Start rolling operations as soon as placed mix can bear weight of roller without undue displacement of material or cracking of surface.
 - .2 Operate roller slowly initially to avoid displacement of material. For subsequent rolling do not exceed 5 km/h for static steel-wheeled rollers and 8 km/h for pneumatic-tired rollers.
 - .3 Overlap successive passes of roller by at least one half width of roller and vary pass lengths.
 - .4 Keep wheels of roller slightly moistened with water to prevent pick-up of material but do not over-water.
 - .5 Do not stop vibratory rollers on pavement that is being compacted with vibratory mechanism operating.
 - .6 Do not permit heavy equipment or rollers to stand on finished surface before it has been compacted and has thoroughly cooled.
 - .7 After traverse and longitudinal joints and outside edge have been compacted, start rolling longitudinally at low side and progress to high side. Finish joint repair to be flat and match existing grades of surfaces with no irregularities in the transverse direction exceeding 5 mm and not uniformly high or low in the longitudinal direction.
 - .8 Where rolling causes displacement of material, loosen affected areas at once with lutes or shovels and restore to original grade of loose material before re-rolling.
-

- 3.9 Compacting (Cont'd) .3 Finish rolling:
.1 Accomplish finish rolling while material is still warm enough for removal of roller marks. If necessary to obtain desired surface finish, Engineer may specify use of pneumatic-tired rollers.
.2 Conduct rolling operations in close sequence.
.3 Compact mix with hot tampers or other equipment approved by Engineer in areas inaccessible to roller.
- 3.10 Joints .1 Construct feather joints so that thinner portion of joint contains fine graded material obtained by raking out coarse aggregate in mix. Place and compact joint so that joint is smooth and without visible breaks in grade.
.2 Locate feather joints where new asphalt meets existing asphalt.
- 3.11 Finish Tolerances .1 Finished asphalt surface to be within 5 mm of profiles indicated on drawings but not uniformly high or low.
.2 Finished asphalt surface not to have irregularities exceeding 5 mm when checked with a 4.5 m straight edge placed in any direction.
- 3.12 Defective Work .1 Correct irregularities which develop before completion of rolling by loosening surface mix and removing or adding material as required. If irregularities or defects remain after final compaction, remove surface course promptly and lay new material to form a true and even surface and compact immediately to specified density.

PART 1 - GENERAL

- | | | |
|--|----|--|
| <u>1.1 Reference Standards</u> | .1 | Uniform Traffic Control Devices of Canada (1976). |
| <u>1.2 Coordination and Scheduling</u> | .1 | Contractor to notify Engineer prior to commencing work. |
| | .2 | Contractor to be responsible for close coordination of all work. |

PART 2 - PRODUCTS

- | | | |
|-----------------------------------|----|--|
| <u>2.1 Materials</u> | .1 | Paint: <ul style="list-style-type: none">.1 To CGSB 1-GP-74M, alkyd traffic paint..2 To CGSB 1-GP-149M, alkyd reflectorized traffic paint..3 Colour: to CGSB 1-GP-12c Standard Paint Colours.<ul style="list-style-type: none">.1 yellow 505-308..2 white 513- 301..3 black 512-301..4 blue 502-105 |
| | .2 | Thinner: to CAN/CGSB-1.5-M91. |
| | .3 | Glass beads: <ul style="list-style-type: none">.1 Overlay type: to CGSB 1-GP-74M, sprinkled via a hopper immediately following spray nozzles. |
| <u>2.2 Equipment Requirements</u> | .1 | Painting Equipment: <ul style="list-style-type: none">.1 Pressurized bead dispensing to achieve proper bead application and reflectivity with minimum application rate of 1 litre per 4 m²..2 Paint rollers and brushes for other markings as approved by Engineer. |
-

PART 3 - EXECUTION

- | | | | |
|-----|----------------------------|-----|--|
| 3.1 | <u>Surface Preparation</u> | .1 | Removal of pavement markings when required to be by paint method using masking paint colour black in areas as directed by Engineer. |
| | | .2 | Pavement surface to be free from surface water, frost, ice, dust, oil, grease and other foreign materials deleterious to making a good bond between pavement and paint |
| 3.2 | <u>Application</u> | .1 | Pavement markings to be painted to widths, layouts and dimensions in accordance with Uniform Traffic Control Guide and as identified by Engineer. |
| | | .2 | Unless otherwise approved by Engineer apply paint only when air temperature is above 10°C and no precipitation is forecast. |
| | | .3 | Apply traffic paint to 5 mil thickness. |
| | | .4 | Do not thin paint unless approved by Engineer.
.1 Where approved, paint to be thinned to a maximum of 10%. |
| | | .5 | Centre line spaces at intersections to be determined by Engineer. |
| | | .6 | Painted lines to be of uniform colour and density with sharp edges. |
| | | .7 | Thoroughly clean distributor tank before refilling with paint of different colour. |
| | | .8 | Following cleaning of equipment tank, contents to be disposed of off DND property at approved dumpsite for materials to be disposed of. |
| | | .9 | Apply glass beads at a rate of 700 g/L of paint.
.1 Beads to be used with yellow paint only. |
| | | .10 | Engineer will test paint and check wet film thickness at periodic intervals. |
| | | .11 | Painting of markings to be restricted to areas where repairs to pavements have |

3.2 Application (Cont'd)	.11 (Cont'd) eliminated crucial markings for traffic safety.
-----------------------------	--

3.3 Protection of Completed Work	.1 Protect pavement markings until dry.
-------------------------------------	---

National Defence	Manhole, Catch Basin	Section	02631
14 Wing Greenwood N.S	And Valve Box	Page 1	
Job No.L-G111-9900/1135	Adjustments	2022-02-03	

PART 1 - GENERAL

- 1.1 References
- .1 ASTM A 48-94a, Specification for Gray Iron Castings.
 - .2 ASTM C 139-73(1989), Specification for Concrete Masonry Units for Construction of Catch Basins and Manholes.
 - .3 ASTM C 478M-94, Specification for Precast Reinforced Concrete Manhole Sections.
 - .4 ASTM D 698-91, Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort (600 kN-m/m³).
 - .5 CAN/CSA-A5-93, Portland Cement.
 - .6 CAN/CSA-A8-93, Masonry Cement.
 - .7 CAN/CSA-A23.1-94, Concrete Materials and Methods for Concrete Construction.
 - .8 CSA A82.56-M1976, Aggregate for Masonry Mortar.
 - .9 A165 Series-94 Series-M85, CSA Standards on Concrete Masonry Units.
 - .10 CAN/CSA-G30.18-M92, Billet Steel Bars for Concrete Reinforcement.
 - .11 CSA G164-M92, Hot Dip Galvanizing of Irregularly Shaped Articles.
- 1.2 Scheduling of Work
- .1 Schedule work to minimize interruptions to existing services and to maintain existing flow during construction.
- 1.3 Measurement for Payment
- .1 Adjusting tops of existing manholes, catch basins and/or Valve Boxes will be measured in units adjusted.

PART 2 - PRODUCTS

- 2.1 Materials .1 Cast-in-place concrete:
- .1 Cement: to CAN/CSA-A5-93, type 10.
 - .2 Concrete mix design to produce 21 MPa minimum compressive strength at 28 days and containing 25 mm maximum size coarse aggregate, with water/cement ratio to CAN/CSA-A23.1-94, for class C-4 exposure.
- .2 Mortar:
- .1 Aggregate: to CSA A82.56-1950(R71).
 - .2 Cement: to CAN/CSA-A8-93.
- .3 Adjusting rings: to ASTM C 478M-94.
- .4 Concrete Brick: to A165 Series-94 Series.
- .5 Frames, gratings, covers to dimensions as indicated and following requirements:
- .1 Metal gratings and covers to bear evenly on frames. A frame with grating or cover to constitute one unit. Assemble and mark unit components before shipment.
 - .2 Gray iron castings: to ASTM A 48-94a, strength class 30B.
 - .3 Castings: coated with two applications of asphalt varnish sand blasted or cleaned and ground to eliminate surface imperfections.
 - .4 Manhole frames and covers: heavy duty municipal type for road service; light duty for landscape service. Cover cast without perforations and complete with two 25 mm square lifting holes.
- .6 Valve Box Assembly: Standard of Acceptance Type V.I.3 piece slide type and associated components necessary to raise or lower tops to meet finished grades. Materials as supplied by Industrial Marine Products 15 Akerly Blvd, Dartmouth, NS PO Box 535. Components can consist of upper, lower, extensions and covers.
-

- 3.3 Adjusting Tops of Existing Units (Cont'd)
- .4 Monolithic units:(Cont'd)
- .2 Lower monolithic units with straight wall by removing concrete to elevation indicated for rebuilding.
- .3 When monolithic units with tapered upper section are to be lowered more than 150 mm, remove concrete for entire depth of taper plus as much straight wall as necessary, then rebuild upper section to required elevation with cast-in-place concrete.
- .5 Install additional manhole ladder rungs in adjusted portion of units as required.
- .6 Re-use existing gratings, frames and I beams.
- .7 Re-set gratings and frames to required elevation on not more than 4 courses of brick. Make brick joints and join brick to frame with cement mortar, parge and trowel smooth.
- .8 Re-set gratings and frames to required elevation on full bed of cement mortar, parge and trowel smooth.
- 3.4 Sealing over Existing Units
- .1 Cut galvanized iron sheet to extend 50 mm beyond opening of existing manhole or catch basin grating. Center iron sheet over existing grating and spot or stitchweld to grating.
- .2 Fill with material approved by Engineer.
- 3.5 Installation
- .1 Backfill using Class A gravel and compact granular backfill in all cases to 98% Standard Proctor Density to ASTM D 698-91.
- .2 Layer thickness when compacting not to exceed 150 mm.

PART 1 - GENERAL

1.1 Related Work .1 Sodding: Section 02938

1.2 Source Quality Control .1 Advise Engineer of sources of topsoil to be supplied and provide access for sampling.

.2 Contractor is responsible for soil analysis when requested by Engineer and requirements for amendments to supply topsoil as specified.

.3 Acceptance of topsoil subject to inspection and/or soil analysis test results. Do not commence work until topsoil accepted by Engineer.

PART 2 - PRODUCTS

2.1 Topsoil .1 Topsoil: friable, neither heavy clay nor of very light sandy nature consisting of 45% sand, 35% silt, 20% clay and pH value of 6-7. Free from subsoil, roots, vegetation, debris, toxic materials, stones over 50 mm dia.

.2 Fertilizer:

.1 Complete commercial synthetic fertilizer with minimum 65% insoluble nitrogen.

.2 Formulation ratio: 1:4:4.

.3 Bonemeal: finely ground with a minimum analysis of 20% phosphoric acid.

.3 Limestone:

.1 Ground agricultural limestone containing minimum 85% of total carbonates.

.2 Gradation requirements: percentage passing by weight, 90% passing 1.0 mm sieve, 50% passing 0.125 mm seive.

.4 Water: potable.

.5 Seed and Mixture:

.1 20% Kentucky Bluegrass.

.2 30% Creeping Red Fescue.

.3 10% Smooth Brome grass.

.4 15% Timothy.

.5 10% Annual Rye Grass.

.6 5% Alsike Clover.

- | | | |
|-------------------------|----|---|
| 2.1 Topsoil
(Cont'd) | .6 | In containers with original tags. |
| | .7 | Grass seed: Canada Certified No. 1 Grade in accordance with Government of Canada Seeds Act and Regulations. |

PART 3 - EXECUTION

- | | | |
|-----------------------------|----|--|
| 3.1 Stripping of
Topsoil | .1 | Do not handle topsoil while in wet or frozen condition or in any manner in which soil structure is adversely affected. |
| | .2 | Stockpile in locations as directed by Engineer. Stockpile height not to exceed 2 m. |
| | .3 | Dispose of unused topsoil where directed by Engineer off Work site. |
| | .4 | Protect stockpiles from contamination and compaction. |
-
- | | | |
|--------------------------------------|----|---|
| 3.2 Preparation of
Existing Grade | .1 | Verify that grades are correct. If discrepancies occur, notify Engineer and do not commence work until instructed by Engineer. |
| | .2 | Grade soil, eliminating uneven areas and low spots, ensuring positive drainage. |
| | .3 | Remove debris, roots, branches, stones in excess of 50 mm diameter and other deleterious materials. Remove soil contaminated with calcium chloride, toxic materials and petroleum products. Remove debris which protrudes more than 75 mm above surface. Dispose of removed material off DND property at approved dump sites. |
| | .4 | Course cultivate entire area which is to receive topsoil to depth of 100 mm. Cross cultivate those areas where equipment used for hauling and spreading has compacted soil. |

3.3 Placing and Spreading of Topsoil

- .1 Place topsoil after Engineer has accepted subgrade.
- .2 Spread topsoil in uniform layers not exceeding 150 mm unless directed otherwise by Engineer, over unfrozen subgrade free of standing water.
- .3 Spread topsoil as indicated to following minimum depths after settlement and 90% compaction:
 - .1 100 mm for seeded and areas to be sodded.
- .4 Manually spread topsoil around any obstacles.
- .5 Ensure areas be seeded have been cultivated to depth of 25 mm and are moist to depth of 150 mm before seeding. Fine grade free of humps and hollows and free of deleterious and refuse materials.
- .6 Obtain Engineer's approval of topsoil grade and depth before starting to seed.

3.4 Application of Limestone

- .1 For areas to be sodded or seeded: apply and mix limestone thoroughly into full specified depth of topsoil
 - .1 20 kg of lime per 100 m² of topsoiled area existing soil.

3.5 Application of Seed

- .1 Seed top dressed area using 1 kg grass seed per 100 m² with seed mixture
 - .2 For manual seeding:
 - .1 Use "Cyclone" type manually operated seeder.
 - .2 Use manually operated, water ballast, landscaping type, smooth steel drum roller. Ballast as directed by Engineer.
 - .3 Use equipment and method acceptable to Engineer.
 - .3 Blend applications 150 mm into adjacent grass areas or previous applications to form uniform surfaces.
 - .4 Sow half of required amount of seed in one direction and remainder at right angles as applicable.
-

3.5 Application of .5 Incorporate seed by light raking in cross
Seed directions.
(Cont'd)

.6 Consolidate mechanically seeded areas by rolling area with equipment approved by Engineer immediately after seeding.

3.6 Application of .1 Apply fertilizer at least one week after.
Fertilizer limestone application.

.2 Spread fertilizer uniformly over entire area of topsoil at rate determined on basis of soil sample test.

.3 Mix fertilizer thoroughly to full depth of topsoil.

3.7 Top Dressing .1 Top dress sodded areas with dry, friable and clean topsoil having high humus content.

.2 Spread topsoil to thickness of 5 to 10 mm, filling in low and bare spots.

.3 Overseed top dressed area using 1 kg grass seed per 100 m² with seed mixture of 50% Kentucky Blue grass and 50% Creeping Red Fescue or seed mixture as specified.

.4 Mix topsoil and seed by means of light raking. Roll with light roller and water, ensuring contact between sod, seed and top dressing.

.5 Water thoroughly and take precautions to prevent erosion of topsoil and seeding.

3.8 Finish Grading .1 Grade to eliminate rough spots and low areas and ensure positive drainage. Prepare loose friable bed by means of cultivation and subsequent raking.

.2 Consolidate topsoil to required bulk density using equipment approved by Engineer. Leave surfaces smooth, uniform and firm against deep footprinting.

- 3.8 Finish Grading .3 (Cont'd)
- Perform following operations from time of seed application until final acceptance by Engineer:
- .1 Water seeded area as required to ensure germination and continued growth of grass. Control watering to prevent washouts.
 - .2 Cut grass to 40 to 50 mm whenever it reaches height of 65 mm. Remove clippings which will smother grass.
 - .3 Fertilize seeded areas one month after seeding. Spread evenly and water in well. Use Type 2 fertilizer, ratio 2:1:1, at rate of 50 kg per hectare. Postpone fertilizing until following spring if application falls within four week period prior to expected end of local growing season.
 - .4 Repair dead or bare spots to allow establishment of seed prior to acceptance.
- 3.9 Maintenance .1
- Maintain seeded area from start of installation until final acceptance.
 - .2 Water seeded areas in sufficient quantities and at frequency required to maintain soil continuously moist to depth of 75 to 100 mm.
 - .3 Cut grass to 40 mm when it reaches height of 60 mm. Remove clippings which will smother grassed areas.
 - .4 Fertilize seeded areas one month after seeding with 2:1:1 ratio fertilizer. Spread evenly at rate of .5 kg of nitrogen/100m² and water in well.
- 3.10 Acceptance .1
- Engineer will inspect and test topsoil in place and determine acceptance of material, depth of topsoil and finish grading. Approval of topsoil material subject to soil testing and analysis.
 - .2 Testing of topsoil will be carried out by testing laboratory designated by Engineer. Soil sampling, testing and analysis to be in accordance with Provincial regulations and standards.

- 3.10 Acceptance .3 Areas will be accepted by Engineer provided
(Cont'd) that:
- .1 Seeded areas are uniformly established and turf is free of rutted, eroded, bare or dead spots.
 - .2 Seeded areas have been cut at least twice.
 - .4 Areas seeded in fall will be accepted in following spring one month after start of growing season provided acceptance conditions are fulfilled.
- 3.11 Restoration of .1 Restore stockpile sites acceptable to
Stockpile Sites Engineer.
- 3.12 Surplus .1 Dispose of materials not required when_
Material and where directed by Engineer off site.

PART 1 - GENERAL

- 1.1 Related Work .1 Topsoil and Finish Grading: Section 02921
- 1.2 Source Quality Control .1 Obtain approval from Engineer Consultant of sod at source.
- .2 When proposed source of sod is approved, use no other source without written authorization.
- 1.3 Scheduling .1 Schedule sod laying to coincide with preparation of soil surface.
- .2 Schedule sod installation after frost has left ground and before September 30.

PART 2 - PRODUCTS

- 2.1 Materials .1 Field sod: not sown or cultivated as turf grass crop but containing good percentage of common turf grasses and free of weeds, mosses and stones.
- .1 Fertilize field sod minimum 2 weeks prior to lifting with 2:1:1 ratio fertilizer at rate of 0.5 kg nitrogen/100 m².
- .2 Mow field sod within 36 h prior to lifting and remove clippings.
- .2 Water:
- .1 Supplied by Engineer at designation source.
- .2 Potable, free of impurities.
- .3 Fertilizer:
- .1 To Canada "Fertilizers Act" and "Fertilizers Regulations".
- .2 Complete, synthetic, slow release with 65% of nitrogen content in water-insoluble form.
-

PART 3 - EXECUTION

- 3.1 Preparation .1 Verify that grades are correct and prepared in accordance with Section 02921 - Topsoil and Finish Grading. If discrepancies occur, notify Engineer and do not commence work until instructed by Engineer.
- .2 Do not perform work under adverse field conditions such as frozen soil, excessively wet or dry soil or soil covered with snow, ice, or standing water.
- .3 Fine grade surface free of humps and hollows to smooth, even grade, to contours and elevations indicated, to plus or minus 15 mm for Field or Pasture Sod, surface to drain naturally.
- .4 Remove and dispose of weeds; debris; stones 50 mm in diameter and larger; soil contaminated by oil, gasoline and other deleterious materials; off site in location as directed by Engineer.
- .5 Cultivate fine grade to 25 mm depth immediately prior to sodding.
- 3.2 Sod Placement .1 Lay sod within 36 h of being lifted.
- .2 Lay sod sections in rows, longitudinally, along contours of slopes, joints staggered. Butt sections closely without overlapping or leaving gaps between sections. Cut out irregular or thin sections with sharp implements.
- .3 Roll sod as directed by Engineer. Provide close contact between sod and soil by light rolling. Use of heavy roller to correct irregularities in grade is not permitted.
- .4 Prior to sodding, obtain approval from Engineer that finished grade and depth of topsoil are satisfactory.
- .5 Water sod immediately after laying to obtain moisture penetration into top 100 mm of topsoil.
-

- 3.2 Sod Placement .6 Stake sod in place for steep slope and/or
(Cont'd)
- 3.3 Top Dressing .1 Top dress sodded areas with dry, friable and
clean topsoil having high humus content.
- .2 Spread topsoil to thickness of 5 to 10 mm,
filing in low and bare spots.
- .3 Over seed top dressed area using 1 kg
grass seed per 100 m* with seed mixture
of 50% Kentucky Blue grass and 50%
Creeping Red Fescue or as specified in
Section 02921.
- .4 Mix topsoil and seed by means of light raking.
Roll with light roller and water, ensuring
contact between sod, seed and top dressing.
- .5 Water thoroughly and take precautions to
prevent erosion of topsoil and seeding.
- 3.4 Maintenance .1 Maintain sodded area from start of
installation until final acceptance.
- .2 Water sodded areas in sufficient quantities
and at frequency required to maintain soil
under sod continuously moist to dept of 75 to
100 mm.
- .3 Cut grass to 40 mm when it reaches height of
60 mm. Remove clippings which will smother
grassed areas.
- .4 Fertilize sodded areas one month after sodding
with 2:1:1 ratio fertilizer. Spread evenly at
rate of .5 kg of nitrogen/100 m* and water in
well.
- 3.5 Acceptance .1 Field Sodded areas will be accepted by
Engineer provided that:
- .1 Sodded areas are properly established.
- .2 Extent of surface soil visible when grass
has been cut to height of 60 mm is acceptable.
- .3 Sod is free of bare or dead spots and
extent of weeds apparent in grass is
acceptable.
- .4 Sodded areas have been cut minimum 2
times, and within 24 h prior to acceptance.
-

- 3.5 Acceptance
(Cont'd)
- .1 (Cont'd)
 - .5 Fertilizing in accordance with fertilizer program has been carried out at least once.
 - .2 Areas sodded in fall will be accepted in following spring one month after start of growing season provided acceptance conditions are fulfilled.

PART 1 - GENERAL

- 1.1 Related Work .1 Site work Demolition and Removal: Section 02070
- 1.2 References .1 CAN/CSA-A23.1-94 - Concrete Materials and Methods of Concrete Construction.
- 1.3 Environmental Conditions .1 Provide adequate nuisance dust protection masks and ear protection to operator.
- .2 Provide adequate ventilation adjacent to work area.
- .3 Wet cutting only will be permitted unless directed otherwise by Engineer.
- 1.4 Protection .1 Protect surrounding surfaces from damage due to work of this section. Make good such damage to satisfaction of Engineer and at no additional cost.
- 1.5 Concrete Cutting .1 Contractor to cut concrete where required. Do NOT use jackhammer unless approved by Engineer and only for instances as outlined in paragraph 3.2.4 of this section.
- . 2 Concrete cutting is for both HMAC and PCC structures.
- 1.6 Contractor's Responsibilities .1 Furnish labour and facilities to:
- .1 Provide access to work requiring cutting.
- .2 Make good work disturbed by Cutting.
- .3 Provide storage on site for cutting specialists equipment and tools.
-

PART 2 - PRODUCTS

- 2.1 Materials .1 Arrange with Engineer for provision of water and electricity for use during cutting operation.
- .2 Concrete cutting saw to CSA C22.2-94 71.1-M89 - Portable Electric Tools.

PART 3 - EXECUTION

- 3.1 Preparation .1 Do not commence work until all electrical and mechanical services likely to be encountered in the process of the cut have been identified and disconnected.
- .2 Define exactly, outline of area to be cut and removed, and mark with indelible lines. All quantities and thicknesses to be determined with Engineer and provided to Engineer in writing.
- .3 Advise Engineer prior to commencing cutting.
- .4 Engineer to approve areas, quantities, and thicknesses identified prior to any cutting.
- 3.2 Cutting, General .1 Sawcut to depth required using a purpose made blade in a specialized concrete saw. Depth to be a minimum of 15 mm to avoid the necessity of feather edging.
- .2 Sawed surfaces to be smooth, plane and parallel unless otherwise specified.
- .3 Remove all debris and clean surfaces of loose material.
- .4 Where complete section cannot be removed by cut alone, use light jackhammering or other chipping tools to avoid damaging surrounding areas and loss of bond in remaining concrete.
- .5 Remove all concrete required to perform work specified and as approved by Engineer.
-

PART 1 - GENERAL

- 1.1 References .1 CAN/CSA-A23.1-94, Concrete Materials and Methods of Concrete Construction.
- .2 CAN3-O86-M84, Engineering Design in Wood (Working Stress Design).
- .3 CAN/CSA-O86.1-94, Engineering Design in Wood (Limit States Design).
- .4 CAN3-O86-M84, Supplement No. 1-1987, to CAN3-O86-M84, Engineering Design in Wood (Working Stress Design) and CAN/CSA-O86.1-94 Engineering Design in Wood (Limit States Design).
- .5 CSA O121-M1978, Douglas fir Plywood.
- .6 CAN/CSA-S269.3-M92, Formwork.

PART 2 - PRODUCTS

- 2.1 Materials .1 Formwork lumber: plywood and wood formwork materials to CSA O121-M1978 CAN3-O86-M84 CAN/CSA-O86.1-94 CAN3-O86-M84 CSA O153-M1980.
- .2 Form ties: removable or snap-off metal ties, fixed or adjustable length, free of devices leaving holes larger than 25 mm dia in concrete surface.
- .3 Form stripping agent: colourless mineral oil, free of kerosene, with viscosity between 70 and 110 s Saybolt Universal 15 to 24 mm²/s at 40°C, flashpoint minimum 150°C, open cup.
- .4 CSA B111-1974 Wire Nails, Spikes and Staples.
- .5 CSA O121-M1978 Douglas Fir Plywood.
- .6 CAN/CSA-O141-91 Softwood Lumber.
- .7 CSA O151-M1978 Canadian Softwood Plywood.
- .8 National Lumber Grades Authority (NLGA) Standard Grading Rules for Canadian Lumber 1991.

PART 3 - EXECUTION

- 3.1 Erection .1 Verify lines, levels and centres before proceeding with formwork and ensure dimensions agree with drawings.
- .2 Fabricate and erect formwork in accordance with CAN/CSA-S269.3-M92 to produce finished concrete conforming to shape, dimensions, locations and levels indicated within tolerances required by CAN/CSA-A23.1-94.
- .3 Align form joints and make watertight. Keep form joints to minimum.
- .4 Form chases, slots, openings, drips, recesses, expansion and control joints as indicated.
- .5 Clean formwork in accordance with CAN/CSA-A23.1-94, before placing concrete.
- .6 Leave formwork in place for following minimum periods of time after placing concrete.
.1 2 days for curbs.
- .7 Re-use formwork subject to requirements of CAN/CSA-A23.1-94.
-

PART 1 - GENERAL

- 1.1 Standard .1 Concrete materials and methods of construction: to CAN/CSA-A23.1-94 unless otherwise specified.
- 1.2 Inspection .1 Concrete testing: to CSA CAN3-A23.2-94 by testing laboratory designated and paid for by Engineer. Accelerated test methods will apply.
- .2 Give Engineer minimum 24 h notice before each concrete pour.

PART 2 - PRODUCTS

- 2.1 Materials .1 Cement: to CAN/CSA-A5-93, Type 10.
- .2 Joint sealer/filler: purpose-made, pourable or gun-grade type, grey in colour.
- .3 All other concrete materials: to CAN/CSA-A23.1-94.
- 2.2 Mix Proportions .1 Method: Alternative (1) of CAN/CSA-A23.1-94.
- .2 Cement type: as specified under 2.1.
- .3 Minimum 28 day compressive strengths and exposure classifications:
- .1 All concrete other than curb and gutters: 25 MPa; C-4.
- .2 PCC concrete: to be to NSDOT specifications for curbing, and curb and gutters 32 MPa.
- .4 Nominal size of coarse aggregate: Clause 14 of CAN/CSA-A23.1-94.
- .5 Slump: to Table 6 of CAN/CSA-A23.1-94.
- .6 Air content: all concrete to contain purposely entrained air in accordance with Table 10 of CAN/CSA-A23.1-94.
- .7 Admixtures: to Clause 6 of CAN/CSA-A23.1-94.

PART 3 - EXECUTION

- 3.1 Inserts .1 Cast in posts, braces and other inserts required to be built-in.
- .2 Ensure top surfaces of all concrete are convex in nature to provide positive drainage of water.
- .3 Seal all joints between steel posts and concrete with sealer to prevent water infiltration.
-
- 3.2 Finishes .1 Formed surfaces exposed to view: steel troweled finish to CAN/CSA-A23.1-94.
- .2 Provide radiused edges on top perimeter of all concrete as indicated or specified.
- .3 Curb profiles to be in accordance with NSDOT specifications.
-
- 3.3 Curing .1 Cure and protect concrete in accordance with CAN/CSA-A23.1-94, except that curing compounds shall not be used where bond is required by subsequent topping or coating.
-



SECURITY REQUIREMENTS CHECK LIST (SRCL)

LISTE DE VÉRIFICATION DES EXIGENCES RELATIVES À LA SÉCURITÉ (LVERS)

PART A - CONTRACT INFORMATION / PARTIE A - INFORMATION CONTRACTUELLE			
1. Originating Government Department or Organization / Ministère ou organisme gouvernemental d'origine DND		2. Branch or Directorate / Direction générale ou Direction RP Ops Det Greenwood	
3. a) Subcontract Number / Numéro du contrat de sous-traitance		3. b) Name and Address of Subcontractor / Nom et adresse du sous-traitant	
4. Brief Description of Work / Brève description du travail W6899-220085 - Standing Offer Agreement - Asphalt Repairs - 14 Wing Greenwood - SRCL to establish a Standing Offer Agreement to provide all labour, equipment and transportation for the repair and replacement of defective asphalt at 14 Wing Greenwood, Camp Aldershot, Middleton and Yarmouth Armouries under Job No. L-G111-9900/1135. Some Construction site are within Operations Zones, others are in Public/Reception Zones.			
5. a) Will the supplier require access to Controlled Goods? Le fournisseur aura-t-il accès à des marchandises contrôlées?		<input checked="" type="checkbox"/> No Non	<input type="checkbox"/> Yes Oui
5. b) Will the supplier require access to unclassified military technical data subject to the provisions of the Technical Data Control Regulations? Le fournisseur aura-t-il accès à des données techniques militaires non classifiées qui sont assujetties aux dispositions du Règlement sur le contrôle des données techniques?		<input checked="" type="checkbox"/> No Non	<input type="checkbox"/> Yes Oui
6. Indicate the type of access required / Indiquer le type d'accès requis			
6. a) Will the supplier and its employees require access to PROTECTED and/or CLASSIFIED information or assets? Le fournisseur ainsi que les employés auront-ils accès à des renseignements ou à des biens PROTÉGÉS et/ou CLASSIFIÉS? (Specify the level of access using the chart in Question 7. c) (Préciser le niveau d'accès en utilisant le tableau qui se trouve à la question 7. c)		<input checked="" type="checkbox"/> No Non	<input type="checkbox"/> Yes Oui
6. b) Will the supplier and its employees (e.g. cleaners, maintenance personnel) require access to restricted access areas? No access to PROTECTED and/or CLASSIFIED information or assets is permitted. Le fournisseur et ses employés (p. ex. nettoyeurs, personnel d'entretien) auront-ils accès à des zones d'accès restreintes? L'accès à des renseignements ou à des biens PROTÉGÉS et/ou CLASSIFIÉS n'est pas autorisé.		<input type="checkbox"/> No Non	<input checked="" type="checkbox"/> Yes Oui
6. c) Is this a commercial courier or delivery requirement with no overnight storage? S'agit-il d'un contrat de messagerie ou de livraison commerciale sans entreposage de nuit?		<input checked="" type="checkbox"/> No Non	<input type="checkbox"/> Yes Oui
7. a) Indicate the type of information that the supplier will be required to access / Indiquer le type d'information auquel le fournisseur devra avoir accès			
Canada <input type="checkbox"/>		NATO / OTAN <input type="checkbox"/>	Foreign / Étranger <input type="checkbox"/>
7. b) Release restrictions / Restrictions relatives à la diffusion			
No release restrictions Aucune restriction relative à la diffusion <input type="checkbox"/>		All NATO countries Tous les pays de l'OTAN <input type="checkbox"/>	No release restrictions Aucune restriction relative à la diffusion <input type="checkbox"/>
Not releasable À ne pas diffuser <input type="checkbox"/>			
Restricted to: / Limité à : <input type="checkbox"/>		Restricted to: / Limité à : <input type="checkbox"/>	Restricted to: / Limité à : <input type="checkbox"/>
Specify country(ies): / Préciser le(s) pays :		Specify country(ies): / Préciser le(s) pays :	Specify country(ies): / Préciser le(s) pays :
7. c) Level of information / Niveau d'information			
PROTECTED A PROTÉGÉ A <input type="checkbox"/>		NATO UNCLASSIFIED NATO NON CLASSIFIÉ <input type="checkbox"/>	PROTECTED A PROTÉGÉ A <input type="checkbox"/>
PROTECTED B PROTÉGÉ B <input type="checkbox"/>		NATO RESTRICTED NATO DIFFUSION RESTREINTE <input type="checkbox"/>	PROTECTED B PROTÉGÉ B <input type="checkbox"/>
PROTECTED C PROTÉGÉ C <input type="checkbox"/>		NATO CONFIDENTIAL NATO CONFIDENTIEL <input type="checkbox"/>	PROTECTED C PROTÉGÉ C <input type="checkbox"/>
CONFIDENTIAL CONFIDENTIEL <input type="checkbox"/>		NATO SECRET NATO SECRET <input type="checkbox"/>	CONFIDENTIAL CONFIDENTIEL <input type="checkbox"/>
SECRET SECRET <input type="checkbox"/>		COSMIC TOP SECRET COSMIC TRÈS SECRET <input type="checkbox"/>	SECRET SECRET <input type="checkbox"/>
TOP SECRET TRÈS SECRET <input type="checkbox"/>			TOP SECRET TRÈS SECRET <input type="checkbox"/>
TOP SECRET (SIGINT) TRÈS SECRET (SIGINT) <input type="checkbox"/>			TOP SECRET (SIGINT) TRÈS SECRET (SIGINT) <input type="checkbox"/>



PART A (continued) / PARTIE A (suite)

8. Will the supplier require access to PROTECTED and/or CLASSIFIED COMSEC information or assets?
Le fournisseur aura-t-il accès à des renseignements ou à des biens COMSEC désignés PROTÉGÉS et/ou CLASSIFIÉS? ☒ No ☐ Yes
Non Oui
If Yes, indicate the level of sensitivity:
Dans l'affirmative, indiquer le niveau de sensibilité :

9. Will the supplier require access to extremely sensitive INFOSEC information or assets?
Le fournisseur aura-t-il accès à des renseignements ou à des biens INFOSEC de nature extrêmement délicate? ☒ No ☐ Yes
Non Oui

Short Title(s) of material / Titre(s) abrégé(s) du matériel :

Document Number / Numéro du document :

PART B - PERSONNEL (SUPPLIER) / PARTIE B - PERSONNEL (FOURNISSEUR)

10. a) Personnel security screening level required / Niveau de contrôle de la sécurité du personnel requis

- | | | | |
|---|---|---|--|
| <input checked="" type="checkbox"/> RELIABILITY STATUS
COTE DE FIABILITÉ | <input type="checkbox"/> CONFIDENTIAL
CONFIDENTIEL | <input type="checkbox"/> SECRET
SECRET | <input type="checkbox"/> TOP SECRET
TRÈS SECRET |
| <input type="checkbox"/> TOP SECRET- SIGINT
TRÈS SECRET - SIGINT | <input type="checkbox"/> NATO CONFIDENTIAL
NATO CONFIDENTIEL | <input type="checkbox"/> NATO SECRET
NATO SECRET | <input type="checkbox"/> COSMIC TOP SECRET
COSMIC TRÈS SECRET |
| <input type="checkbox"/> SITE ACCESS
ACCÈS AUX EMPLACEMENTS | | | |

Special comments:

Commentaires spéciaux : _____

NOTE: If multiple levels of screening are identified, a Security Classification Guide must be provided.

REMARQUE : Si plusieurs niveaux de contrôle de sécurité sont requis, un guide de classification de la sécurité doit être fourni.

10. b) May unscreened personnel be used for portions of the work?
Du personnel sans autorisation sécuritaire peut-il se voir confier des parties du travail? ☐ No ☒ Yes
Non Oui
If Yes, will unscreened personnel be escorted?
Dans l'affirmative, le personnel en question sera-t-il escorté? ☒ No ☐ Yes
Non Oui
Unscreened Personnel may only access Public and Reception Zones

PART C - SAFEGUARDS (SUPPLIER) / PARTIE C - MESURES DE PROTECTION (FOURNISSEUR)

INFORMATION / ASSETS / RENSEIGNEMENTS / BIENS

11. a) Will the supplier be required to receive and store PROTECTED and/or CLASSIFIED information or assets on its site or premises?
Le fournisseur sera-t-il tenu de recevoir et d'entreposer sur place des renseignements ou des biens PROTÉGÉS et/ou CLASSIFIÉS? ☒ No ☐ Yes
Non Oui

11. b) Will the supplier be required to safeguard COMSEC information or assets?
Le fournisseur sera-t-il tenu de protéger des renseignements ou des biens COMSEC? ☒ No ☐ Yes
Non Oui

PRODUCTION

11. c) Will the production (manufacture, and/or repair and/or modification) of PROTECTED and/or CLASSIFIED material or equipment occur at the supplier's site or premises?
Les installations du fournisseur serviront-elles à la production (fabrication et/ou réparation et/ou modification) de matériel PROTÉGÉ et/ou CLASSIFIÉ? ☒ No ☐ Yes
Non Oui

INFORMATION TECHNOLOGY (IT) MEDIA / SUPPORT RELATIF À LA TECHNOLOGIE DE L'INFORMATION (TI)

11. d) Will the supplier be required to use its IT systems to electronically process, produce or store PROTECTED and/or CLASSIFIED information or data?
Le fournisseur sera-t-il tenu d'utiliser ses propres systèmes informatiques pour traiter, produire ou stocker électroniquement des renseignements ou des données PROTÉGÉS et/ou CLASSIFIÉS? ☒ No ☐ Yes
Non Oui

11. e) Will there be an electronic link between the supplier's IT systems and the government department or agency?
Disposera-t-on d'un lien électronique entre le système informatique du fournisseur et celui du ministère ou de l'agence gouvernementale? ☒ No ☐ Yes
Non Oui



PART C - (continued) / PARTIE C - (suite)

For users completing the form **manually** use the summary chart below to indicate the category(ies) and level(s) of safeguarding required at the supplier's site(s) or premises.

Les utilisateurs qui remplissent le formulaire **manuellement** doivent utiliser le tableau récapitulatif ci-dessous pour indiquer, pour chaque catégorie, les niveaux de sauvegarde requis aux installations du fournisseur.

For users completing the form **online** (via the Internet), the summary chart is automatically populated by your responses to previous questions.

Dans le cas des utilisateurs qui remplissent le formulaire **en ligne** (par Internet), les réponses aux questions précédentes sont automatiquement saisies dans le tableau récapitulatif.

SUMMARY CHART / TABLEAU RÉCAPITULATIF

Category Catégorie	PROTECTED PROTÉGÉ			CLASSIFIED CLASSIFIÉ			NATO				COMSEC					
	A	B	C	CONFIDENTIAL CONFIDENTIEL	SECRET	TOP SECRET TRÈS SECRET	NATO RESTRICTED NATO DIFFUSION RESTREINTE	NATO CONFIDENTIAL NATO CONFIDENTIEL	NATO SECRET	COSMIC TOP SECRET COSMIC TRÈS SECRET	PROTECTED PROTÉGÉ			CONFIDENTIAL	SECRET	TOP SECRET TRÈS SECRET
											A	B	C			
Information / Assets Renseignements / Biens																
Production																
IT Media / Support TI																
IT Link / Lien électronique																

12. a) Is the description of the work contained within this SRCL PROTECTED and/or CLASSIFIED?

La description du travail visé par la présente LVERS est-elle de nature PROTÉGÉE et/ou CLASSIFIÉE?



No
Non



Yes
Oui

If Yes, classify this form by annotating the top and bottom in the area entitled "Security Classification".

Dans l'affirmative, classifiez le présent formulaire en indiquant le niveau de sécurité dans la case intitulée « Classification de sécurité » au haut et au bas du formulaire.

12. b) Will the documentation attached to this SRCL be PROTECTED and/or CLASSIFIED?

La documentation associée à la présente LVERS sera-t-elle PROTÉGÉE et/ou CLASSIFIÉE?



No
Non



Yes
Oui

If Yes, classify this form by annotating the top and bottom in the area entitled "Security Classification" and indicate with attachments (e.g. SECRET with Attachments).

Dans l'affirmative, classifiez le présent formulaire en indiquant le niveau de sécurité dans la case intitulée « Classification de sécurité » au haut et au bas du formulaire et indiquer qu'il y a des pièces jointes (p. ex. SECRET avec des pièces jointes).