

---

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 RELATED SECTIONS

.1 Division 1 Specification Sections.  
.2 Section 26 05 01 - Common Work Results - Electrical.

1.3 PRODUCT DATA

.1 Submit product data in accordance with Division 1 Specification Sections.

PART 2 - PRODUCTS

2.1 DISCONNECT SWITCHES

.1 Fusible and non-fusible disconnect switch, sized as indicated.  
.2 Provision for padlocking in on-off switch position by three locks.  
.3 Mechanically interlocked door to prevent opening when handle in ON position.  
.4 Fuse holders: relocatable and suitable without adaptors, for type and size of fuse indicated.  
.5 Quick-make, quick-break action.  
.6 ON-OFF switch position indication on switch enclosure cover.  
.7 Heavy duty rated.  
.8 EEMAC 4X for exterior use and EEMAC 2 for interior use.

2.2 EQUIPMENT  
IDENTIFICATION

.1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.  
.2 Indicate name of load controlled on size 4 nameplate.

Neddy Harbour Development  
Norris Point, NL  
PN: C2-00205

Disconnect Switches  
Fused and Non Fused

Section 26 28 23  
Page 2

---

PART 3 - EXECUTION

3.1 INSTALLATION

.1 Install disconnect switches complete with  
fuses as indicated.