

---

PART 1 - GENERAL

1.1 RELATED  
DOCUMENTS

- .1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SHOP DRAWINGS  
AND PRODUCT DATA

- .1 Submit shop drawings and product data for cabinets in accordance with Division 01 - Submittal Procedures.

PART 2 - PRODUCTS

2.1 JUNCTION AND  
PULL BOXES

- .1 Weatherproof junction and pull boxes as indicated and sized on drawings. To be used for exterior electrical connections on poles and jib cranes for lighting circuits and wharf receptacles.
- .2 Enclosures rating EEMAC 4X and threaded hubs. Corrosion resistant to salt environment.

PART 3 - EXECUTION

3.1 JUNCTION & PULL  
BOX INSTALLATIONS

- .1 Install junction and pull boxes in locations as indicated on drawings.
- .2 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

3.2 IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name, voltage and phase.