

PART 1 - GENERAL

1.1 SECTION INCLUDES .1 Materials and installation for Wire and Box Connectors 0-1000 V.

1.2 RELATED SECTIONS .1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

PART 2 - PRODUCTS

- 2.1 MATERIALS
- .1 Pressure type wire connectors: with current carrying parts of copper sized to fit copper conductors as required.
 - .2 Fixture type splicing connectors: with current carrying parts of copper sized to fit copper conductors 10 AWG or less.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Remove insulation carefully from ends of conductors and:
- 1. Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 C22.2 no 65.