



**RETURN BIDS TO:**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services

**Bid Fax:** 1-855-983-1808

**Bid Email:** [soumissionsami-bidsrpc@pc.gc.ca](mailto:soumissionsami-bidsrpc@pc.gc.ca)

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A  
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

**Issuing Office:**

Parks Canada Agency  
National Contracting Services  
Calgary, AB

<b>Title:</b> Mt. Norquay Road Phase 2 Repairs, Banff National Park	
<b>Solicitation No.:</b> 5P468-22-0007/A	<b>Date:</b> April 20, 2022
<b>Amendment No.:</b> 001	
<b>Client Reference No.:</b> N/A	
<b>GETS Reference No.:</b> PW-22-00992446	

<b>Solicitation Closes:</b> <b>At:</b> 2:00 PM <b>On:</b> <b>May 05, 2022</b>	<b>Time Zone:</b> MDT
---	--------------------------

<b>F.O.B.:</b> Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
<b>Address Enquiries to:</b> Ken Lacanilao	
<b>Telephone No.:</b> 587-832-1894	<b>Fax No.:</b> 1-855-983-1808
<b>Email Address:</b> <a href="mailto:Kenneth.lacanilao@pc.gc.ca">Kenneth.lacanilao@pc.gc.ca</a>	
<b>Destination of Goods, Services, and Construction:</b> See Herein	

**TO BE COMPLETED BY THE BIDDER**

<b>Vendor/ Firm Name:</b>	
<b>Address:</b>	
<b>Telephone No.:</b>	<b>Fax No.:</b>
<b>Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):</b>	
<b>Signature:</b>	<b>Date:</b>

**Solicitation No.:**  
5PXXX-XX-XXXX/X

**Amendment No.:**  
00

**Contracting Authority:**  
Insert name

Ver.02.08.21

**Client Reference No.:**  
Insert reference no.

**Title:**  
Insert solicitation title

---

## **Amendment 001**

This amendment is raised to extend the solicitation closing date and answer questions from bidders.

### **A. Solicitation Closing Date**

The closing date for solicitation 5P468-22-0007/A, titled Mt. Norquay Road Phase 2 Repairs, Banff National Park, is extended from April 28, 2022, 2:00 PM until May 05, 2022, 2:00 PM (MDT)

If you have already submitted your bid, you are invited to send us your revisions, where necessary, by fax / email to 1-855-983-1808 or [soumissionsami-bidsrpc@pc.gc.ca](mailto:soumissionsami-bidsrpc@pc.gc.ca). Please indicate the solicitation number on all correspondence.

### **B. Questions and Answers**

**Q1.** Where salvaged lock blocks be stockpiled?

**A1.** To be stockpiled at Cascade Pit, which is roughly within 10 Km of the worksite.

**Q2.** If there is tree cutting involved, how is it paid?

**A2.** No tree cutting or tree removals are intended as part of the project.

**Q3.** Please provide details to show how the 300mm PVC pipe through the gabion wall.

**A3.** The intent is for the PVC pipe to sit at the top 300mm of the gabion basket, minor repairs to the basket wire, additional galvanized tie wire around the pipe and grouting may be required to close any gaps at the outlet. The outlet end of the pipe is intended to be open for future maintenance purposes.

An HDPE or metal storm grate will be required to be installed on the inlet of the pipe at the road surface and removable for future maintenance purposes.

To reiterate what is shown in the contact documents, this is the responsibility of the contractor.

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.**