

Fisheries and Oceans Canada / Pêches et Océans Canada
ADDENDUM TWO / ADDENDUM DEUX
May 2, 2022 / 2 mai 2022
30002557

New Floating Wharves Installation, Chance Harbour, New Brunswick / Installation de nouveau quais flottants,
Chance Harbour, Nouveau-Brunswick

ENGLISH

In the general requirements says supply and install new timber sheathing/ wales/ fender piles/ reinstall existing timber ladders as indicated on our drawings. Regarding Plans p. M4 of M7 detail D2 & D3. Plans indicate NEW treated fenders & new treated wales & sheathing.

Question #1

Is there any particulars on the treatment and or materials ?

Response

Please refer to section 06 30 00 from the specification.

Question #2

Is there a section in 01 22 06, Measurement for payment ?

Response

Concerning the general requirements where it says supply and install new timber sheathing/ wales/ fender piles/ reinstall existing timber ladders, see Section 06 08 99 under 1.03.2.

Question #3

I do see removal & disposal of these items mentioned above on page 2, of this section, but are the new materials to put back to be included here ?

Response

Additional information required

FRANÇAIS

Dans les exigence général il dit faut qu'on fournit et installe de nouveau revêtement/ transversal/ pieu de défense tourne/ réinstaller des échelle existant comme indiquer sur les dessins. Concernant les détails D2 et D3 du dessin p. M4 de M7, les dessins indique la demande de nouveau pieu de défense et nouveau transversal traiter ainsi que du revêtement.

Question #1

Est-ce qu'on a des exigences particulières concernant le traitement et ou le matériel?

Réponse

Veuillez-vous référer à la section 06 30 00 du devis.

Question #2

Est-ce qu'il a une section 01 22 06, mesure pour paiement?

Réponse

Concernant les exigences générales ou il dit faut qu'on fournit et installe de nouveau revêtement/ transversal/ pieu de défense tourne/ réinstaller des échelles existant, voir section 06 08 99 sous 1.03.2.

Question #3

Je vois l'enlèvement et élimination de ces items mentionner sur page 2 de cette section mais est-ce que le nouveau matériel qui soit remis est incluse ici?

Réponse

Informations supplémentaires requises