

Neddy Harbour Development – Norris Point, NL

F6140-220702/A

AMENDMENT # 1

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

ADDENDUM NO. 1

QUESTIONS AND ANSWERS:

Question # 1: I would like to request clarification on the geotextile specified in Section 31 32 19.01. As shown below there are physical properties contained under section 2.1 for two different thicknesses for the geotextile. Which thickness is required?

- 1.1 shows a thickness of 4.7mm
- 2.1 shows a thickness of 2.5mm

Answer # 1: The thickness required is the material specified in 2.1.1 (4.7 mm thick). 2.1.2 of the specification section shall be omitted.

BY SUBMISSION OF ITS TENDER, THE TENDERER CONFIRMS THAT IS HAS READ AND UNDERSTANDS THE REQUIREMENTS EXPRESSED IN ALL ADDENDA AND HAS INCLUDED ALL COSTS OF THESE REQUIREMENTS IN THE TOTAL TENDER AMOUNT.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
