



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works & Government Services  
Canada/Réception des soumissions Travaux publics et  
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

<b>Title - Sujet</b> Centreville Wharf Reconstruction	
<b>Solicitation No. - N° de l'invitation</b> EB144-230034/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> EB144-23-0034	<b>Date</b> 2022-06-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-SPWA-502-6250	
<b>File No. - N° de dossier</b> PWA-2-88004 (502)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Atlantic Daylight Saving Time ADT <b>on - le 2022-06-14</b> Heure Avancée de l'Atlantique HAA	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Parsons (PWA), Richard	<b>Buyer Id - Id de l'acheteur</b> pwa502
<b>Telephone No. - N° de téléphone</b> (902) 399-8427 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Amendment 006 is raised for the following:**

Refer to Specification Section 26 05 00:

Delete Section 26 05 00, 3.7 and replace with:

**3.7 CO-ORDINATION OF PROTECTIVE DEVICES**

- .1 Provide a Short-Circuit and Protective Device Coordination study from the utility connection to the 120/208V distribution level at the new service entrance backboard.
- .2 Coordination of Protective Device: Provide a report to Departmental Representative showing all values and settings, stamped and signed by a professional Engineer. **The contractor shall engage the successful manufacturer of the electrical distribution equipment to prepare the complete short-circuit and protective device coordination study. Arrange and pay for associated fees.** The report shall include time-current curves on a logarithmic scale. Submit a copy of the study stamped and signed by professional engineer registered and licensed in Provinces of Nova Scotia, Canada during shop drawing review phase.
- .3 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.
- .4 Provide an Arc-Flash Analysis in conjunction with the protective device coordination study to determine the arc-flash boundary and personnel protective requirement in accordance with the latest adopted CSA Z-462. Provide warning labels to suit. Install warning label on their respective equipment.
- .5 Mark the distribution equipment with lamicoid nameplates identifying the level of PPE to be worn when performing maintenance on the electrical equipment.

***ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED***