



- | | | | |
|---|--|----|---|
| 1 | 65ø HWS FROM BELOW AND UP. | 10 | RESERVED |
| 2 | 65ø HWR FROM ABOVE AND DOWN. | 11 | 15ø HWS/HWR FROM BELOW TO SERVE RAD-2. |
| 3 | 65ø CHWS FROM BELOW AND UP. | 12 | 20ø HWS/HWR UP THROUGH FLOOR TO SERVE RADIATOR AT LEVEL ABOVE. PROVIDE NEW FLOOR OPENING, SCAN FLOOR PRIOR TO CORING AND COORDINATE OPENING WITH RADIATOR LOCATION. |
| 4 | 65ø CHWR FROM ABOVE AND DOWN. | 13 | PIPING PENETRATES THROUGH FLOOR INTO THE RADIATOR TROUGH. |
| 5 | PROVIDE NEW FLOOR OPENINGS. SCAN FLOOR PRIOR TO CORING AND COORDINATE WITH STRUCTURAL. | 14 | 65ø CHWS/CHWR FROM BELOW. 25ø CHWS TO LEVEL ABOVE. |
| 6 | 20ø HWS UP THROUGH FLOOR TO SERVICE RADIATORS AT LEVEL ABOVE. RE-USE EXISTING FLOOR OPENINGS. | 15 | FOR HVAC PIPING, PLUMBING PIPING AND HVAC DUCTING WITHIN RISER SHAFT, REFERT TO PART PLAN 3 ON DRAWINGS M60-01. |
| 7 | 20ø HWR DOWN THROUGH FLOOR FROM RADIATORS AT LEVEL ABOVE. RE-USE EXISTING FLOOR OPENINGS. | 16 | 32ø CHWS/CHWR FROM BELOW. |
| 8 | 20ø HWS/HWR DOWN TO SERVE RAD-3. | 17 | RUN PIPE THROUGH INSIDE OF THE WALL TO RADIATORS SECTION BEYOND THE COLUMN |
| 9 | 15ø HWS/HWR FROM PARKING GARAGE. PROVIDE NEW FLOOR OPENING, SCAN FLOOR PRIOR TO CORING AND COORDINATE WITH STRUCTURAL. | | |

1. PROVIDE RADIATORS TO MEET THE CAPACITY REQUIREMENTS NOTED ON THE DRAWING AND TO COMPLY WITH DIMENSIONS AND TYPE ACCORDING TO THE SCHEDULE.
2. RADIATORS TO BE C/W ALL ACCESSORIES AND TRIMS NECESSARY TO MAINTAIN CONTINUOUS APPEARANCE ALONG EXTERIOR WALLS.
3. INSTALL HSW/HWR PIPING THROUGH EXISTING FLOOR OPENINGS TO SERVICE RADIATORS ON LEVEL ABOVE AS NOTED. PROVIDE SAME AND MAKE ALL NECESSARY CONNECTIONS AS NECESSARY TO SUIT INSTALLATION AS SHOWN ON THE DRAWING.
4. PROVIDE CONTROL VALVES FOR RADIATORS IN EACH ZONE. REFER TO RADIATOR PIPING DETAILS FOR CONTROL VALVES LOCATION AND PIPING ARRANGEMENTS.
5. SUPPLY AND INSTALL ALL NECESSARY EXPANSION COMPENSATORS, ANCHORS AND ALIGN GUIDES ON ALL HYDRONIC PIPING TO SUIT ALL ALTERNATIVE EXPANSION COMPASSION SHOWN ON THE DRAWING ONLY SUGGESTS THE DESIGN INTENT.

1. DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL FLOOR PLANS AND SPECIFICATIONS.
2. ALL EXISTING STRUCTURES SHOWN ARE APPROXIMATE AND BASED ON EXISTING DRAWINGS.
3. CONTRACTOR SHALL VERIFY ALL LOCATIONS ON SITE.
4. CONTRACTOR SHALL COORDINATE WITH ALL OTHER TRADES INVOLVED ON SITE.
5. ENSURE NOT TO DISTURB STRUCTURES COVERING AREAS NOT INCLUDED IN THE SCOPE. ALL WORK MUST BE COORDINATED WITH DEPARTMENTAL REPRESENTATIVE.
6. CONTRACTOR SHALL VISIT SITE TO VERIFY ALL CONDITIONS.
7. CONTRACTOR TO PROPOSE SOLUTIONS FOR REVIEW TO THE CONSULTANT IF ANY INTERFERENCES OCCUR.
8. ALL MATERIAL USED IN THE CEILING SPACE (RETURN AIR PLENUM) SHALL MEET AND EXCEED THE N.B.C. REQUIREMENTS FLAME AND SMOKE SPREAD/DEVELOPMENT RATINGS.
9. CONTRACTOR TO PROVIDE CONDUIT FOR ALL NEW ELECTRICAL WIRING EQUIPMENT AND UPDATE EQUIPMENT DIRECTLY TO BUILDING HVAC SYSTEM AND UPDATE THE BMS ARCHITECTURE AS REQUIRED.
10. CONTRACTOR TO REMOVE ALL MECHANICAL EQUIPMENT AND INSTALL NEW INS. SENSORS, VALVE AND PIPING TO BE INSTALLED AS SHOWN ON DRAWINGS.
11. MECHANICAL CONTRACTOR TO X-RAY SCAN SLAB PLENUM TO CORING.
12. ALL THE SENSITIVITY IN PUBLIC AREAS TO BE EITHER BLANK PLATE TYPE SENSORS OR PROVIDED WITH PROTECTIVE GUARDS.