



GENERAL NOTES:

1. DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL FLOOR PLANS AND SPECIFICATIONS.
2. ALL EXISTING SERVICES SHOWN ARE APPROXIMATE AND BASED ON EXISTING DRAWINGS.
3. CONTRACTOR SHALL VERIFY ALL LOCATIONS ON SITE.
4. CONTRACTOR SHALL COORDINATE WITH ALL OTHER TRADES INVOLVED ON SITE.
5. ENSURE NOT TO DISTURB SERVICES COVERING AREAS NOT INCLUDED IN THE SCOPE. ALL WORK MUST BE COORDINATED WITH DEPARTMENT OF PUBLIC WORKS.
6. CONTRACTOR SHALL VISIT SITE TO EXAMINE EXISTING CONDITIONS.
7. CONTRACTOR TO PROPOSE SOLUTIONS FOR REVIEW TO THE CONSULTANT IF ANY INTERFERENCES OR DISCREPANCIES TO SITE CONDITIONS.
8. ALL MATERIAL USED IN THE CEILING SPACE (RETURN AIR PLENUM) SHALL MEET AND EXCEED THE N.E.C. REQUIREMENTS FLAME AND SMOKE SPREAD/DEVELOPMENT RATINGS.
9. CONTRACTOR SHALL BE RESPONSIBLE TO RELOCATE EXISTING EQUIPMENT AND ADDED EQUIPMENT DIRECTLY TO BUILDING HVAC SYSTEM AND UPDATE THE BMS ARCHITECTURE AS REQUIRED.
10. CONTRACTOR SHALL BE RESPONSIBLE TO REMOVE EXISTING EQUIPMENT AND INSTALL NEW ONES: SALVAGE AND REINSTALL ONLY WHEN SPECIFICALLY INDICATED.
11. PROVIDE BALANCING DAMPERS AS REQUIRED FOR COMPLETE BALANCING OF THE SYSTEM. REFER TO THE BMS ARCHITECTURE FOR DAMPER SIZES.