

GENERAL NOTES - POWER

- A THESE DRAWINGS AND SPECIFICATIONS TO BE READ IN CONJUNCTION WITH ARCHITECTURAL, STRUCTURAL, INTERIOR DESIGNER'S, MECHANICAL, AND OTHER DIVISIONS DRAWINGS. ALL ELECTRICAL WORK SHALL COMPLY WITH OWNERS REQUIREMENTS AND BASE BUILDING STANDARDS.
- B "AS REQUIRED, MAKE OPERATIONAL" - DENOTES ELECTRICAL INSTALLATION TO SUIT SITE CONDITIONS, TO CONFORM WITH THE REQUIREMENTS OF ALL APPLICABLE CODES AND STANDARDS AND INSTALLATION TO INCLUDE ALL NECESSARY MATERIAL, EQUIPMENT AND LABOUR (ALTHOUGH NOT SHOWN ON THE DRAWINGS) TO MAKE IT OPERATIONAL. NO ALLOWANCES WILL BE MADE SUBSEQUENTLY FOR ANY CONSIDERATIONS OVERLOOKED.
- C UNLESS NOTED OTHERWISE ALL WIRING AND CONDUITS TO BE CONCEALED.
- D ALL ELECTRICAL EQUIPMENT (LIGHTING FIXTURES, POWER EQUIPMENT AND CABLES) OR ANY OTHER CONTRIVANCE THAT GENERATES EITHER ELECTROMAGNETIC FIELD OR ELECTROMAGNETIC INTERFERENCE ARE TO BE KEPT AT LEAST 12" AWAY FROM THE COMMUNICATION CABLE TRAYS. INSTALL ELECTRICAL EQUIPMENT AND CABLES TO CONFORM TO THE ABOVE EQUIREMENTS.
- E UNLESS NOTED OTHERWISE ALL CIRCUIT NUMBERS SHOWN ARE FOR GROUPING PURPOSES ONLY. SHOW ACTUAL CIRCUIT NUMBERS ON AS-BUILT DRAWINGS.

DRAWING KEYNOTES


- P11 PROVIDE NEW POWER FROM CIRCUIT INDICATED FOR RE-CONNECTION OF EXISTING ELEVATOR DISCONNECT SWITCH.
- P12 TERMINATE (X1) 15A-1P CIRCUIT IN JUNCTION BOX TO BE LOCATED IN CLOSE PROXIMITY TO MECHANICAL UNIT FOR USE WITH 120V EQUIPMENT (LIGHTING RECEPTACLE/CONTROL CIRCUITRY) WITHIN UNIT. COORDINATE EXACT JUNCTION BOX LOCATION ON-SITE WITH MECHANICAL TRADES.
- P13 PROVIDE WEATHERPROOF 20A (5-20R) GFCI RECEPTACLE FOR MAINTENANCE OF MECHANICAL EQUIPMENT ON ROOF. COORDINATE EXACT LOCATION ON SITE WITH MECHANICAL EQUIPMENT INSTALLATION.

NORR


NORR Architects & Engineers Limited
An Ingenium Group Company

175 Bloor St. East
North Tower, 15th Floor
Toronto, ON Canada M4W 3R8
norr.com


key plan



project and true North



project legend



ISSUED FOR TENDER 2022-05-27

revisions date

project

**DANIEL J MACDONALD
MODERNIZATION**

161 GRAFTON STREET
CHARLOTTETOWN, PEI, C1A 1L1

drawing dessin

**POWER PLAN -
PENTHOUSE FLOOR**

designed NORR compu

date 12/21/18

drawn NORR dessiné

date 12/21/18

approved SR approuvé

date 2022-05-27

Tender Soumission

PWGSC Project Manager Administrateur de projets TPSCG

project number no. du projet

R.056687.005

drawing no. no. du dessin

E10-06