

Branch Panel: RP-3AN1															
Location: ELECTRICAL ROOM 3-06						Volts: 120/208 Wye				A.I.C. Rating: 10kA					
Supply From: TX-R3AN						Phases: 3				Mains Rating: 400 A					
Mounting: SURFACE						Wires: 4				MCB Rating:					
Enclosure: Type 2															
CCT	Circuit Description	Trip	Poles	A	B	C	A	B	C	Poles	Trip	Circuit Description	CCT		
RP-3AN1-1	RP-3AN3	70 A	3	1600			700	1200		1	20 A	FRIDGE	RP-3AN1-12		
RP-3AN1-3					2092					1	20 A		RP-3AN1-14		
RP-3AN1-5						1172		1000	1000	1	20 A	GFCCI O/C RECEPT	RP-3AN1-16		
RP-3AN1-7	APR Room 3-23, 3-25	15 A	1	400						1	20 A	MICROWAVE	RP-3AN1-18		
RP-3AN1-8	Room 3-25, 3-27	20 A	1		800			1000			20 A	MICROWAVE	RP-3AN1-19		
RP-3AN1-11	HK RECEPT Room 3-35, 3-06, 3-26	20 A	1			500			1400	1	15 A	LARGE MEETING ROOM 3-44	RP-3AN1-20		
RP-3AN1-13	D/O GENDER NEUTRAL BARRIER FRREE WR...	20 A	1	400			250			1	15 A	FLOOR BOX LARGE MEETING ROOM 3-44	RP-3AN1-21		
RP-3AN1-15	Room 3-34, 3-32, 3-33	15 A	1				400	900		1	15 A	GNRL RECEPT CORRIDOR 3-43	RP-3AN1-22		
RP-3AN1-17	PROJECT ROOM 3-31	15 A	1			1000			600	1	15 A	GNRL RECEPT ITM & ADMIN APPLICATION...	RP-3AN1-23		
RP-3AN1-19	PROJECT ROOM 3-30	15 A	1	1000				250		1	15 A	FLOOR BOX ITM & ADMIN APPLICATION...	RP-3AN1-24		
RP-3AN1-21	RECEPTACLE FOCUS ROOM 3-02	15 A	1		600					1	15 A	FLOOR BOX ITM & ADMIN APPLICATION...	RP-3AN1-25		
RP-3AN1-23	FLOOR BOX OPEN WORKSPACE 3-34	15 A	1						250	400	1	15 A	WORKSTATION ITM & ADMIN APPLICATION...	RP-3AN1-26	
RP-3AN1-25	GNRL RECEPT OPEN WORKSPACE 3-34	15 A	1	400			300	1200		1	15 A	RECEPTACLE Room 3-48, 3-49	RP-3AN1-27		
RP-3AN1-27	HK RECEPT OPEN WORKSPACE 3-34	20 A	1				500			1	15 A	O/C RECEPT BUSINESS CENTRE 3-01	RP-3AN1-28		
RP-3AN1-29	WORKSTATION OPEN WORKSPACE 3-34	15 A	1				300	800		200	400	1	15 A	RECEPTACLE BUSINESS CENTRE 3-01	RP-3AN1-29
RP-3AN1-31	WORKSTATION OPEN WORKSPACE 3-34	15 A	1		800			700				1	20 A	PRINTER BUSINESS CENTRE 3-01	RP-3AN1-30
RP-3AN1-33	WORKSTATION OPEN WORKSPACE 3-34	15 A	1				800		1000			1	15 A	MEDIUM MEETING ROOM 3-08	RP-3AN1-31
RP-3AN1-35	WORKSTATION	15 A	1				800		250	1	15 A	FLOOR BOX MEDIUM MEETING ROOM 3-08	RP-3AN1-32		
RP-3AN1-37	WORKSTATION OPEN WORKSPACE 3-34	15 A	1	800									RP-3AN1-33		
RP-3AN1-39	WORKSTATION OPEN WORKSPACE 2-49	15 A	1										RP-3AN1-34		
RP-3AN1-41	WORKSTATION OPEN WORKSPACE 2-49	15 A	1				800			750	1	15 A	FLOOR BOX OPEN WORKSPACE 3-34	RP-3AN1-35	
RP-3AN1-43	WORKSTATION OPEN WORKSPACE 2-49	15 A	1	800				0			1	15 A	SPARE	RP-3AN1-36	
RP-3AN1-45	WORKSTATION OPEN WORKSPACE 3-34	15 A	1					0	0		1	15 A	SPARE	RP-3AN1-37	
RP-3AN1-47	WORKSTATION OPEN WORKSPACE 3-34	15 A	1						0	0	1	15 A	SPARE	RP-3AN1-38	
RP-3AN1-49	WORKSTATION OPEN WORKSPACE 3-34	15 A	1	800					0	0	1	15 A	SPARE	RP-3AN1-39	
RP-3AN1-51	WORKSTATION	15 A	1				800				1	15 A	SPARE	RP-3AN1-40	
RP-3AN1-53	WORKSTATION OPEN WORKSPACE 3-34	15 A	1				800			0	1	15 A	SPARE	RP-3AN1-41	
RP-3AN1-55	WORKSTATION OPEN WORKSPACE 2-49	15 A	1	800						0	1	15 A	SPARE	RP-3AN1-42	
RP-3AN1-57	WORKSTATION OPEN WORKSPACE 2-49	15 A	1				800			0	1	15 A	SPARE	RP-3AN1-43	
RP-3AN1-59	WORKSTATION OPEN WORKSPACE 2-49	15 A	1				800		0	1	15 A	SPARE	RP-3AN1-44		
RP-3AN1-61	FLOOR BOX OPEN WORKSPACE 3-34	15 A	1	750						0	1	15 A	SPARE	RP-3AN1-45	
RP-3AN1-63	HK RECEPT OPEN WORKSPACE 3-34	20 A	1		300						1	15 A	SPARE	RP-3AN1-46	
RP-3AN1-65	WORKSTATION OPEN WORKSPACE 3-34	15 A	1				1200		0	1	20 A	SPARE	RP-3AN1-47		
RP-3AN1-67	WORKSTATION OPEN WORKSPACE 2-49	15 A	1	1200						0	1	20 A	SPARE	RP-3AN1-48	
RP-3AN1-69	WORKSTATION OPEN WORKSPACE 2-49	15 A	1		1200				0	1	20 A	SPARE	RP-3AN1-49		
RP-3AN1-71	WORKSTATION OPEN WORKSPACE 2-49	15 A	1			1200		0	0	1	20 A	SPARE	RP-3AN1-50		
RP-3AN1-73	Room 3-38, 3-42, 3-41	15 A	1	1400						0	1	20 A	SPARE	RP-3AN1-51	
RP-3AN1-75	HK RECEPT CORRIDOR 3-43	20 A	1			200		0	1	1	20 A	SPARE	RP-3AN1-52		
RP-3AN1-77	GFCCI RECEPT CORRIDOR 3-43	20 A	1			200		200	0	1	1	20 A	SPARE	RP-3AN1-53	
RP-3AN1-79	GNRL RECEPT KITCHENETTE/ LOUNGE 3-07	15 A	1							0	1	20 A	SPARE	RP-3AN1-54	
RP-3AN1-81	GNRL RECEPT KITCHENETTE/ LOUNGE 3-07	15 A	1							0	1	20 A	SPARE	RP-3AN1-55	
RP-3AN1-83	FRIDGE	20 A	1			700			0	1	1	20 A	SPARE	RP-3AN1-56	
				Total Load:	16000 VA		15042 VA	16072 VA							
				Total Amps:	135 A		125 A	135 A							
<b>Legend:</b> * DENOTES GFCCI BREAKER ! DENOTES BREAKER LOCK ON CIRCUIT															
<b>Notes:</b> PANEL TO HAVE 200% RATED NEUTRAL													<b>Panel Totals</b> Total Conn. Load: 47164 VA Total Conn. Current: 131 A		