


**NORR**


NORR Architects & Engineers Limited  
An Ingenium Group Company

175 Bloor St. East  
North Tower, 15th Floor  
Toronto, ON Canada M4W 3R8  
norri.com


Key plan



Project and True North



Project legend



0 ISSUED FOR TENDER 2022-05-27

revisions date

project project

**DANIEL J MACDONALD  
MODERNIZATION**

161 GRAFTON STREET  
CHARLOTTETOWN, PEI, C1A 1L1

drawing dessin

**SECURITY PLAN -  
SECOND FLOOR**

designed NORR compu  
date 01/02/19

drawn NORR dessin  
date 01/02/19

approved SR approuvé  
date 2022-05-27


Tender Soumission  
PWGSC Project Manager Administrateur de projets TPSC

project number no. du projet  
**R.056687.005**

drawing no. no. du dessin

**E50-02**

E-OPM000-E: 553185 v1



#### GENERAL NOTES - SECURITY

- A THESE DRAWINGS AND SPECIFICATIONS TO BE READ IN CONJUNCTION WITH ARCHITECTURAL, STRUCTURAL, INTERIOR DESIGNER'S, MECHANICAL, AND OTHER DIVISIONS DRAWINGS. ALL ELECTRICAL WORK SHALL COMPLY WITH OWNERS REQUIREMENTS AND BASE BUILDING STANDARDS.
- B \*AS REQUIRED, MAKE OPERATIONAL\* - DENOTES ELECTRICAL INSTALLATION TO SUIT SITE CONDITIONS, TO CONFORM WITH THE REQUIREMENTS OF ALL APPLICABLE CODES AND STANDARDS AND INSTALLATION TO INCLUDE ALL NECESSARY MATERIAL, EQUIPMENT AND LABOUR (ALTHOUGH NOT SHOWN ON THE DRAWINGS) TO MAKE IT OPERATIONAL. NO ALLOWANCES WILL BE MADE SUBSEQUENTLY FOR ANY CONSIDERATIONS OVERLOOKED.
- C UNLESS NOTED OTHERWISE ALL WIRING AND CONDUITS TO BE CONCEALED.
- D ALL ELECTRICAL EQUIPMENT (LIGHTING FIXTURES, POWER EQUIPMENT AND CABLES) OR ANY OTHER CONTRIVANCE THAT GENERATES EITHER ELECTROMAGNETIC FIELD OR ELECTROMAGNETIC INTERFERENCE ARE TO BE KEPT AT LEAST 12" AWAY FROM THE COMMUNICATION CABLE TRAYS. INSTALL ELECTRICAL EQUIPMENT AND CABLES TO CONFORM TO THE ABOVE EQUIREMENTS.

#### GENERAL NOTES - SECURITY

- E PROVIDE SYSTEM OF CONDUITS AND JUNCTION BOXES FOR SECURITY SYSTEM INCLUDING SUPPLY, INSTALLATION, WIRING AND FINAL TERMINATION OF SECURITY SYSTEM DEVICES. EXACT LOCATION OF ALL DEVICES TO BE DETERMINED ON SITE, IN COORDINATION WITH ARCHITECT / INTERIOR DESIGNER AND SECURITY SYSTEM CONTRACTOR. NOT ALL DEVICES ARE SHOWN ON THIS DRAWING (REX, DOOR CONTACTS ETC), REFER TO DOOR DETAILS FOR LOCATION AND ELEVATION OF DEVICES AND CONDUITS AT THE DOORS.
- F ALL DOORS WITH DOOR IDENTIFICATION TAG ON THIS DRAWING ARE TO BE PROVIDED WITH CONDUIT AND ROUGHINS FOR SECURITY AND DOOR HARDWARE DEVICES. REFER TO DRAWING E03-02 FOR DOOR HARDWARE SET AND DETAIL THAT CORRESPONDS WITH DOOR NUMBER. NOT ALL DEVICES ARE SHOWN ON DRAWING LAYOUT, REFER TO DETAIL FOR EXACT REQUIREMENTS AND REFER TO ARCHITECTURAL DOOR HARDWARE SCHEDULE AND SPECIFICATIONS TO PROVIDE ALL REQUIRED CONDUIT AND ROUGHINS.

#### DRAWING KEYNOTES

○