



**REQUEST FOR PROPOSAL (RFP)**  
**AMENDMENT 002**

VENTILATION DUCT CLEANING SERVICE

**Bid Submission Deadline:**  
**June 17, 2022 at 2:00 PM (EDT)**

**Submit bids to the Canadian Space Agency  
By E-Post Connect**

Or by Fax : 819-997-9776

**Reference:** CSA File No. **9F030-21-0453**

*Note:* Please read this Request for Proposal carefully for further details on the requirements and bid submission instructions.



June 13, 2022



## **AMENDMENT 002**

The purpose of this amendment is to modify **Bid Submission Deadline and to publish the answers of the questions received :**

**1. Delete: June 15, 2022 at 2:00 PM (EDT)**

**Insert: June 17, 2022 at 2:00 PM (EDT)**

**Question 1 : Do you have an estimate of the sections to be repaired or replaced? If not, how do you plan to pay for this item?**

**Answer** : *Sections of insulation to be repaired/replaced is related to addition of access door for cleaning operations. The quantity of access door installed will be evaluated by the Contractor as needed considering the existing access doors show on the plans. Contractor must provide a unit cost for each type of access doors according to TABLE 4 of ANNEX B of the REQUEST FOR PROPOSAL (RFP).*

**Question 2 : Will there be sections of ductwork that require sealing? Or parts of the units that require anti-corrosion treatment?**

**Answer** : *Apart from firestop sealing of ventilation duct passing through firestop partition installed by the Contractor, sealing between ventilation ducts and sealing of access doors, the application of additional sealant is not required. Anti-corrosion treatment is not par of the project's scope of work.*

**ALL OTHER CLAUSES, CONDITIONS REMAIN THE SAME**