

PWGSC PROJECT NO. R114387

ADDENDUM NO. 004

June 28, 2022

Tender Closing Date: June 30, 2022

This Addendum forms part of the Contract Documents and amends the original drawings and specifications. Tenderers are reminded to acknowledge on the Form of Tender that this Addendum has been received.

DRAWINGS**Civil****Item No. 1 Drawing C-2**

- 1.1 The estimated weight for each fuel tank is 18,000lbs empty. This estimate assumes:
- Single wall tank, 1/4" thick carbon steel.
 - No allowance for piping, manholes, structural support members, etc.
- 1.2 Contractor is responsible to confirm actual weight of fuel tanks prior to removal.

END OF ADDENDUM NO. 004