



SHARED SERVICES CANADA REQUEST FOR QUOTATION

APC uninterruptible power supplies (UPS) Batteries or equivalent

Solicitation No.	BPM016438	Date	July 6, 2022
Amdt No.	001	Amdt Date	
GCDocs File No.		GETS Reference No.	

Issuing Office	Shared Services Canada 180 Kent Street, 13 th Floor Ottawa, Ontario K1P 0B5		
Contracting Authority (The Contracting Authority is the contact for all questions and comments about this document)	Name	Oliver Librada	
	Telephone No.	(343) 542-8460	
	Email Address	oliver.librada@ssc-spc.gc.ca	
	Postal Address	180 Kent St, 13-K131 P.O. Box 9808, STN T CSC Ottawa, ON K1G 4A8	
Closing Date and Time	Date at Time July 15, 2022 (3:00 PM / 15h00) (referred to in this solicitation as " Solicitation Closing ")		
Time Zone	Eastern Daylight Time (EDT)		
Destination of Goods/Services	Canada		
Email Address for Submitting your Bid by the Closing Date	Oliver.Librada@ssc-spc.gc.ca		

**REQUEST FOR QUOTATION AMENDMENT 001**

This amendment has been raised to:

- Answer questions posed by potential respondents
-

QUESTION 1:

Item# 1 and Item#4 on Annex A are discontinued – this is a detailed explanation below.

- **Item# 1**
 - Part#RBC132 Replacement battery cartridge for SMT1000RM2U or equivalent X 4 = this is a discontinued product.
 - Part#RBC132 is a battery that goes into SMT1000RM2U, and since we discontinued SMT1000RM2U than Part#RBC132 is also discontinued.
- **Solution**
 - SMT1000RM2UC replaced SMT1000RM2U and in this case we also replaced Part# RBC132 by Part#RBC157 which is compatible with SMT1000RM2UC. The client should replace SMT1000RM2U by newer solution SMT1000RM2UC

SMT1000RM2UC description is (<https://www.apc.com/ca/en/product/SMT1000RM2UC/apc-smartups-line-interactive-1000va-rackmount-2u-120v-6x-nema-515r-outlets-smartconnect-port+smartslot-avr-lcd/>)

Part#RBC157 description is (<https://www.apc.com/ca/en/product/APCRBC157/apc-replacement-battery-cartridge-157-with-2-year-warranty/>)

- **Item # 4**
 - Part# RBC123 Replacement battery cartridge for APC BR1000G or equivalent X 4 = this is a discontinued product.
 - Part# RBC123 is a battery that goes into APC BR1000G , and since we discontinued APC BR1000G than Part# RBC123 is also discontinued.
- **Solution**
 - APC BRM1000MS replaced APC BR1000G and in this case we also replaced Part# RBC123 by Part#RBC160 which is compatible with BRM1000MS. The client should replace BR1000G by newer solution BRM1000MS

BRM1000MS description is (<https://www.se.com/ca/en/product/BR1000MS/apc-backups-pro-1000s-1000va-120v-sinewave-avr-lcd-2-usb-charging-ports-10-nema-outlets-4-surge/>)

RBC160 description is (<https://www.se.com/ca/en/product/APCRBC160/apc-replacement-battery-cartridge-160-with-2-year-warranty/>)

ANSWER 1:

SSC doesn't want to replace the existing UPS's at this time. We want to procure batteries that will be compatible with our existing UPS's. We understand the mentioned APC UPS models are discontinued but we are looking for compatible batteries (either APC branded or equivalent) that are still available in the supply chain.



QUESTION 2:

Can you please provide delivery address, these batteries are heavy and require special shipping carrier.

ANSWER 2:

Delivery address are available in Annex A – List of Deliverables

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME