



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
PWGSC/TPSGC Acquisitions
Sherwood Business Centre
161 St. Peters Road/
161, rue St. Peters
2nd Floor, Suite 204/
2ième étage, pièce 204
Charlottetown
Prince Edward Island
C1A 5P7
Bid Fax: (902) 566-7514

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Sherwood Business Centre
161 St. Peters Road/
2nd Floor, Suite 204
Charlottetown
Prince Ed
C1A 5P7

Title - Sujet Wharf Reconstruction Wharf Reconstruction- Structure 407 North Rustico, PEI	
Solicitation No. - N° de l'invitation ED001-230164/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client ED001-230164	Date 2022-07-08
GETS Reference No. - N° de référence de SEAG PW-\$PWC-039-4576	
File No. - N° de dossier PWC-2-45004 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Daylight Saving Time ADT on - le 2022-07-14 Heure Avancée de l'Atlantique HAA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucette (PWC), Trisha	Buyer Id - Id de l'acheteur pwc039
Telephone No. - N° de téléphone (506) 343-7645 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
l'acheteur
ED001-230164/A

Amd. No. - N° de la modif.
006

Buyer ID - Id de
PWC039

Client Ref. No. - N° de réf. du client
FMS No./N° VME
R.118987.001

File No. - N° du dossier
PWC-2-45004

CCC No./N° CCC -

Solicitation Amendment No. 006

Title: Wharf Reconstruction - Structure 407 North Rustico, Prince Edward Island

(1) This solicitation is hereby amended to provide the following questions and answers:

- Q13.** Is galvanizing required on all tie rod materialsrods, nuts, plate washers, curved washers , sleeve in anchor blocks?
- R13.** All items listed in the email shall be Hot Dipped galvanized as per Project Specifications.
- Q14.** Drawing M3. Section 1. Shows considerable excavation or dredging required and with an uncertain elevation on existing dredge material. We assume this material is tested or will be during construction. If this material is deemed contaminated , will the department covers costs to haul and pay tippage wherever it needs to be disposed of? How will this be handled for payment ?
- R14.** Testing will be required, Section 01 45 00 - Testing and Inspection.

TESTING REQUIREMENTS SPECIFIED ELSEWHERE

.1 Additional and particular requirements for inspection and testing to be carried out and paid for by the Departmental Representative are specified under various technical Sections of the Specification.

If the material is contaminated, the contractor will be required to dispose of the material at an approved waste management facility.

The estimated volume of material behind the back wall is approximately 775 cubic meters. The estimated volume of material in-front of the wharf back wall is 430 cubic meters.

There is space to stockpile the estimated 430 m3 on-site to dewater. This location will be identified by the Departmental Representative.

- (2)** Reference: **Closing date appearing of page one of the solicitation document**
DELETE the closing date of **2022-07-12**; and
INSERT the revised closing date of **2022-07-14**.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the below noted address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged remain unchanged.

All enquiries concerning this amendment are to be forwarded to:
Name: Trisha Doucette
161 St. Peters Road/

Solicitation No. - N° de l'invitation
l'acheteur
ED001-230164/A

Amd. No. - N° de la modif.
006

Buyer ID - Id de
PWC039

Client Ref. No. - N° de réf. du client
FMS No./N° VME
R.118987.001

File No. - N° du dossier
PWC-2-45004

CCC No./N° CCC -

2nd Floor, Suite 204
Charlottetown, PEI, C1A 5P7
Telephone No: (506) 343-7645
Facsimile No: (506) 851-6759
Email: trisha.doucette@pwgsc-tpsgc.gc.ca