



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Simpson Trailhead & Bow Lake Privies – Kootenay & Banff National Parks	
Solicitation No.: 5P468-22-0056/A	Date: July 8, 2022
Amendment No.: 001	
Client Reference No.:	
GETS Reference No.: PW-22-00999940	

Solicitation Closes: At: 2:00 PM On: July 14, 2022	Time Zone: MDT
---	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Jen Maheu	
Telephone No.: 587-432-8458	Fax No.: 1-855-983-1808
Email Address: jennifer.maheu@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 001

This amendment is raised to distribute the answers to bidder questions.

A. QUESTIONS & ANSWERS

Q1 Are there drawings available for this tender? The documents have only "reference" drawings are we to assume that these will be the same as IFC plans?

A1 As PER SOW 5.2:

The contractor will provide drawings based on the reference document included in the package.

5.2 Submission, for PCA review, all complete shop drawing documentation and product information for all project elements including but not limited to:

5.2.1 Engineer-stamped drawings and specifications of privy design based on reference drawings, PCA input, as well as desired elements and functionality of similar privy designs provided as part of this package.

Q2 The moraine lake privy's shown are both accessible dual stall washrooms are we to assume the same size and type are to be installed in both new locations?

tender docs only note :

5.4 Supply and installation of two new 2-hole vault toilets as per contractor supplied shop drawings and specifications. One at Bow Lake South and one at Simpson River Trailhead.

A2 The same size, style and type of privy are to be installed at each site. One at Bow Lake South and one at Simpson River Trailhead. Each site privy is to be a 2-hole, independently accessed universal accessible toilet as based on the reference drawings provided, noted in the SOW 5.2.1.

Q3 Is the contractor to pay for a QEP to perform the birdsweep or is PCA going to supply an ESO to perform the sweep?

A3 As PER SOW 5.3:

The contractor is responsible for the bird sweep as noted in the SOW.

5.3.3 Perform a bird sweep of the building structure by a Qualified Environmental Professional (QEP) within 14 days prior to the start of exterior surface demolition. Qualifications of the QEP shall be submitted to the DR for approval.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.