



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
PWGSC/TPSGC Acquisitions  
Sherwood Business Centre  
161 St. Peters Road/  
161, rue St. Peters  
2nd Floor, Suite 204/  
2ième étage, pièce 204  
Charlottetown  
Prince Edward Island  
C1A 5P7  
Bid Fax: (902) 566-7514

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
Sherwood Business Centre  
161 St. Peters Road/  
2nd Floor, Suite 204  
Charlottetown  
Prince Ed  
C1A 5P7

<b>Title - Sujet</b> Daniel J. MacDonald (DJM) Building Daniel J. MacDonald (DJM) Building Modernization, Charlottetown, PE	
<b>Solicitation No. - N° de l'invitation</b> ED001-212664/B	<b>Amendment No. - N° modif.</b> 009
<b>Client Reference No. - N° de référence du client</b> ED001-212664	<b>Date</b> 2022-07-12
<b>GETS Reference No. - N° de référence de SEAG</b> PW-SPWC-034-4575	
<b>File No. - N° de dossier</b> PWC-2-45003 (034)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Atlantic Daylight Saving Time ADT <b>on - le 2022-08-03</b> Heure Avancée de l'Atlantique HAA	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Stockman (PWC), Sonia	<b>Buyer Id - Id de l'acheteur</b> pwc034
<b>Telephone No. - N° de téléphone</b> (506) 961-7412 ( )	<b>FAX No. - N° de FAX</b> (506) 851-6759
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Solicitation Amendment No. nine (9) is raised to include the following :

1. Answer the following questions:

**Q31.** Reference Section 10 23 26 - Glass Partition Systems-- Can PVC gaskets be used in place of ABS?

**A31.** No. Specification is to be followed as written.

**Q32.** Please advise if the below manufacturers are acceptable:

Grilles and diffusers – section 23 37 13 – Nailor

VAV boxes and fan powered boxes – section 23 36 00 - Nailor

Fire/smoke dampers and fire dampers – section 23 33 16 – Nailor

Louvers – section 23 37 20 - Ventex

Control dampers – section 23 33 15 – Alumavent or Nailor

Fans – section 23 34 00 and 23 34 23.13 - Loren Cook

ERV – section 23 72 00 – Loren Cook

Silencers – section 23 33 53 - VAW Systems

Destrat fans – section 23 34 13 - Big Ass fans or Canarm HVLS

**A32.** Only products meeting specifications and drawings will be acceptable

**Q33.** Reference to Specification 10 23 26 – Glass Partition System-Specs call for laminate doors, is veneer an acceptable alternate?

**A33.** Bidders to price as specified. Product substitutions can be considered during construction with samples and product substitution process.

**Q34.** Reference to Specification 10 23 26 – Glass Partition System- Two STC rating are noted, 36 and 46, which will be difficult to blend and keep true STC rating for each application once installed. Once a door way is installed in any glass wall that STC no longer reflects the glass rating. Is a solution with full 36 STC acceptable including the doorways? If not what is the minimum Acceptable STC?

**A34.** The glass and frames in the wall assembly are to meet the requirements as shown in the STC plans, the door is to meet the requirements as shown on the Door Schedule - the overall performance of the entire wall may not reflect the performance of these individual components.

**Q35.** Reference to Specification 10 23 26 – Glass Partition System- Hardware set notes continuous hinge, is a standard Butt hinge acceptable?

**R35.** No

**Q36.** Reference to Specification 10 23 26 – Glass Partition System- 2.1.2 calls for unitized panels however in the type 1 frame elevations it shows butt glazed glass which is contradictory of the unitized panel requirement, can additional clarification be provided as what style is being requested?

**A36.** The perimeter frames are to be unitized panels however, where internal joints are required because of the length of individual panels is insufficient to fill the entire opening a silicone butt joint will be required. Please see Spec Section 01 61 10, Items GS-1, GS-2, GS-3 for a more complete description of these systems

**Q37.** Reference to Specification 10 23 26 – Glass Partition System- Specs call for laminated glass, is tempered acceptable?

**A37.** Lamination is required to achieve the STC ratings required of the glass partition system

**All other terms and conditions remain the same.**