

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
MAU1-1		HVAC	AHU	Captive Aire	A1-D.250-G10	1	Popina	Requires a filter change	230V	8.1A		Quarter
AC-1-1	6YW01885	HVAC	Air cooled Condenser	Mitsubishi	PUHY-P96tKMU-A	1	Popina		230V	4.5A		Quarter

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
UH-1-2	BKK7943N26266X	HVAC	Gas fired Unit Heater	Reznor	UDAP225	2	Food Court East	Needs Annual gas Testing				Semi
UH-2-2	C794584	HVAC	Gas fired Unit Heater	ITT	BLO-400	2	Market	Needs Annual gas Testing				Semi
UH-3-2	B1A7943N83853X	HVAC	Gas fired Unit Heater	Reznor	UDPOB400	2	Market	Needs Annual gas Testing				Semi
UH-1-3	A2C66Q3N03517TE	HVAC	Gas fired Unit Heater	Reznor	B250-E	2	Market	Needs Annual gas Testing				Semi
UH-2-3	A2C66A3N03515TE	HVAC	Gas fired Unit Heater	Reznor	B250-E	2	Market	Needs Annual gas Testing				Semi
UH-3-3	3001090909451--9694	HVAC	Gas fired Unit Heater	Modine	PDP250AE 0130	2	Market	Needs Annual gas Testing				Semi
UH-1-4	18010905092410-2987	HVAC	Gas fired Unit Heater	Modine	PDP400AE 0130	2	Market	Needs Annual gas Testing				Semi
UH-2-4	A2C66Q3N03518TE	HVAC	Gas fired Unit Heater	Reznor	B400	2	Market	Needs Annual gas Testing				Semi
UH-3-4	A2C66Q3N03518TE	HVAC	Gas fired Unit Heater	Reznor	B250-E	2	Market	Needs Annual gas Testing				Semi
UH-1-7	15101052044697	HVAC	Gas fired Unit Heater	Modine	BP250AE28 31	2	Market	Needs Annual gas Testing				Semi
UH-2-7	A2C66Q3N03519TE	HVAC	Gas fired Unit Heater	Modine	B250-E	2	Market	Needs Annual gas Testing				Semi
EF-6-2	LB24	HVAC	Exhaust Fan	PVC	DOMEX	2	Electrical Vault	3/4HP	200V	3.45A		Annual
EF-7-2	LB24	HVAC	Exhaust Fan	PVC	DOMEX	2	Electrical Vault	3/4HP	200V	3.45A		Annual
EF-8-2	90J05533	HVAC	Exhaust Fan	Greenheck	G-90-DGEX-OD	2	Womens Washroom					Annual
EF-1-4	118SG52907 00/0000701	HVAC	Exhaust Fan	Cook	120 ACF 120C10D	2	Mens Washroom	Direct Drive fan 0.167HP	115V	1.8A		Annual
EF-2-4	LB24	HVAC	Exhaust Fan	PVC	DOMEX	2	Exhaust above staff Bathrooms	Belt: Qty 1 A29/4L310 1/8HP	115V	07/4.5A		Annual
EF-9-2	AB35	HVAC	Exhaust Fan	PVC	DOMEX	2	Exhaust for Baby change room	Belt Qty 1 4L240 1/6HP	115V	3.6A		Annual
EF no tag					PENN		Elec room center					Annual
EF no tag							Elec room center	wall mounted				Annual
EF no tag					PENN		Elec room East roof	On Roof, need a boom to service				Annual
UH							Elec room East	Electric				Annual
UH							Elec room west	Electric				Annual
UH							Elec room center	Electric				Annual
EF 10		HVAC						Market EF entrance doors				Annual
EF 11		HVAC						Market EF entrance doors				Annual
EF 12		HVAC						Market EF entrance doors				Annual
EF 13		HVAC						Market EF entrance doors				Annual
EF 14		HVAC						Market EF entrance doors				Annual
EF 15		HVAC						Market EF entrance doors				Annual
EF 16		HVAC						Market EF entrance doors				Annual
EF 17		HVAC						Market EF entrance doors				Annual
EF 18		HVAC						Market EF entrance doors				Annual
EF 19		HVAC						Market EF entrance doors				Annual
EF 20		HVAC						Market EF entrance doors				Annual
EF 21		HVAC						Market EF entrance doors				Annual
EF 22		HVAC						Market EF entrance doors				Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
JANUARY	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
EF1												Annual
EF2												Annual
EF3												Annual
EF4												Annual
EF5												Annual
EF6												Annual
RTU-1-6	2892F09222	HVAC	AHU	CARRIER RTU	48DR016530	6	Review Stage		208/230V	5.4/12/0.94	216000 BTUH	Quarter

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	SERVICE
Boiler 1	65151654EVCA2000BN1-UEA	HVAC	Boiler	Thermal solutions		20	HUB	Heat			Semi
Boiler 2		HVAC	Boiler	RBI	Futera 2	20	HUB	Heat			Semi
Boiler 3	111366311	HVAC	Boiler	RBI	Futera 3	20	HUB	Heat			Semi
Domestic Boiler	AA34-89-0784	HVAC	Boiler	Patterson Kelly		20	HUB	Domestic			Semi
CO sensor system		HVAC	CO sensor	Honeywell		20	HUB	Annual Test/ Calibration			Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
UH-1-27		HVAC	Gas fired Unit Heater	Modene	F50	27	1249 Cartwright		115V	1.5A	40000BTUH	Semi
UH-2-27		HVAC	Gas fired Unit Heater	Reznor	F50	27	1249 Cartwright		115V	1.5A	40000BTUH	Semi
UH-3-27	ADF41K5N36979	HVAC	Gas fired Unit Heater	Reznor	F50	27	1247 cartwright	Needs annual gas testing	115V	1.5A	40000BTUH	Semi
UH-4-27	ADF41K5N36977	HVAC	Gas fired Unit Heater	Reznor	F50	27	1247 cartwright	Needs annual gas testing	115V	1.5A	40000BTUH	Semi
UH-5-27	ADF41K5N36975	HVAC	Gas fired Unit Heater	Reznor	F50	27	1245 Cartwright	Needs annual gas testing	115V	1.5A	40000BTUH	Semi
UH-6-27		HVAC	Gas fired Unit Heater	Modene	F50	27	1243 Cartwright	Needs annual gas testing	115V	1.5A	40000BTUH	Semi
UH-7-27	ADF41K5N36978	HVAC	Gas fired Unit Heater	Reznor	F50	27	1243 Cartwright	Needs annual gas testing	115V	1.5A	40000BTUH	Semi
AC-1-27	4013C82418	HVAC	AHU	Carrier	48TCE07A2 A5A0A0A	27	Fdn of Cdn Artists	Filters Qty 4-16x16x2	208/230V	1.5A	93,000 BTUH	Quarter
EF-2-27	C15AY51122	HVAC	Exhaust Fan	Penn	DX10R	27	Mech Room	1/12HP	115V			Annual
EF-1-27	XR-60	HVAC	Exhaust Fan	Penn	Domex	27	Mech Room					Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	SERVICE
CO/P-1-31		CO sensors	HVAC sensor	OEL		31	Parkade	Needs Annual Testing			Annual
EF-18-31		HVAC	Exhaust Fan	Greenheck	Cube-420-20	31	Parkade				Annual
EF-20-31		HVAC	Exhaust Fan	Greenheck	Cube-420-20	31	Parkade				Annual
EF-26-31	31112371	HVAC	Exhaust Fan	Greenheck	Cube-420-20	31	Parkade	Belt: Qty 1-A71			Annual
EF-1-31	37F614T523	HVAC	Exhaust Fan	Baldor	EM3313T-5	31	Bldg 31				Annual
EF-30-31	93H12336	HVAC	Exhaust Fan	Greenheck	BSO-130-5	31	Electrical Vault	Belt Qty 1-4L430			Annual
FC-1-31	930866394	HVAC	AHU	Magic Air	60-EWH-6-A	31	Electrical Vault	Filter: Qty (3) 16x20x1 (1) 20x20x2 (1) 20x25x2 1/2HP	208V	3.8A	Quarterly
SF-09-31	93H112980	HVAC	AHU	Greenheck	BCF-THH-06-3	31	Elevator Room	lower level by elevator room			Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS		SERVICE
EF-1-33		HVAC	Exhaust Fan	Broan	L150	33	BC Blacksmith	Deleted	120V	1.3A		Annual
EF-2-33		HVAC	Exhaust Fan	Broan	L150	33	Upstart		120V	1.3A		Annual
EF-3-33		HVAC	Exhaust Fan	Broan	L150	33	Hilary Morris Studio		120V	1.3A		Annual
EF-4-33		HVAC	Exhaust Fan	Broan	L150	33	Funk Shui		120V	1.3A		Annual
EF-5-33		HVAC	Exhaust Fan	Broan	L150	33	Alarte		120V	1.3A		Annual
EF-6-33		HVAC	Exhaust Fan	Broan	L150	33	Off the Tracks		120V	1.3A		Annual
EF-7-33		HVAC	Exhaust Fan	Broan	L150	33	Aurum-Argentum		120V	1.3A		Annual
EF-8-33		HVAC	Exhaust Fan	Broan	L150	33	Hartman Leather		120V	1.3A		Annual
EF-9-33		HVAC	Exhaust Fan	Broan	L150	33	Artisan Sake Maker		120V	1.3A		Annual
EF-10-33		HVAC	Exhaust Fan	Broan	L150	33	Dalbergia		120V	1.3A		Annual
EF-11-33		HVAC	Exhaust Fan	Broan	L150	33	Peter Kiss		120V	1.3A		Annual
EF-12-33		HVAC	Exhaust Fan	Broan	L150	33	Sandryna Design		120V	1.3A		Annual
EF-13-33		HVAC	Exhaust Fan	Broan	L150	33	Studio 13		120V	1.3A		Annual
UH-1-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	BC Blacksmith		120V	4.9A	21870 BTUH	Semi
UH-2-33	E00102546012	HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Upstart		120V	4.9A	21870 BTUH	Semi
UH-3-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Hilary Morris Studio		120V	4.9A	21870 BTUH	Semi
UH-4-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Funk Shui		120V	4.9A	21870 BTUH	Semi
UH-5-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Alarte		120V	4.9A	21870 BTUH	Semi
UH-6-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Off the Tracks		120V	4.9A	21870 BTUH	Semi
UH-7-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Aurum-Argentum		120V	4.9A	21870 BTUH	Semi
UH-8-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Hartman Leather		120V	4.9A	21870 BTUH	Semi
UH-9-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Artisan Sake Maker		120V	4.9A	21870 BTUH	Semi
UH-10-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Dalbergia		120V	4.9A	21870 BTUH	Semi
UH-11-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Peter Kiss		120V	4.9A	21870 BTUH	Semi
UH-12-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Sandryna Design		120V	4.9A	21870 BTUH	Semi
UH-13-33		HVAC	Gas fired Unit Heater	Sterling	RF-30	33	Studio 13		120V	4.9A	21870 BTUH	Semi

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS		SERVICE
F-1-34	9904082	HVAC	AHU	Eng Air	XE160HBM AES/S	34	Bldg 34	Filter- Qty (1) 15x30x1	208V	8.8A	128,000 BTU	Semi
F-2-34	9904083	HVAC	AHU	Eng Air	XE160HBM AES/S	34	Bldg 34	Filter- Qty (1) 15x30x1	208V	8.8A	128,000 BTU	Semi

Start of Heating season, September/December

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS		SERVICE
CO Sensor system		HVAC	CO sensor	Honeywell		36	Parking area	two sensors to be tested annually				Annual
EF-2-36	M09AK92161	HVAC	Exhaust fan	Penn Barry	FX18BH	36	Dry Storage	Belt: Qty 1-A27	115V	6.25/3A		Annual
EF-5-36	L09AI81162	HVAC	Exhaust fan	Penn Barry	FX14B	36	Parkade	Operated by CO sensor Belt: Qty 1-4L250 0.18KW	115V	4.80/2.30-2.40A		Annual
EF-1-36	L09AI87576	HVAC	Exhaust fan	Penn Barry	FX18BH	36	Parkade	Operated by CO sensor Belt: Qty 1-4L290 0.25KW	115V	6.25/3A		Annual
007-36	T10A06236	HVAC	Air Cooled Condenser	Larkin	LZT025M6 C	36	Cold Storage	Refrigerant type 404a, 22 0.04KW	200-230V	1 Amp		
008-36	T10A06233	HVAC	Air Cooled Condenser	Larkin	LHT030X6C	36	Cold Storage	Refrigerant type 404a 0.04KW	200-230V	3.5 A		
EF-4-36	D11AB43831	HVAC	Exhaust Fan	Penn Barry	FX18BHFT	36	Edible Canada Bathroom		208V			
RTU-1-36	358001109	HVAC	AHU	Ice	HTDM 1000	36	Edible Canada		208V	28 A		

SERVICE MONTH	PRICE+GST
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	SERVICE
HP-1-38		HVAC	Variable refrigerant			38	B&B scale models	split system, upper Office			Quarter
UH-5-38		HVAC	Gas Fired Unit Heater	Reznor	V3 SCV	38	B&B scale models	Needs annual Gas Testing			Semi
UH-2-38		HVAC	Gas Fired Unit Heater	Reznor	V3 SCV	38	B&B scale models	Needs annual Gas Testing			Semi
UH-3-38		HVAC	Gas Fired Unit Heater	Reznor	V3 SCV	38	Malasapina	Needs annual Gas Testing			Semi
UH-4-38		HVAC	Gas Fired Unit Heater	Reznor	V3 SCV	38	Malasapina	Needs annual Gas Testing			Semi
SF-2-38	BN4-124	HVAC	Supply Fan with Duct heater	MagneTek	65420-20	38	Malasapina				Semi
HP-2-38		HVAC	Variable refrigerant			38	Island studios	split system, Island studios			Quarter

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	SERVICE
RTU#3	1317118926	HVAC	AHU	Trane	Multizone-M#YCH092F3RHA04COOA	40		Filters: Qty 4-20x25x2 2-20x25x2 media	House Panel-40-13		Quarter
MUA-1-39-1649	S20809-HV-1	HVAC	AHU	Eng Air	S-150-O	40	1649	Belt: Qty-1 AX40			Quarter
AC-6-39-1645	3436244	HVAC	AHU	Pace	A12-12FC	40	1649	4-20x25x2 TAS			Quarter
SP-1-39-200-250	5605D05512	HVAC	Air cooled Condenser	Lennox	HS29-090-3Y	40	200-250	Filters: Qty-4 16x20x2			Semi
EF-1-39	N/A	HVAC	Exhaust Fan	Penn	Domex	40	Net Loft				Annual
EF-1-40	AB-35	HVAC	Exhaust Fan	Penn	Domex	40	Net Loft	Belt: Qty-1 4L230	115V	5.0A	Annual
EF-3-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	Fibre Arts Exhaust		115V	0.9A	Annual
EF-2-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	Kingsmill Studio		115V	0.9A	Annual
EF-4-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	Luthery		115V	0.9A	Annual
EF-5-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	Kroma Paints		115V	0.9A	Annual
EF-6-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	John Notter Studio		115V	0.9A	Annual
EF-7-39		HVAC	Exhaust Fan	General Electric	5KCP39CN8039A	40	John Notter Studio		115V	0.9A	Annual
RTU#2	131711790L	HVAC	AHU	Trane	YCH092F3RHA04COOA	40		Filters: QTY 4 - 20x25x2 TAS	House Panel-40-13		Quarter
RTU#4	C13C01330	HVAC	AHU	Trane	YCD420BELK24A2DC50BC	40		Filters: Qty 16 - 16x20x2 Belt BX 103	House Panel-40-13		Quarter
RTU#5	C13C01331	HVAC	AHU	Trane	YCD420BELK24A2DC50BC	40		Filters: 16-16x20x2 Belt BX 103	House Panel-40-13		Quarter
UHH#1	6394A51765	HVAC	Gas Fired Unit Heater	Lennox	LF24-100A-1	40	John Notter Studio				Semi
UHH#2	6392M55195	HVAC	Gas Fired Unit Heater	Lennox	LF24-100A-1	40	John Notter Studio				Semi
EF-2-40-S1	BB45	HVAC	Exhaust Fan	Penn	Domex	40	Washrooms Exhaust	Belt: Qty-1 3L240			Annual
EF-3-40-1640	N/A	HVAC	Exhaust Fan	Greenheck	N/A	40	1640	Belt (HM-25)			Annual
EF-4-40	N/A	HVAC	Exhaust Fan	Greenheck	N/A	40	Net Loft	Belt- HM-22			Annual
EF-5-40		HVAC	Exhaust Fan	Delhi		40	Dundegrave Studio	Belt: Qty 1-A33/4L350			Annual
AC-5-41-211	NCNM061447	HVAC	AHU	York	D7CG036N07925A	40	West Offices	Filters: 2-15x20x2 and 1-14x30x2 TAS			Quarter
AC-4-41-211	NFNM080762	HVAC	AHU	York	DM102N15B2AAA3C	40	Reception	Filters: 4-20x25x2 TAS 1-14x25x2 2-14x20x2 Belt: Qty 1-A56			Quarter
AC-3-41-211	NGNM085538	HVAC	AHU	York	D7CG048N09925A	40	East Offices	Filters: 2-15x20x2 and 1-14x30x2 TAS			Quarter
RTU#1	131711799L	HVAC	AHU	Trane	YHC092F3RHA02QP	40	10-20-30-40	Filters: 4-20x25x2			Quarter
MUA-2-41-	5870-1	HVAC	AHU	Eng Air	S-300-OVF1	40	203-201-301	Filters: 4-16x20x2 media Belt: Qty 1-B58			Quarter
SP-1-41-211	94E01382C	HVAC	Air cooled Condenser	Mitsubishi	PU24EK	40	Boardroom	washable filters	115V	5.6A	Semi
SP-2-41-1660	DDN000940	HVAC	Air cooled Condenser	Fujitsu	AOV24CL	40	Net Loft- Upper Roof	washable filters			Semi
EF-1-41	NTB328711	HVAC	Exhaust Fan	Centri Master	PNN245H	40	Net Loft- Upper Roof	Belt: Qty-1 A34 HP: 0.750	115V		Annual
EF-2-41	138628591409	HVAC	Exhaust Fan	Greenheck	CBE-141-4X-QD	40	Net Loft- Upper Roof	Belt: Qty-1 3L220	115V	5.4A	Annual
UH-1-40		HVAC	Unit Heater	FPE	UH27-383-2-24	40	Admin office entrance stairwell	Electric UH, ANNUAL	208V	1.1A	Annual
SP-3-41	DDA001096	HVAC	Air cooled Condenser	Fujitsu	ASU24CL	40	Liberty Wines		208/230V	0.2A	Semi

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	R	SERVICE
HP-1-58		HVAC	Condenser unit	Mitsubishi	PUZ-A36NKA7	58	Interior	split Heat pump, On Roof	208/230		R410A	Quarter
HP-2-58	11R02973	HVAC	Fan coil	Mitsubishi	PEAD-A36AA7MX	58	Interior	Inside unit	208/230			Quarter

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
UH-2-59	5610E02072	HVAC	Gas Fired Unit Heater		7813703	59	Liberty Distillery	Needs Annual Gas Testing				Semi
SF-1-59	2G7496ADBAF481003188	HVAC	AHU	Rheem	RKNL-A036JK12E	59	Liberty Distillery	Needs filter change 16x20x1	208-230V	16.7A	94,500 BTU	Quarter
EF-1-59		HVAC	Exhaust fan	Delhi	309	59	Washrooms/shower of shop	Belt: Qty 1-4L400				Annual
EF-2-59		HVAC	Exhaust fan	Delhi	309	59	Kitchen	Belt: Qty 1-4L330				Annual
UH-1-59	5609B01678	HVAC	Gas Fired Unit Heater	Lenox	LF24-200A-6	59	Mech Shop		120V	6A (max)	195,000 BTUH	Semi
DE-1-59	0063004 0810	HVAC	Exhaust fan	CEG	DMOML80 B2234R71	59	Mech Shop	Direct Drive 1.1KW	115/230V	14.7/7.4A		Annual
EF-3-59		HVAC	Exhaust fan		71731567	59	Tool Room	Direct Drive	115V	1.4A		Annual
SF-4-59	"05-2011"	HVAC	AHU	Thermolec	FC-TER-10-5240	59	Lunch Room	Filter: Qty (1) 12x24x2 5.0KW	240V	20.83		Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
UH-1-62		HVAC	Gas Fired Unit Heater	Lennox		62	Artist Studios	Needs annual Gas Testing				Semi
UH-2-62		HVAC	Gas Fired Unit Heater	Lennox		62	Artist Studios	Needs annual Gas Testing				Semi
EF-1-62			Exhaust Fan	General Elec	5KH33FN7	62	Paint booth in all tenants	Belt: Qty 1-3L220				Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
MUA-1-70	18521-AH-2	HVAC	AHU	Eng Air	DJ-100	70	Theatre	Filters- Qty (9) 20x25x2 Belts - Qty (3) B88 Rear of building				Quarter
EF-1-70	LC12X	HVAC	Exhaust Fan	Penn	Dynafan (west)	70	West	West Theatre				Annual
EF-2-70	LC12A	HVAC	Exhaust Fan	Penn	Dynafan (east)	70	East	East Theatre				Annual
EF-3-70	06AB42711	HVAC	Exhaust Fan	Penn	ZPR0188	70	Bathroom	Bathroom fan dual shaft				Annual
MUA-2-70	18521-AH-1	HVAC	AHU	Eng Air	DJ-40	70	Lobby	Filters - Qty (2) 20x25x2 (2) 16x25x2 Belts Qty (2) B63	208V	23A	304,000	Quarter
F1-70	276SF48312-00/00007	HVAC	Exhaust Fan	Cook	365 SQI 365SQIB	70		2HP Large MUA on roof	208V			Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
HP-1-72		HVAC	Fan coil	Samsung	AM048MNHDC	72	Unit 4		208-230V	2A	48 000	quarter
HP-2-72		HVAC	Fan coil	Samsung	AM048MNHDC	72	Unit 4		208-230V	2A	48 000	quarter
MCU-1-72		HVAC	Heat EX	Samsung	MCU-S4NEK3N	72	Unit 4		208-230V	0.2A		quarter
HP-3-72		HVAC	Fan coil	Samsung	AM012MNMDC	72	Unit 3		208-230V	1.1A	12 000	quarter
HP-4-72	ORZAPALK800059D	HVAC	Fan coil	Samsung	AM048MNHDC	72	Unit 3		208-230V	2A	48 000	quarter
MCU-2-72	B814P3X	HVAC	Heat EX	Samsung	MCU-S4NEK3N	72	Unit 3		208-230V	0.2A		quarter
HP-5-72	ORZAPALK800036X	HVAC	Fan coil	Samsung	AM048MNHDC	72	Unit 2		208-230V	2A	48 000	quarter
EF-4-72		HVAC	Exhaust Fan	Queace	S33Q222ZB-09+	72	Unit 4		115V	0.4/0.22A		Annual
EF-2-72		HVAC	Exhaust Fan	Queace	S33Q222ZB-09+	72	Unit 2		115V	0.4/0.22A		Annual
EF-3-72		HVAC	Exhaust Fan	Queace	S33Q222ZB-09+	72	Unit 3		115V	0.4/0.22A		Annual
EF-1-72		HVAC	Exhaust fan	Rotom	8213215115	72	Unit 1	Bathroom Exhaust	115V	0.65A		Annual
EF-3.2-72		HVAC	Exhaust Fan	fanAm	CBI Jet 315	72	Unit 3		115/208-230V			Annual
SP-4.1-72	B83YP3GK800005B	HVAC	Air cooled Condenser	Samsung	AM120FXVAFR	72	Unit 4		208-230V	3.0A	129 000	quarter
SP-3.1-72	B83RP3GK800005H	HVAC	Air cooled Condenser	Samsung	AM072FXVAFR	72	Unit 3		208-230V	4.0A		quarter
SP-2.1-72	B10SP3AK800063W	HVAC	Air cooled Condenser	Samsung	AM048FXMDCH	72	Unit 2		208-230V	0.6A		quarter
EF-1.2-72	W6-9	HVAC	Exhaust Fan	Baldor		72	Unit 1		208-230V			Annual
SF-1-72		HVAC	Supply Fan with Heater	Armstrong	Ultra SX 80	72	Unit 1 IE Creative	Requires a filter change				Semi

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	AMPS	BTU	SERVICE
AC-1-89	4298G20856	HVAC	AHU	Carrier	48TJE006501GA	89	1st/2nd Floor (South)	Filters - Qty (2) 16x25x2 Belts - Qty (1) 4L410/AX39				Quarter
AC-2-89	3198G10707	HVAC	AHU	Carrier	48SS042100531AA	89	Ground Floor North	Filters - Qty (1) 20x20x2				Quarter
AC-3-89	0299G30190	HVAC	AHU	Carrier	48TJE008-521GA	89	Top Floor S.W.	Filters - Qty (4) 16x20x2 Belts - Qty (1) 4L500/AX47				Quarter
AC-4-89	3397G30870	HVAC	AHU	Carrier	48TJE008-511GA	89	Top Floor N.W	Filters - Qty (4) 16x20x2 Belts - Qty (1) 4L510/AX47				Quarter
AC-5-89	7000049T	HVAC	AHU	Mitsubishi	MUH15NNV1	89	2nd Floor, PTC Library					Semi
AC-6-89	7000082T	HVAC	AHU	Mitsubishi	MUH12NNV1	89	3rd Floor Booth					Semi
EF-1-89	368841 002	HVAC	Exhaust Fan	Carnes	VEBK12L1A1CA20SK C1	89	Bathroom Exhausts		115V			Annual

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	

Asset Tag	Serial	Model category	Model Sub	Make	Model	Building number	Serves	Comments	Volts	BTU	SERVICE
EF-2	N/A	HVAC	Exhaust Fan	NO TAG	N/A	93	N.E Side	Northeast- Upper Roof			Annual
EF-1	N/A	HVAC	Exhaust Fan	NO TAG	N/A	93	South Side	South- Upper Roof			Annual
WEF-2	118SG85370 00/0000701	HVAC	Exhaust Fan	Cook	120 ACE 120C13D	93			115V		Annual
EF-3	N/A	HVAC	Exhaust Fan	NO TAG	N/A	93	N.W Side	Northwest- Upper Roof 0.250HP			Annual
EF-5	N/A	HVAC	Exhaust Fan	NO TAG	N/A	93	East Wall- Ground Level	Wall mount - East wall ground level			Annual
EF-4	XQ82	HVAC	Exhaust Fan	Penn	Domex	93	Lower Roof	Lower Roof			Annual
AC-1-93	248100166D	HVAC	AHU	Trane	YCD150D3HAA A	93	Upper Theatre	Filters - Qty (2) 20x20x2 (4) 20x25x2 Belt Qty (1) B62	208-230/4	203,000 BTUH	Quarter
AC-2-93	25151781H	HVAC	AHU	Trane	YCC030F1MOB H	93	Lounge	Filters - Qty (1) 20x25x2		60,000 BTUH	Quarter
AC-3-93	304101040L	HVAC	AHU	Trane	YSC060A3RHA1 3DOB0000	93	Upper Dressing Room	Filters - Qty (2) 20x30x2			Quarter

SERVICE MONTH	PRICE+GST
SEPTEMBER	
DECEMBER	
MARCH	
JUNE	
PRICE PER ANNUM	