


NOTES:

1. PROVIDE THREE (3) NEW ENCLOSED STOP PUSHBUTTONS TO READ "EMERGENCY BOILER # SHUTDOWN". SWITCHES TO BE IN BOTH LOCATIONS AS INDICATED.
2. EXTEND, RE-ROUTE, RE-WIRE AND RECONNECT NEW AND EXISTING EQUIPMENT TO EXISTING CIRCUIT AS POSSIBLE SITE.



3	ISSUED FOR CONSTRUCTION	2022-05-17
2	99% CONSTRUCTION DOCUMENT	2021-08-06
1	50% DESIGN SUBMISSION	2021-05-28

revisions		date
project		projet

Wabush - ATB Boiler Upgrade

Wabush Airport Terminal Building (ATB)

BOILER ROOM - NEW POWER PLAN AND WALL ELEVATION

designed BC conçu

drawn RD dessiné

approved HCC approuvé

Tender Soumission


PSPC Project Manager Administrateur de projets TPSGC

project no. no. du projet

R111141.001

drawing no. no. du dessin

E-5



APPROX. NORTH

BOILER'S EMERGENCY SHUT-OFF SWITCHES. LOCATE INSIDE BOILER ROOM (SHOWN FOR REFERENCE ONLY)

EXISTING TO REMAIN

1 BOILER ROOM - NEW POWER PLAN  
E-5 1 : 50

2 WALL ELEVATION - NEW  
E-5 NTS