

Part 1 General

1.1 REFERENCES

- .1 ASTM International
 - .1 ASTM A123/A123M-13, Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
 - .2 ASTM A653/A653M-13, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvanealloyed) by the Hot-Dip Process.
 - .3 ASTM F1667-13, Standard Specification for Driven Fasteners: Nails, Spikes, and Staples.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB 51.34-M86, Vapour Barrier, Polyethylene Sheet for Use in Building Construction and amendment.
- .3 CSA Group
 - .1 CSA O80-Series-08, Wood Preservation.
 - .2 CSA O112.9-10 (R2014), Evaluation of Adhesives for Structural Wood Products (Exterior Exposure).
 - .3 CSA O121-08 (R2013), Douglas Fir Plywood.
 - .4 CSA O141-05 (R2014), Softwood Lumber.
 - .5 CSA O151-09 (R2014), Canadian Softwood Plywood.
 - .6 CSA O325-07 (R2012), Construction Sheathing.
- .4 National Lumber Grades Authority (NLGA)
 - .1 NLGA Standard Grading Rules for Canadian Lumber (2014 edition).

1.2 QUALITY ASSURANCE

- .1 Lumber by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood, particleboard, OSB, and wood based composite panels in accordance with CSA and ANSI standards.

1.3 DELIVERY, STORAGE, AND HANDLING

- .1 Deliver, store, and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect wood products from damage.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 FRAMING STRUCTURAL AND PANEL MATERIALS

- .1 Lumber: Softwood, S4S, moisture content 19% (S-dry) or less in accordance with following standards:
 - .1 CSA O141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
- .2 Furring, blocking, nailing strips, grounds, rough bucks, cants, curbs, fascia backing and sleepers:
 - .1 Use S2S or S4S materials.
 - .2 Board sizes: "Standard" or better grade.
 - .3 Dimension sizes: "Standard" light framing or better grade.
- .3 Plywood, OSB and wood based composite panels: CSA O325.
- .4 Douglas fir plywood (DFP): CSA O121, standard construction.
- .5 Canadian softwood plywood (CSP): CSA O151, standard construction.
- .6 Treated wood products: To CSA O80 Series.

2.2 ACCESSORIES

- .1 Vapour barrier: Polyethylene film to CAN/CGSB 51.34, Type 1, 0.25 mm (10 mils) thick.
- .2 Sealants: In accordance with Section 07 92 00 - Joint Sealants.
- .3 General purpose adhesive: CSA O112.9.
- .4 Nails, spikes and staples: ASTM F1667.
- .5 Bolts: 12.5 mm diameter unless indicated otherwise, complete with nuts and washers.
- .6 Proprietary fasteners: Toggle bolts, expansion shields and lag bolts, screws and lead or inorganic fibre plugs, recommended for purpose by manufacturer.
- .7 Fasteners: Hot dipped galvanized steel to ASTM A123/A123M or ASTM A653/A653M for high humidity and treated wood locations, unfinished steel elsewhere.
- .8 Wood Preservative:
 - .1 Preservative: in accordance with manufacturer's recommendations for surface conditions.

Part 3 Execution

3.1 EXAMINATION

- .1 Verify conditions of substrates are acceptable for rough carpentry installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate.
 - .2 Inform Departmental Representative of unacceptable conditions.
 - .3 Proceed with installation only after unacceptable conditions have been remedied.

3.2 PREPARATION

- .1 Treat surfaces of material with wood preservative, before installation.
- .2 Use pressure-treated lumber at wet locations and at locations in contact with concrete.

3.3 FURRING AND BLOCKING

- .1 Install furring and blocking as required to space-out and support electrical equipment mounting boards, architectural hardware, fire extinguisher brackets, and other work as required.
- .2 Install rough bucks, nailers, and linings to rough openings as required to provide backing for frames and other work.
- .3 Install wood cants, nailers, curbs, and other wood supports as required and secure using galvanized steel fasteners.
- .4 Install sleepers as indicated.

3.4 EQUIPMENT/ELECTRICAL MOUNTING BOARD

- .1 Equipment/Electrical mounting board:
 - .1 Douglas Fir plywood, good one side.
 - .2 Size: 1220 x 2440 mm x 19 mm (48 x 96 x ¾ inch).
 - .3 Finish: Fire retardant paint finish, refer to Section 09 91 00 – Painting; white or to match wall colour unless otherwise specified; finish on all six surfaces prior to installation to ensure proper sealing.
 - .4 Fastening: Exposed stainless steel fasteners, at 400 mm (16 inches) o.c. unless otherwise specified.

3.5 CLEANING

- .1 Clean in accordance with Section 01 74 00 - Cleaning.
- .2 Leave Work area clean at end of each day.
- .3 Final Cleaning: Upon completion, remove surplus materials, rubbish, tools, and equipment.

3.6 WASTE MANAGEMENT

- .1 Remove waste materials in accordance with Section 01 74 19 - Waste Management and Disposal.
- .2 Re-use scrap lumber to the greatest extent possible. Separate scrap lumber for use on site as accessory components, including shims, bracing, and blocking.
- .3 Do not leave any wood, shavings, sawdust, or other wood waste on the ground or buried in fill. Prevent saw dust and wood shavings from entering the storm drainage system.
- .4 Do not burn scrap lumber that has been pressure treated.
- .5 Do not send lumber treated with pentachlorophenol, CCA, or ACA to co-generation facilities or “waste-to-energy” facilities.

3.7 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by rough carpentry installation.

END OF SECTION