



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Trans-Canada Highway No.1 Resurfacing – Glacier National Park	
Solicitation No.: 5P468-22-0076/A	Date: July 26, 2022
Amendment No.: 001	
Client Reference No.:	
GETS Reference No.: PW-22-01000999	

Solicitation Closes: At: 2:00 PM On: July 29, 2022	Time Zone: MDT
---	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Jen Maheu	
Telephone No.: 587-432-8458	Fax No.: 1-855-983-1808
Email Address: jennifer.maheu@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Solicitation No.:
5P468-22-0076/A

Amendment No.:
001

Contracting Authority:
Jen Maheu

Ver.02.08.21

Client Reference No.:

Title:
Trans-Canada Highway No.1 Resurfacing – Glacier National Park

Amendment 001

This amendment is raised to extend the solicitation closing date, revise tender package and questions and answers.

A. BID CLOSING DATE

The closing date for tender 5P468-22-0076/A is extended from July 26, 2022 to **July 29, 2022 at 2:00PM Mountain Daylight Time (MDT)**.

B. QUESTION AND ANSWER

Q1: Are there other locations for the application of Reclamite Preservative Treatment not included in the drawing package.

A1: Yes, other locations within Glacier National Park will be selected for surface treatment by the Departmental Representative.

C. TENDER PACKAGE REVISIONS

IN: ITT 22-0076, Bid and Acceptance Form (BA)

DELETE:

BA06 CONSTRUCTION TIME

The Contractor must perform and complete the Work by August 31, 2022.

REPLACE WITH:

BA06 CONSTRUCTION TIME

The Contractor must perform and complete the Work by September 30, 2022.

IN: ITT 22-0076, Appendix 1 Combined Price Form

DELETE:

Unit Price Table Item 5

5	32 01 12	Asphalt Pavement Surface Treatment a) Reclamite Preservative Seal	Litres	32,000	\$	\$
---	----------	---	--------	--------	----	----

REPLACE WITH:

Unit Price Table Item 5

5	32 01 12	Asphalt Pavement Surface Treatment a) Reclamite Preservative Seal	Litres	25,000	\$	\$
---	----------	---	--------	--------	----	----

DELETE:

Unit Price Table Item 8

8	32 17 23	Pavement Marking a) Line Painting	m	5,000	\$	\$
---	----------	--------------------------------------	---	-------	----	----

REPLACE WITH:

Unit Price Table Item 8

8	32 17 23	Pavement Marking a) Line Painting	m	10,000	\$	\$
---	----------	--------------------------------------	---	--------	----	----

IN: Specification Section 01 11 00 Summary of Work

DELETE:

Clause 1.7.5

REPLACE WITH:

Revised Section 01 11 00 Summary of Work, Clause , hereafter presented:

.5 The Contractor shall:

.1 Mobilize after June 1, 2022.

.2 Complete all asphalt paving and rehabilitation works by September 15, 2022

.3 Complete all of the Work by September 30, 2022 (Contract Completion Date).

IN: Specification Section 32 01 12 Asphalt Pavement Surface Treatment

DELETE:

Clause 3.1.3

REPLACE WITH:

Revised Section 32 01 12 Asphalt Pavement Surface Treatment, Clause , hereafter presented:

.3 Dilute Reclamite Preservative Seal with water at **2:1** ratio (2 parts Reclamite to 1 part water) for application.

.1 Mix thoroughly by pumping or other method accepted by Departmental Representative..

DELETE:

Clause 3.1.4

REPLACE WITH:

Revised Section 32 01 12 Asphalt Pavement Surface Treatment, Clause , hereafter presented:

.4 Apply asphalt surface treatment material evenly to pavement surface at rate as directed by Departmental Representative, of **0.4 L/m²** plus or minus 0.1 L/m².

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.