



<p>RETURN BIDS TO: RETOURNER LES SOUMISSIONS À:</p> <p>Bid Receiving - Environment Canada / Réception des soumissions – Environnement Canada</p> <p>Electronic Copy: soumissionsbids@ec.gc.ca</p> <p>BID SOLICITATION AMENDMENT MODIFICATION DE LA DEMANDE DE SOUMISSIONS</p> <p>The referenced Bid Solicitation is revised in this document; unless otherwise indicated, all other terms and conditions of the Bid Solicitation remain the same.</p> <p>La demande de soumissions citée en référence est modifiée dans ce document; sauf indication contraire, les modalités de la demande de soumissions demeurent les mêmes.</p>	Title – Titre	
	Jenpeg Weather Station	
	EC Bid Solicitation No./SAP PR No. - N° de la demande de soumissions EC / N° SAP PR	Amendment No. - N° de modif.
	5000066228	001
	Date of Bid Solicitation (YYYY-MM-DD) – Date de la demande de soumissions (AAAA-MM-JJ)	
	2022-07-20	
	Bid Solicitation Closes (YEAR-MM-DD) - La demande de soumissions prend fin (AAAA-MM-JJ)	Time Zone – Fuseau horaire
	at – à 15 :00h on – 2022-08-12	Eastern Daylight Time
	F.O.B – F.A.B	
	Address Enquiries to - Adresser toutes questions à	
Shawn Davis		
Telephone No. – No de téléphone	Fax No. – No de Fax	
N/A		
Delivery Required (YEAR-MM-DD) – Livraison exigée (AAAA-MM-JJ)		
2022-09-30		
Destination of Services / Destination des services		
Manitoba		



The bid solicitation is modified by the following:

Bid Solicitation Closes (YEAR-MM-DD) - La demande de soumissions prend fin (AAAA-MM-JJ)

Delete :

at – à 15 :00h
on – 2022-08-05

Insert:

at – à 15 :00h
on – 2022-08-12

The amendment to the bid solicitation is to address the enquiries received:

Q1: On the scope of work for electrical. It provides a list of all the material the government will supply. I'm wondering about the instrumentation junction box as to who is supplying it. I do not see any specs on the size of junction box or if it will be supplied by government?

A1: The Instrument junction box which houses the datalogger and where signal cables are terminated is provided by ECCC/Government. It has been procured and populated and is ready for the installation. ECCC will mount as needed.

Q2: The bidders scope of work is to provide a 100a weatherproof panel with breakers and all other material is supplied by government?

A2: The contractor is to provide a 100a weatherproof panel with breakers, all other materials is supplied by Government/ECCC, including cables/junction boxes/terminals etc.

Q3: Who is to terminate the control cable at each weather station?

A3: ECCC/Government Technicians will terminate all control/signal cable utilized for all the sensors at the weather station. The contractor will terminate power cables as per Statement of Work and the Canadian Electrical Code.

End of Amendment