



- NOTES: POWER & SYSTEMS**
- EXISTING TELEPHONE BACKBOARD C/W WITH CONDUIT AND PULL WIRE BACK TO MAIN BUILDING DEMARK.
 - EXISTING POWER GRID IN CEILING SPACE.
 - PROVIDE CONNECTRAC SYSTEM FROM WALL TO CENTER OF TABLE. PROVIDE AV/POWER AND COMMUNICATION MODULE.
 - PROVIDE (1) ONE 100mm x 100mm RECESSED AV BOX ON WALL AND A 41mm CONDUIT STUBBED INTO CEILING SPACE. CONNECTRAC SHALL BE STUBBED INTO AV BOX.
 - PROVIDE POWERED FURNITURE WHIP CONNECTION FOR POWER AND COMMUNICATION E.C. SHALL PROVIDE ALL DATA OUTLET AND CABLING IN FURNITURE AND MAKE ALL FINAL CONNECTIONS. (IN THIS LOCATION ONLY.)
 - EXISTING DOOR ASSIST SHALL REMAIN AND BE MAINTAINED.
 - PROVIDE NEW AUDIBLE/VISUAL FIRE ALARM DEVICE WIRE AND CONNECT TO EXISTING BASE BUILDING FIRE ALARM SYSTEM.
 - POWER FOR CHARGING STATION FOR FORK LIFT.
 - * DESIGNATES A DEDICATED 20 S-SLOT CIRCUIT REQUIRE IN FURNITURE FOR EQUIPMENT.
 - PROVIDE 20A T-SLOT BREAKER FOR INDICATED CIRCUIT.
 - PROVIDE DUPLEX RECEPTACLE WITH ONE USB PORT.
 - REPLACE EXISTING DEVICE WITH NEW DUPLEX RECEPTACLE WITH ONE USB PORT.
 - PROVIDE 2 - CAT 6 CABLES FROM CENTER OF TABLE TO AV BOX AND RUN IN CONDUIT THAT IS STUBBED INTO CEILING SPACE. THE CABLE SHALL BE RUN TO IT ROOM AND ARE PROVIDED FOR AV ONLY.
 - DISCONNECT AND REMOVE EXISTING POWER IN CEILING AND USE POWER TO FEED WAREHOUSE WORKSTATION.
 - PROVIDE 2 COMPARTMENT POWER POLE WIREMOLD.
 - PROVIDE POWER FOR SHREDDER COORDINATE ON SITE WITH TENANT FOR REQUIREMENTS AND PROVIDE RECEPTACLE TO MEET UNITS CONFIGURATION.
 - WIRE AND CONNECT ROLLING DOOR AND ALL CONTROLS, PROVIDE ROUGH IN FOR ANY CONTROL FOR CARD READER ACCESS.
 - WIRE AND CONNECT DOOR ASSIST AND PROVIDE ANY ROUGH IN FOR PROXIMITY READER.
 - RELOCATED EXISTING FIRE ALARM DEVICE TO NEW LOCATION. WIRE AND CONNECT TO EXISTING SYSTEM.
 - DISCONNECT AND RELOCATE POWER FOR HEATING UNIT TO NEW LOCATION SHOWN.
 - PROVIDE EV CHARGING STATION EQUAL TO FLO SMART 2 WALL MOUNTED.
 - COORDINATE MOUNTING LOCATION ON SITE WITH TENANT EQUIPMENT.
 - PROVIDE 20A T-SLOT RECEPTACLE MOUNTED ON ROOF.

Plan de construction seulement pour information et ne doit pas être utilisé pour la construction.
Drawing for information only and shall not be used for Construction.

5		
4		
3		
2		
1		
0	ISSUED FOR CONSTRUCTION	22.01.05
Revision	Description	Date
Client		client

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Project 996
UNIT 120 - 1821 WELLINGTON AVE. WINNIPEG, MANITOBA
IMAGING FACILITIES BUSINESS CONTINUITY SITE

Designed by: ConT'u par
Drawn by: MFP Dessin: par
Approved by: DG Approuvé: par
PWGSC Project Manager / Administrateur de Projets TPSGC
DG

FLOOR PLAN - POWER AND SYSTEMS

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.111175	EP2.0 OF	0

2 FLOOR PLAN - POWER AND SYSTEMS
EP2.0
SCALE: 1:100

