



**RETURN BIDS TO:**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services

**Bid Fax:** 1-855-983-1808

**Bid Email:** [soumissionsami-bidsrpc@pc.gc.ca](mailto:soumissionsami-bidsrpc@pc.gc.ca)

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO AN INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

**Issuing Office:**

Parks Canada Agency  
National Contracting Services  
Calgary, AB

<b>Title:</b> Palisades Machine Shed Renovation, Jasper National Park	
<b>Solicitation No.:</b> 5P468-22-0057/B	<b>Date:</b> August 09, 2022
<b>Amendment No.:</b> 02	
<b>Client Reference No.:</b> N/A	
<b>GETS Reference No.:</b> PW-22-01001951	

<b>Solicitation Closes:</b> <b>At:</b> 2:00 PM <b>On:</b> August 11, 2022	<b>Time Zone:</b> MDT
---	--------------------------

<b>F.O.B.:</b> Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
<b>Address Enquiries to:</b> Ken Lacanilao	
<b>Telephone No.:</b> (587) 832-1894	<b>Fax No.:</b> (855) 983-1808
<b>Email Address:</b> <a href="mailto:kenneth.lacanilao@pc.gc.ca">kenneth.lacanilao@pc.gc.ca</a>	
<b>Destination of Goods, Services, and Construction:</b> See Herein	

**TO BE COMPLETED BY THE BIDDER**

<b>Vendor/ Firm Name:</b>	
<b>Address:</b>	
<b>Telephone No.:</b>	<b>Email.:</b>
<b>Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):</b>	
<b>Signature:</b>	<b>Date:</b>

Solicitation No.:  
5P468-22-0057/B

Amendment No.:  
02

Contracting Authority:  
Ken Lacanillao

Ver.02.08.21

Client Reference No.:  
N/A

Title:  
Palisades Machine Shed Renovation, Jasper National Park

---

## Amendment 001

This amendment is raised to make changes to the specifications, and provide responses to bidder questions.

### A. Questions and Answers

**Q1.** Confirmation that the power requirement was 60A for the machine shed and that this indeed allows for plug-ins for a microwave, kettle and one in the bathroom of both units

**A1.** **The power requirement for the Machine Shed building is to 60A.**

**Q2.** Confirmation that conduit is preferred over tech cable from the panel to the building

**A2.** **As per the drawings and due to environmental conditions, conduit is to be installed over tech cables.**

**Q3.** Can the existing security panel be used?

**A3.** **As per key note #1 on drawing E2, the security panel and monitoring modules are to be reconnected.**

### B. Tender Package/ Solicitation Revisions

In: **2022.06.14 Palisades Machine Shed Specs\_Tender Package.pdf**  
Section: **Section 01 11 00 – Summary of Work**  
Part: **1.1 WORK OF THIS CONTRACT**

Delete: ~~.1 — Mechanical upgrades to add on-demand hot water for the showers and sinks is included.~~

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.**