



**RETURN BIDS TO /
RETOURNER LES SOUMISSIONS Á:**

**Parks Canada Agency, Bid Receiving Unit
National Contracting Services**

BID FAX : 1-855-983-1808

**Bid Email / Courriel de soumission:
soumissionsami-bidsrpc@pc.gc.ca**

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**INVITATION TO TENDER
APPEL D'OFFRES**

Proposal to: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Issuing Office :

Parks Canada Agency
National Contracting Services
Cornwall, Ontario, K6H 6S2

Title-Sujet Western Brook Bridge Replacement, Highway 430, Gros Morne National Park.		
Solicitation No. - No. de l'invitation 5P468-22-0100/A		Date: August 17, 2022
GETS Reference No. – No de référence de SEAG PW-22-01002696		Client Ref. No. – No. de réf du client. 2285
Solicitation Closes – L'invitation prend fin :		
at – à 2:00 PM	on – le August 23, 2022	Time Zone - Fuseau horaire HAT - NDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Sheldon Lalonde sheldon.lalonde@pc.gc.ca		
Telephone No. - No de téléphone 343-585-3836		Fax No. – No de FAX: 1-855-983-1808
Destination of Goods, Services, and Construction: Destinations des biens, services et construction :		
See Herein – Voir aux présentes		

**TO BE COMPLETED BY THE BIDDER
À ÊTRE COMPLÉTÉ PAR LE SOUMISSIONNAIRE**

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

AMENDMENT #1

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

- 1. REVISED SPECIFICATION – 2022/08/11 **ALL OTHER TERMS AND CONDITIONS OF THIS IS REMAIN THE SAME:**

Revisions to the Specifications:		
1.	ADD:	Appendix 'A' – Environmental Documents
2.	REMOVE:	Section 03 20 00 – “Concrete Reinforcing”
	2.1.5.1	Remove subsection;
	2.1.5.2	Remove subsection;
	2.1.5.3	Remove subsection;
	2.1.5.4	Remove subsection;
	2.1.5.	To remain as stated.

2. QUESTIONS AND RESPONSES:

Q1: Is there an alternative to having the reinforcement chromated?

A1: **See revisions to specifications. Delete subsections 2.1.5.1 to 2.1.5.4 from Section 03 20 00 within the specification. All bars shall be galvanized as per 2.1.5.**

Q2: Clarification with respect to Drawing S6, Note 5 states “Primer coat only on all inside surfaces of box”. Confirm that this includes ‘B1’, “VB1” and “D1” bracing angles, HSS and all gusset plates and the interior side of the hatches.

A2: **Primer coat only on the inside of the box girder is to be applied to all steel surfaces within the interior of the box. This includes, but not limited to, ‘B1’, ‘VB1’ and ‘D1’ bracing angles, HSS and all gusset plates, stiffeners and the interior side of the hatches.**

Q3: Clarification with respect to Drawing S6, Note 5 states “membrane drain downspouts shall also be fully coated”, is this coating required?

A3: **Membrane drains are to be galvanized only as per Section 05 50 00.**

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.