



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3
Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scot
B3J 1T3

Title - Sujet Galvanized Steel Tower Fabrication Galvanized Steel Tower Fabrication	
Solicitation No. - N° de l'invitation F6839-215061/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F6839-21-5061	Date 2022-08-22
GETS Reference No. - N° de référence de SEAG PW-SHAL-412-11550	
File No. - N° de dossier HAL-1-87225 (412)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Daylight Saving Time ADT on - le 2022-08-25 Heure Avancée de l'Atlantique HAA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Sheppard, Tara	Buyer Id - Id de l'acheteur hal412
Telephone No. - N° de téléphone (709) 640-6581 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F6839-215061
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
004
File No. - N° du dossier

Buyer ID - Id de l'acheteur
HAL412
CCC No./N° CCC - FMS No./N° VME

Solicitation Amendment 004

- Q1. Please see attached 2 submissions (3M DBI SALA Lad Saf Flexible Cable Vertical Safety Systems and MSA Latchways Vertical Ladder Kits) for your consideration as equal to Trylon Cougar safety rail.
- A1. The suggested fall arrest systems will not be accepted as CCG uses rigid rail systems only. No cable or rope fall arrest system will be accepted. Please see the below specifications on acceptable fall arrest safety system:
- The Contractor shall design, supply and install a CSA approved Fall Arrest
 - Rail to meet CSA S37-18 and the latest version of CSA Z259.2.4-15 and CSA Z259.2.5-12.
 - Rail system is to be Trylon type trolley compliant or *approved equivalent*.
 - The fall arrest rail shall be free from obstructions for the complete height of the tower.
 - The fall arrest rail shall be supported at spans not more than 1 m. Any extension beyond the top of the tower must be structurally supported for the entire height.
 - Proper manufactured stop hardware is to be installed at the top of the fall arrest rail to prevent accidental dislodging of the trolley from the rail.

As per the RFP, all enquiries must be submitted in writing to the Contracting Authority no later than seven (7) calendar days before the bid closing date – August 17th, 2022. Enquiries received after that time may not be answered.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME