



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Highway 19 Flood Damage Reinstatement – Riding Mountain National Park	
Solicitation No.: 5P468-22-0080/A	Date: August 25, 2022
Amendment No.: 002	
Client Reference No.: N/A	
GETS Reference No.: PW-22-01003728	

Solicitation Closes: At: 2:00 PM On: August 30, 2022	Time Zone: CDT
---	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Ken Lacanilao	
Telephone No.: (587) 832-1894	Fax No.: (855) 983-1808
Email Address: kenneth.lacaniclao@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Email.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 002

This amendment is raised to answer questions from bidders and make revisions to the tender package.

A. Questions and Answers

- Q1.** In previous projects, RMNP has allowed us to dispose of the waste excavation at the grey owl trail. Could you please confirm this will not be allowed?
- A1.** It is confirmed that disposal of waste excavation at the Grey Owl pit is not allowed. The Grey Owl pit has been decommissioned and is no longer a ground for disposal.
- Q2.** Could you please confirm if Crushed Rock, 50mm minus, and 25mm minus (100% Crushed) granular sourced would be an acceptable alternative to the limestone?
- A2.** See below revisions in section 32 15 40 - Crushed Stone Surfacing part 2.1.1 Materials
- Q3.** Could you please provide more information regarding amendment 1, "Clause 4.1.2.9 - Rural municipalities within parkland district have interest for the bid item 2 type D Material"?
- A3.** See below revisions in section 01 11 00 Summary of Work part 4.1.2 Project Location.

B. Tender Package / Solicitation Revisions

In: **SPECS (IFT)_Hwy 19.pdf**
Section: **01 11 00 Summary of Work**
Part: **4.1.2 Project Location**

Add: .9 Rural Municipalities within the Parkland district have interest for the bid Item 2 Type D material. **The rural municipalities of McCreary will accept up to 5,000 cubic yards of fill, delivered to the waste disposal grounds, grader shed, and a few other spots between town and Provincial Highway #19. The rural municipalities of Rosedale is interested in the remaining fill, especially at the landfill east of Kelwood. Haul distances are within the 20 km range from East Gate of Park.**

In: **SPECS (IFT)_Hwy 19.pdf**
Section: **32 15 40 - Crushed Stone Surfacing**
Part: **2.1.1 Materials**

Delete: .1 Crushed Rock, 50mm Minus (Limestone):

Replace With: .1 Crushed Rock, 50mm Minus (Limestone), **50 mm Minus (100% crushed), or Approved Equal.**

In: **SPECS (IFT)_Hwy 19.pdf**
Section: **32 15 40 - Crushed Stone Surfacing**
Part: **2.1.2 Materials**

Delete: .2 Crushed Rock, 25mm Minus (Limestone):

Replace With: .2 Crushed Rock, 25mm Minus (Limestone), **25 mm Minus (100% crushed), or Approved Equal.**

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.