



RETURN BIDS TO:
RETOURNER LES SUBMISSION À :
Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 002 TO A INVITATION TO TENDER

RÉVISION 002 À UNE INVITATION A SOUMISSIONER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
National Contracting Services

Parks Canada Agency
Banff National Park
Banff, AB

Title - Sujet : Castle Mountain Campground Rehabilitation – Phase 2 Banff National Park	
Solicitation No. - N° de l'invitation : 5P421-22-0017/A	Date : August 24, 2022
Amendment No. - N° de modification : 002	
Client Reference No. - N° de référence du client : N/A	
GETS Reference No. N° de référence de SEAG : PW-22-01003452	
Solicitation Closes - L'invitation prend fin : At - à : 2 :00 On - le : 30 August 2022	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>	
Address Enquiries to - Adresser toutes demande de renseignements à : Rose Marino	
Telephone No. - N° de telephone : (403) 760-1319	Fax No. -N° de télécopieur : (1-855-983-1808)
Email Address – Courriel : Rose.marino@canada.ca	
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein – Voir aux présentes	
TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE	
Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P421-22-0017/A

Amd. No. - N° de la modif. :
002

Contracting Authority - Autorité contractante :
Rose Marino

Client Ref. No. - N° de réf. du client :

Title – Titre :
Castle Mountain Campground Rehabilitation – Phase 2 Banff National Park

Amendment 002

This amendment is raised to:

- A. Answer questions from bidders

A. Questions and Answers

Q1. The wall assemblies show 4" EPS Rigid insulation, but on the specifications, Roxul CavityRock seems to be required. Please clarify which one is required.

A1. Roxul CavityRock is required for inside of stud cavities, including for interior and exterior walls according to the drawings; 4" EPS Rigid insulation is required on all exterior walls, in addition to the requirement for stud cavity insulation. Refer to Architectural drawings for wall assembly details.

Q2. Proposed product alternative:

- Contract specified acceptable product: Specifications 07 42 46 – Fibre Reinforced Cementitious Wall Panels, section 2.2.6.1.1. Acceptable products are as follows
 - Knight Wall Systems, Thermazee
- Proposal alternative: ISO Clips and 18-gauge galvanized girts

A2. Proposed alternative is acceptable. Product to be installed as per manufacturer recommendations.

Q3. Proposed product alternative:

- Contract specified acceptable products: Specifications 07 27 00 – Air Barriers, section 2.2.2. Acceptable products are as follows:

- .1 Vapour Permeable Air Barrier 3015VP as manufactured by 3M.
- .2 Perm-A-Barrier VPS as manufactured by Grace (GCP Applied Technologies).
- .3 Sopraseal Stick VP as manufactured by Soprema.
- .4 Blueskin VP 160 as manufactured by Henry.
- .5 Other preapproved alternate.

- Proposed alternative: SRP AirOutshield™ SA 280, self-adhered, vapour permeable air barrier as manufactured by SRP Canada. www.srpcanada.ca

A3. Proposed alternative is acceptable.

To assist with bonding and insurance requirements, this project is estimated at a value between \$1,000,001 > \$2,000,000, Taxes extra.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED