



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A :**

GRC-RCMP

Bid Receiving/Réception des soumissions
Attn: Brianne Leach
Email: Brianne.Leach@rcmp-grc.gc.ca

**SOLICITATION
AMENDMENT**

**MODIFICATION DE
L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments: - Commentaries :

THIS DOCUMENT CONTAINS A SECURITY REQUIREMENT

LE PRÉSENT DOCUMENT COMPORTE UNE EXIGENCE EN MATIÈRE DE SÉCURITÉ

Title – Sujet Construction: TPOF Walkway/Pathway to Upper Terrace		Date August 29, 2022
Solicitation No. – N° de l'invitation 202206291		Amendment No. – N° de la modification 01
Client Reference No. - No. De Référence du Client 202206291		
Solicitation Closes – L'invitation prend fin		
At / à :	1400 (2:00 pm)	EDT (Eastern Daylight Time) HAE (heure avancée de l'Est)
On / le :	September 2, 2022	
F.O.B. – F.A.B See herein.	GST – TPS See herein.	Duty – Droits See herein.
Destination of Goods and Services – Destinations des biens et services See herein.		
Instructions See herein.		
Address Inquiries to – Adresser toute demande de renseignements à Brianne Leach Brianne.Leach@rcmp-grc.gc.ca		
Telephone No. – No. de téléphone 343-541-8512		

Delivery Required – Livraison exigée	Delivery Offered – Livraison proposée
Vendor/Firm Name, Address and Representative – Raison sociale, adresse et représentant du fournisseur/de l'entrepreneur:	
Telephone No. – No. de téléphone	Facsimile No. – No. de télécopieur
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) – Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date



Solicitation Amendment: 001

This solicitation amendment 001 has been raised to:

- (A) Identify Changes to the ITT
 - (B) Add Addenda to the ITT
 - (C) Respond to a questions regarding the ITT
-

(A) CHANGES

(Change 1): At the cover page, solicitation closing date:

Delete: August 31, 2022 at 2:00 pm EDT (Eastern Daylight Time)

Insert: September 2, 2022 at 2:00 pm EDT (Eastern Daylight Time)

(B) ADDENDA

Addendum 1:

Addendum 1 has been added to this tender; please see attachment.

(C) QUESTIONS AND ANSWERS

Question 1: Will there be an allowance for rebuilding the structure of the Manhole/Handhole under the tree if the tree / tree roots have damaged it?

Answer 1: No. The existing structure will be inspected during construction, after tree removal. If any repair work is required to the structure caused by tree / tree roots it will be considered for a change order/contract amendment, if required. Adjustment of the height of the manhole is included as part of the contract, as specified on drawings.

Question 2: Is there a location on site for dumping excess materials?

Answer 2: No. Refer to ITEM 4.7 of Technical Specifications.

Question 3: Will any landscape reinstatement be composed of 100mm topsoil? Sod or seed? Also can the landscape be pushed to be completed after May 1st 2023?

Answer 3: Landscape reinstatement is specified under ITEM 7.4 of Technical Specifications. Project schedule will be finalized with successful contractor after award and suggested revisions will be considered by the project team.

Question 3: At the concrete crossings where depressed curbs are to be installed, can the concrete roadway be cut and reinstated to allow to form the curbs?

Answer 4: Yes. Refer to attached marked-up drawings (C3.1, C3.2 and C4.2) for clarifications, and for the addition of Detail 206.



Question 5: Some rock will need to be hoe rammed, is there a requirement to monitor the vibrations?

Answer 5: Yes. Refer to ITEM 5.6 of the Technical Specifications.

Question 6: I have just started to look into this project and noticed that there was a mandatory site visit. We have performed work with the RCMP sites before and I would love the opportunity to place a bid. Is it at all possible to schedule another site visit?

Answer 6: Unfortunately, another site visit will not be scheduled. Attendance of the site visit for this project is mandatory.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.