



Parks
Canada

Parcs
Canada



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-877-558-2349

Bid E-mail Address:

soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 003 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services

Parks Canada Agency
Halifax, Nova Scotia

Title:

Ingonish Beach Washroom Replacement, Cape Breton Highlands
National Park

Solicitation No.:

5P468-22-0072/A

Date:

30 August 2022

Amendment No.:

003

Client Reference No.:

2230

GETS Reference No.:

PW-22-01003726

Solicitation Closes:

At: 14:00

On: 08 September 2022

Time Zone:

ADT/HAA

F.O.B.:

Plant: ☐ Destination: ☒ Other: ☐

Address Enquiries to:

Jaime Creaser

Telephone No.:

902-266-8592

Fax No.:

1-877-558-2349

Email Address:

Jaime.Creaser@pc.gc.ca

Destination of Goods, Services, and Construction:

See Herein

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:

Address:

Telephone No.:

Fax No.:

Name of person authorized to sign on behalf of the Vendor/
Firm (type or print):

Signature:

Date:

Solicitation No.:
5P468-22-0072/A

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
2230

Title:
Ingonish Beach Washroom Replacement, Cape Breton Highlands National Park

Amendment 003

This amendment is raised to provide questions and answers.

1.0 Questions and Answers

Q1. We are looking to get approval for the 1.5" snaplock profile for the install on the Ingonish washrooms. I am also attaching the information on the PVDF as well. They also do have 5 other profiles if this isn't approved.

A1. 1.5" Profile is acceptable provided that the product meets all the requirements listed in Volume 01 specifications 07.61.00, 07.46.19 and related sections. Fastening to allow for thermal expansion with proposed dark color and sub-structure. Color to be approved by Department Representative and Architect at sample submission.

Q2. Looking to clarify the size and finish of the kerdi-line drain as listed on spec sheet section 09 30 13 tiling page 6 of 11 point 2.7 membranes for showers. Also, we can supply Kerdi-Board [so long as it is in stock, in other projects we have had to provide cement board due to supply shortages] and Kerdi-Line drain but would they need to be installed by other unionized trades (as indicated by note to co-ordinate with other trades)?

A2. Shower drains to be circular as shown in Mechanical and Architectural documents. Drains to be compatible with all membranes and flooring to provide waterproof condition in showers. Basis of Design for acceptable product performance is KERDI-DRAIN or similar that is compatible. Not required to be installed by other trades

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED