



RETURN BIDS TO :
RETOURNER LES SOUMISSIONS À :
Bid Receiving - Réception des soumissions:

GEN-ONTContractingBidSubmissions/Soumissionsdecontrats@CSC-SCC.GC.CA

**INVITATION TO TENDER
AMENDMENT
MODIFICATION DE L'INVITATION À
SOUMISSIONNER**

Tender to: Correctional Service Canada

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission à : Service correctionnel du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux appendices ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments — Commentaires :
« THIS DOCUMENT DOES NOT CONTAIN A SECURITY REQUIREMENT » « LE PRÉSENT DOCUMENT NE COMPORTE PAS D' EXIGENCE RELATIVE À LA SÉCURITÉ »

Title — Sujet: High Mast Lights Replacement-CBI	
Solicitation No. — No. de l'invitation 21401-22/23-4193452	
Solicitation Amendment No. — No. de modification de l'invitation 001	Date: September 2, 2022
GEIS Reference No. — No. de Référence de SEAG PW-22-00998121	
Solicitation Closes — L'invitation prend fin at / à : 1 :00pm on / le : Sept 8, 2022	
F.O.B. — F.A.B. Plant – Usine: ___ Destination: ___ Other-Autre: ___	
Address Enquiries to — Soumettre toutes questions à: Mark Kelly Contracting & Procurement Officer Correctional Services Canada Mark.Kelly@csc-scc.gc.ca	
Telephone No. – No de téléphone: 613-329-7251	Fax No. – No de télécopieur: 613-536-4571
Destination of Goods, Services and Construction: Destination des biens, services et construction: Collins Bay Institution 1455 Bath Road Kingston, Ont K7L 4V9	
Instructions: See Herein Instructions : Voir aux présentes	



Invitation to Tender Amendment 001 is issued to

1. Change in Scope of Work

- Delete: N/A

Insert:

1. Contractor to provide a PVC drain in Pole 3 similar to the drain in Pole 1 prior to grout installation.
2. Alternative pre-approved Type B1 fixture is Cooper GLEON-SA9-740-9-5NQ

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.