



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St. / 11, rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Electrical & Electronics Products Division
L'Esplanade Laurier
East Tower, 4th floor,
Ottawa
Ontario
K1A 0S5

Title - Sujet Security System for Maritime Centre Système de sécurité pour le Centre Maritime	
Solicitation No. - N° de l'invitation H1121-214780/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client H1121-214780	Date 2022-09-14
GETS Reference No. - N° de référence de SEAG PW-\$\$HN-336-81347	
File No. - N° de dossier hn336.H1121-214780	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2022-09-27 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bisson(hn336), Phillippe	Buyer Id - Id de l'acheteur hn336
Telephone No. - N° de téléphone (613) 295-8641 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT 002 IS RAISED TO ANSWER THE FOLLOWING QUESTIONS:

Question 1:

Regarding the doors which need (recessed door contacts, electric strikes & UnLatch electric strikes) can we know if those doors' materials are either all wood or interior steel door frames, please clarify.

Response 1:

Interior steel door frames.

Question 2:

Kindly confirm that we will be responsible only for the supply/installation of the parts in the required parts list section 3.1.6 with the required cables as well.

Response 2:

Cabling requirements can be determined from the following drawings:

- Appendix B – 15th Floor North (one new card reader door)
- Appendix C – 15th Floor South (one new card reader door)
- Appendix E – 17th Floor South (one new card reader door)
- Appendix G – 18th Floor South (two new card reader doors and nine panic alarms)

Question 3:

Regarding the requested Sentrol 1" DPDT recessed door contacts, can we quote the Recessed Steel Door Contact from GE 1" Diameter, DPDT or not? and if not please advise the door hardware material and the exact required model from Sentrol?

Response 3:

As identified in Section 3.1.6 Sentrol 1" DPDT recessed door contacts or equivalent (Sentrol 1076D-N Recessed Steel Door Contact w/Wire Leads, 1" Diameter, DPDT, 1/2" Gap Size, Double Pole-Double Throw, White or equivalent).

Question 4:

Regarding the Securitron UNL UnLatch electric strikes, kindly confirm that UNL-24 is acceptable and if not please advise with the required model?

Response 4:

As identified in Section 3.1.6 Securitron UNL UnLatch electric strikes (SKU: UNL-12 with 626 Satin chromium over nickel, 12VDC or equivalent.)

Solicitation No. - N° de l'invitation
H1121-214780/A
Client Ref. No. - N° de réf. du client
H1121-214780

Amd. No. - N° de la modif.
002
File No. - N° du dossier
hn336.H1121-214780

Buyer ID - Id de l'acheteur
hn336
CCC No./N° CCC - FMS No./N° VME

Question 5:

Regarding the Keyscan “NETCOM2” this is the old version for the communication module and the new one is “NETCOM2P”, so kindly confirm that using the updated model is acceptable and recommended from your side.

Response 5:

As identified in Section 3.1.6 Keyscan NETCOM2 off-board network communication module.

Question 6:

Regarding the Keyscan “CIM” communication module, the Keyscan team is saying that this module will be delayed if we placed an order with it as of the global ships shortage and they advise if the timeline of this project is tight, we have to change those modules to “NETCOM2P” but it will be more expensive, so please advise which one to use?

Response 6:

As identified in Section 3.1.6 Keyscan CIM communication module.

**** ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED ****