



**RETURN BIDS TO /
RETOURNER LES SOUMISSIONS À:**

**Parks Canada Agency, Bid Receiving Unit
National Contracting Services**

BID FAX: 1-855-983-1808

**Bid Email / Courriel de soumission :
soumissionsami-bidsrpc@pc.gc.ca**

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**INVITATION TO TENDER
APPEL D'OFFRES**

Proposal to: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office :

Parks Canada Agency
National Contracting Services
Cornwall, Ontario, K6H 6S2

Title-Sujet Highway crack sealing for Cape Breton Highlands National Park		
Solicitation No. - No. de l'invitation 5P468-22-0078/A		Date: September 15, 2022
GETS Reference No. – No de référence de SEAG PW-22- 01006545		Client Ref. No. – No. de réf du client. 8102
Solicitation Closes – L'invitation prend fin :		
at – à 2:00 PM	on – le September 22, 2022	Time Zone - Fuseau horaire ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Sheldon Lalonde sheldon.lalonde@pc.gc.ca		
Telephone No. - No de téléphone 343-585-3836		Fax No. – No de FAX: 1-855-983-1808
Destination of Goods, Services, and Construction: Destinations des biens, services et construction : See Herein – Voir aux présentes		

**TO BE COMPLETED BY THE BIDDER
À ÊTRE COMPLÉTÉ PAR LE SOUMISSIONNAIRE**

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT #1

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

By submission of bid, the Bidder confirms that the requirements in this addendum have been read and understood.

1. QUESTIONS AND RESPONSES:

Question #1 -

What is Parks Canada process if the completion date is missed? Are there penalties or Liquidated Damages assessed?

For this tender, the time allotted to complete the work is extremely tight.

- Tender closing: September 22, 2022
- Assumed Award Date: September 29, 2022
- Traffic control plan submittals & approval: October 6, 2022
- Completion date: October 28, 2022

This would only 21 days to complete the work. This does not even allow for the requirement to submit a sample of the product and related documentation 2 weeks before starting work (32 01 18 1.4.3.1).

Response: For a missed completion date, please see GC5 – Terms of Payment, sub item 5.10 referred to in the Invitation to Tender (ITT).

Question #2 -

As well, we also must consider the required application temperatures from the specification (32 01 18 3.3.5):

- .5 Fill cracks only when air temperature is above 10 degrees C, daily low temperature does not fall below 5 degrees C, and no rain is forecast.

We have checked the averages for the area and, with an average temperature during the day of 11 degrees C, night temperature of 6 degrees C and 10 days of rain, it would appear it may be impossible to meet the completion date.

Response:

Section 32 01 18

- Part 1.4 Action and Informational Submittals**
- a) Delete part 1.4.3.1 and replace with the following:
.1 Submit one 4 L container of sealant proposed for use 4 days prior to start of work.

- Part 3.3 Application of Sealant**
- a) Delete part 3.3.5 and replace with the following:
.5 Fill cracks only when air temperature is above 5 degrees C. Sealant is not to be placed during wet weather or wet pavement conditions.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED