



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Box/Boîte de Réception des  
Soumissions**

**1st Floor/1<sup>ère</sup> étage, Suite 1212**

**100-1045 Main Street**

**Moncton**

**New Brunswick**

**E1C 1H1**

**Bid Fax: (506) 851-6759**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Acquisitions NB/PEI (Moncton Office) – Bureau

d'acquisitions N.-B./Î.-P.-É. (Moncton)

1045 Main Street / 1045, rue Main

Moncton

New Bruns

E1C 1H1

<b>Title - Sujet</b> New Marginal Wharf and Breakwater S New Marginal Wharf and Breakwater Structure 403, Petit-Cap, N.B.	
<b>Solicitation No. - N° de l'invitation</b> EC015-230487/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EC015-230487	<b>Date</b> 2022-09-21
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWJ-017-6251	
<b>File No. - N° de dossier</b> PWJ-2-45041 (017)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Atlantic Daylight Saving Time ADT <b>on - le 2022-10-04</b> Heure Avancée de l'Atlantique HAA	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Stockman (PWJ), Sonia	<b>Buyer Id - Id de l'acheteur</b> pwj017
<b>Telephone No. - N° de téléphone</b> (506) 961-7412 ( )	<b>FAX No. - N° de FAX</b> (506) 851-6759
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Solicitation Amendment No. two (2) is raised to include the following Addendum No. one (1).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

INSERT: Addendum 1:

- E1- Issued for Addendum Sept 14, 2022
- E2- Issued for Addendum Sept 14, 2022
- E3- Issued for Addendum Sept 14, 2022
- E4- Issued for Addendum Sept 14, 2022
- E5- Issued for Addendum Sept 14, 2022

This solicitation is hereby amended to:

1. Reference: Closing date appearing of page one of the solicitation document  
DELETE the closing date of 2022-09-27; and  
INSERT the revised closing date 2022-10-04
2. Answer the following questions:

**Q1: In the item 1 of Creosote Timber Disposal this item only includes the tipping fee to dispose the timber while the transportation of the material is in the lump sum item of Demolition of the Crib. The transportation of material is based on the 270 tonnes estimated. If the tonnage is increased will the transportation of material be able to increase in this item as well?**

A1: Replace 01 29 10 - 1.2.2.1.3 - Item 3 with:

Item 3 - Demolition of 403 Crib Removal/Disposal: This work shall constitute a lump sum price for measurement purposes. This work shall include demolition and disposal of the existing timber crib structure #403, and all excavation, trenching, and transportation of materials to complete the work. It also includes placement of the ballast stone as noted on the drawings. All costs associated with the work shall be included in this item. This item excludes all loading, transportation, and disposal costs of the creosote timbers.

Replace 01 29 10 - 1.2.2.2.1 - Item 1 with:

Item 1 - Creosote Timber Disposal: Creosote timber disposal shall constitute a price per metric tonne for measurement purposes. This item shall include the loading, transportation, and disposal of creosote timbers. This item shall be paid based on the tonnage on the submitted tipping fee receipts from an approved Provincially operated disposal facility.

**Q2: What type of foam is required for under the slab over the h-pile and wall panel?**

A2: The foam must be rigid expanded insulation made of polystyrene. The foam must meet the requirements of CAN/ULC-S701-97.

Solicitation No. - N° de l'invitation  
EC015-230487/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
pwj017

Client Ref. No. - N° de réf. du client  
R.116039.001

File No. - N° du dossier  
PWJ-2-45041

CCC No./N° CCC - FMS No./N° VME

---

**Q3: In the call for tenders, there is no item in the schedule for overheads. Should they be included in mobilization/demobilization, or an item will be created?**

A3: Overhead costs should be included in the mobilization/demobilization item.

**All other terms and conditions remain the same.**