

## DEMANDE DE PROPOSITION (DDP)

Travaux en électricité - Mise à niveau du système d'alarme d'incendie

**Modification 1 : Questions reçues pendant la période de soumission**

**Date de clôture de la période de soumission :  
Le 28 septembre 2022 à 14h00 (HAE)**

Transmettre les soumissions  
**par Service Connexion de la Société canadienne des postes (SCP)**

ou par Fax : 819-997-9776

**Référence:** Dossier ASC n°. 9F030-22-0031

*Nota :* Veuillez lire attentivement la présente demande pour plus de détails sur les exigences et les instructions relatives à la présentation des soumissions.



21 septembre 2022

Question : Quelle est la capacité portante des planchers surélevés ?

Réponse : 365 kg (800 lbs)

## **REQUEST FOR PROPOSAL (RFP)**

Electrical Work - Fire Alarm System Update

**Amendment 1 : Questions received during bid submission period**

**Bid Submission Deadline:  
September 28, 2022 at 2:00 PM (EDT)**

**Submit Bids to:**

**by Canada Post Corporation's (CPC) Connect service**

or

**By Fax : 819-997-9776**

**Reference:** CSA File No. **9F030-22-0031**

*Note:* Please read this Request for Proposal carefully for further details on the requirements and bid submission instructions.



**September 21, 2022**

Question: What is the load bearing capacity of the raised access floors?

Answer: 365 kg (800 lbs)