



DETAIL - ALUMINUM RAKE

SCALE : 1:20  
0mm 500mm 1000mm 1500mm 2000mm 2500mm



PLAN VIEW



DETAIL - SECURITY CHAMBER - SAMH-C

SCALE : 1:20  
0mm 500mm 1000mm 1500mm 2000mm 2500mm

NOTES:

- REFER TO SPECIFICATIONS FOR STRUCTURAL REQUIREMENTS FOR THIS CHAMBER.
- IF JOINTS ARE REQUIRED BETWEEN FLAT TOP SECTION AND WALLS, WALLS SECTIONS, WALLS AND BASE, THEY SHALL HAVE A CONFINED O-RING GASKET, C/W TWO (2) ROWS OF PREFORMED FLEXIBLE PLASTIC GASKET AND BE PROTECTED WITH A WATER PROOFING MEMBRANE, MIN. 450mm WIDE PRIOR TO BACKFILLING, SEE SPECIFICATIONS FOR DETAILS.
- EXACT FLOAT SWITCH ELEVATION TO BE DETERMINED IN THE FIELD.



|   |                               |            |
|---|-------------------------------|------------|
| 3 | ISSUED FOR TENDER             | 04/14/2022 |
| 2 | ISSUED FOR RS4 99% SUBMISSION | 10/30/2020 |
| 1 | ISSUED FOR RS4 66% SUBMISSION | 02/28/2020 |
| 0 | ISSUED FOR RS3 SUBMISSION     | 08/17/2018 |

SEWAGE TREATMENT UPGRADES  
SPRINGHILL INSTITUTION  
SPRINGHILL, NS

SECURITY CHAMBER  
DETAILS

|                       |                                |               |
|-----------------------|--------------------------------|---------------|
| designed              | GMG                            | conçu         |
| date                  | 2018-09-11                     |               |
| drawn                 | GMG                            | dessiné       |
| date                  | 2019-09-11                     |               |
| approved              | ppp                            | approuvé      |
| date                  | 2018-09-11                     |               |
| Tender                |                                | Soumission    |
| PWOSC Project Manager | Administrateur de projets TPSC |               |
| project number        |                                | no. du projet |
|                       | R.061876.001                   |               |
| drawing no.           |                                | no. du dessin |
|                       | C21                            |               |