



Public Works and  
Government Services  
Canada

Travaux publics et  
Services gouvernementaux  
Canada

No of Page/

N° de page \_\_\_\_\_ 3 \_\_\_\_\_

Date of Solicitation Amendment – Date de la modification à la demande

October 14, 2022

Address inquiries to – Adresser toute demande de renseignement à :

See Section 2, Article 4.1.

Voir Section 2, Article 4.1

Destination

See Section 2, Annex A.

Voir Section 2, Annexe A.

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

#### AMENDMENT TO STANDARD REQUEST FOR BID

#### MODIFICATION DE LA DEMANDE D'OFFRE STANDARD

The Bidder offers to provide to Canada the goods, services or both listed in the bid solicitation in accordance with the conditions set out in the bid solicitation and the prices set out in the bid.

This bid solicitation is issued in accordance with the conditions of the Supply Arrangement E60PQ-140003/PQ.

Le soumissionnaire offre de fournir au Canada les biens, services ou les deux énumérés dans la demande de soumissions aux conditions prévues dans la demande de soumissions et aux prix indiqués dans la soumission.

Cette demande de soumissions est émise conformément aux conditions de l'arrangement en matière d'approvisionnement E60PQ-140003/PQ.

Solicitation No. - N° de la demande M5000-22-3980/C	Amendment No. - N° de modification  004
Supplier SA No. - N° de l'AMA de fournisseur :  <u>E60PQ-140003/_____</u>	

Solicitation closes – La demande prend fin :  at – à 14 :00 CST  on – le October 24, 2022	File No. - N° de dossier
---	--------------------------

Instructions:

Municipal taxes are not applicable.

Unless otherwise specified in the bid solicitation, all prices quoted must be net prices in Canadian funds including Canadian customs duties, excise taxes, must be FOB, including all delivery charges to destination(s) as indicated. The amount for Applicable Taxes is to be shown as a separate item.

Instructions:

Les taxes municipales ne s'appliquent pas.

Sauf indication contraire dans la demande de soumissions, tous les prix indiqués doivent être des prix nets, en dollars canadiens, comprenant les droits de douane canadiens, la taxe d'accise et doivent être FAB, y compris tous frais de livraison à la (aux) destination(s) indiqué(s). Le montant des taxes applicables doit apparaître séparément.

Supplier Name and Address – Nom et adresse du fournisseur

Telephone No. - N° de téléphone

Facsimile No. - N° de télécopieur

Name and title of person authorized to sign on behalf of supplier (type or print)

Nom et titre de la personne autorisée à signer au nom du fournisseur (caractère d'impression)

Signature : \_\_\_\_\_ Date : \_\_\_\_\_

--	--

Canada

This amendment is raised to:

- 1) Extend the bid tender closing date from October 14, 2022 to October 24, 2022
- 2) DELETE in its entirety: Solicitation Document M5000-22-03980C dated September 13, 2022 and INSERT Solicitation Document M5000-22-03980C dated for October 14, 2022
- 3) Respond to the following questions:

i) The panel matrix indicates that Panel Type B should have both laminate and fabric for the lower element. Please confirm which material is requested.

Lower Element for Panel Type B is Laminate

ii) Work surface Privacy panels can have a total height of 42" to 49", with a base panel and add-on panel. SA Specifications allow for power below or above work surface. The left image below shows power above the surface, the image on the right below the surface. In the provided image, both power locations are in the lower element on the base panel.

Power location should be as shown in the right image.

iii) The floor plan provided does not show the location of the height-adjustable tables. Please advise, noting that if a fixed surface is placed in front of a height-adjustable surface the sizes dictated by the SA specs do not allow for the 1" safety gap that is required. To solve this, the height-adjustable table would have to be reduced in depth by an additional 1", making the actual depth of a 24 table 22". Secondly, surfaces in the RFB do not appropriately fill the space in the panel layout provided. There would be a dead space of approximately 13" in the corner of the workstation. Please confirm the correct layout and location of all surfaces.

iv) The panel matrix chart in the RFB has a total of 67 Base panels, and 60 add-on panels. If all the panels on the floor plan are to be the same height, then the total base must be the same as the total add-on.

The CAD floor plan provided shows a total of 64 panels in the design. To match the panels in the floorplan the quantities in the chart below would need to be adjusted

Please confirm.

Please see updated solicitation documents

v) *Workstations "4/5/6/7/8/9" are grouped with a total of 15 duplexes (30 simplex outlets). This is above the maximum 6 duplexes per circuit allowable. Therefore 3 circuits would need to be*

*connected to the one base feed to avoid overloading this grouping. Likewise, workstations groupings "10/10/11/12" and "1/2/3" would require 2 circuits attached to 1 base feed.*

Please see updated solicitation documents

vi) Are fabric and/or painted metal acceptable material finishes instead of laminate for the panel tiles?

No

vii) Is street offloading required?

No. We have a paved parking lot.