



RETURN BIDS TO:
RETOURNER LES SUBMISSION À :
Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 15 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 004 TO A INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
National Contracting Services
Gatineau, Qc

Title - Sujet : Fort Henry Masonry Redoubt Recapitalization, Fort Henry National Historic Site		
Solicitation No. - N° de l'invitation : 5P468-22-0135/A	Date : November 8, 2022	
Amendment No. - N° de modification : 004		
Client Reference No. - N° de référence du client : 2261		
GETS Reference No. N° de référence de SEAG : PW-20-01006999		
Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : November 10, 2022		Time Zone - Fuseau horaire EST - HNE
F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Christine Piché		
Telephone No. - N° de telephone : 873-355-8841	Fax No. -N° de télécopieur : 1-855-983-1808	Email Address - Courriel : Christine.piche@pc.gc.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		
TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE		
Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :		
Address - Adresse :		
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature :	Date :	

Solicitation No. - N° de l'invitation :
5P468-22-0135/A

Amd. No. - N° de la modif. :
004

Contracting Authority - Autorité contractante :
Christine Piché

Client Ref. No. - N° de réf. du client :
2261

Title – Titre :
Fort Henry Masonry Redoubt Recapitalization, Fort Henry National Historic Site

AMENDMENT 004

This amendment is raised to:

- A) Answer questions from bidders;
- B) Addition of a Solicitation Attachment document.

A. QUESTIONS AND ANSWERS

Q42: Where should we include for paint removal of wood in the breakdown table?

A42: The instruction to “restore” or “replace” includes surface prep and painting.

Q43: Where should we include for restoration of wrought iron shutters and new copper-clad shutters in the breakdown table?

A43: Refer to revised Appendix 1 Combined Price Form issued with Addendum #3.

Q44: As per section 08 06 00, there is no scope mentioned for the frame of windows (RW2-28 to RW2-35), could you please clarify the intent?

A44: Refer to revised Section 08 06 00 Intervention Work Sheets issued with Addendum #4.

Q45: Where should we include for paint removal of metal in the breakdown table?

A45: The instruction to “restore” or “replace” includes surface prep and painting.

Q46: In the specification 04 03 43.16, 3 quarries are specified for supply limestone similar to Kingston limestone. Our stone shop has contact with them, some of them don't supply limestone block anymore. We used Flintheills limestone (light & grey, see attached photos) to match Kingston limestone on previous jobs. Will the stone be acceptable with this approved alternative?

A46: On issuing this tender, the quarries listed in the specification confirmed availability of stone supply.

Q47: Would it be possible to clarify where the shallow surface delamination repairs are localized (as per detail 9/S402, addendum 2)? Is it a below arcade balcony slab or it is a concrete stools? What is the existing topping which has to be removed/restored?

A47: Refer to 6/S500 and 10/S502.

Q48: As per specs we have to clean all pigeon droppings (note CL on S200...S206) but the limits (zones) are not specified on the elevations. Could you please indicate the approximate area of bird droppings cleaning which should be included in our quote?

Would it be possible to precise the type of bird droppings cleaning – will it be a chemical removal, low pressure micro-abrasive cleaning or something else considering that the pricing for each type of cleaning is different.

A48: Cleaning of the bird droppings is located on the skyward facing surfaces. Assume for pricing pigeon droppings. Refer to specification 04 03 01.13 for cleaning method. An increased level of effort is required to clean pigeon droppings. No additional types of cleaning are required.

Solicitation No. - N° de l'invitation :
5P468-22-0135/A

Amd. No. - N° de la modif. :
004

Contracting Authority - Autorité contractante :
Christine Piché

Client Ref. No. - N° de réf. du client :
2261

Title – Titre :
Fort Henry Masonry Redoubt Recapitalization, Fort Henry National Historic Site

B. ADDITION OF A SOLICITATION ATTACHEMENT DOCUMENT

Refer to documents below uploaded on November 8, 2022:

- **08 06 00 Intervention Schedule Work Sheets**

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED