

The following changes in the tender documents are effective immediately. This Addendum will form part of the contract documents. All other terms and conditions remain unchanged.

Amendment 02 is raised for the following:

- Addendum 02
- Answers to questions raised.

ADDENDUM 02

Reference to specification Section 08 11 00 Clause 2.2

Delete “.6 Provide exit signs for access/egress door”.

Add “.6 Exit signs for access/egress door by Others.”

END OF ADDENDUM 02

QUESTIONS AND ANSWERS

Q1: Could you provide further details/spec pertaining to the “exit signs” required for the mandooors? If they are to be lit than I would recommend this to fall under the electrical scope of work.

A1: Provision of exit signs for access/egress door by others as per addendum 02.

Q2: I noticed in the spec for section 08 11 00 – Metal Doors and Frame, it mentions 10 uninsulated doors and 4 insulated doors, all single (type A). However on the door schedule, **door 101** is also in the scope of work, please clarify if this insulated double door should be included in my quote?

A2: Refer to amendment 01 – Questions and Answers A4.

Q3: Can you clarify if the contractor is responsible for the foundation and associated earthworks . Is there no electrical and mechanical scope of works for this building? Is the foundation existing ?

A3: Refer to Specification Section 01 11 00 Clause 1.7. Design and installation of foundation and associated earthwork is excluded from the work. This tender does not include any scope on electrical and mechanical. Foundation is not existing. Design and installation of foundation by others as per section 01 11 00 clause 1.7.

----End of Addendum 02----