

BUILDING NAME:	RCMP MANITOU DETACHMENT
BUILDING ADDRESS:	245 FRONTAGE RD. MANITOU MB.
DATE:	MONDAY MARCH 22,2021

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN FRONT VESTIBULE ENTRANCE	FACP	MIRCOM FA-204E	✓	x	✓	✓	✓		D2
GUARD ROOM/CELL AREA	ANN	MIRCOM	✓		✓	✓	✓		
MAIN FLOOR ZONE 4 :									
BY FRONT ENTRANCE	M	Z4	✓		✓	✓	✓		
GENERAL OFFICE EAST	S	Z4	✓	x	✓	✓	✓		D1
GENERAL OFFICE BY RECEPTION	S	Z4	✓	x	✓	✓	✓		D1
GENERAL OFFICE RECEPTION	HT	Z4	✓		✓	✓	✓		O1
CORPORALS OFFICE	HT	Z4	✓		✓	✓	✓		O1
SARGENTS OFFICE	HT	Z4	✓		✓	✓	✓		O1
OFFICE BY STAIRS	M	Z4	✓		✓	✓	✓		
EXIT BY STAIRS	M	Z4	✓		✓	✓	✓		
STAIRS TO BASEMENT	S	Z4	✓	x	✓	✓	✓		D1
HALL BY WASHROOMS	S2	Z4	✓		✓	✓	✓	2.4%	
WOMENS WASHROOM	HT	Z4	✓		✓	✓	✓		O1
MENS WASHROOM	HT	Z4	✓		✓	✓	✓		O1
LUNCH ROOM	HT	Z4	✓		✓	✓	✓		O1
HALL BY INTERVIEW ROOM	S2	Z4	✓		✓	✓	✓	2.4%	
INTERVIEW ROOM	S2	Z4	✓		✓	✓	✓	2.4%	
HALL TO CELL AREA	M	Z4	✓		✓	✓	✓		
JANITORS ROOM	S2	Z4	✓		✓	✓	✓	2.4%	
FILE ROOM	S2	Z4	✓		✓	✓	✓	2.6%	
CELL AREA WEST EXIT	M	Z4	✓		✓	✓	✓		
CELL AREA HALL BY GUARDS ROOM	S	Z4	✓	x	✓	✓	✓		D1
CELL AREA GUARD ROOM	S2	Z4	✓		✓	✓	✓	2.4%	
CELL AREA GUARD ROOM	M	Z4	✓		✓	✓	✓		
BY RECEPTION & STAIRS	EOL	Z4	✓		✓	✓			
MAIN ENTRANCE VESTIBULE	M2	Z4	✓		✓	✓	✓		O4
CELL AREA SHOWER ROOM	HT2	Z4	✓		✓	✓	✓		O1
GARAGE ZONE 1:									
GARAGE	RHT	Z1	✓		✓	✓	✓		O1
GARAGE	EOL	Z1	✓		✓	✓			
CELL 1 ZONE 3 :									
CELL1	S	Z1	✓	x	✓	✓	✓		D1,O2
CELL 1	EOL	Z1	✓		✓	✓			
CELL 2 ZONE 2:									
CELL 2	S	Z2		x					D1,O2,D3,O3
CELL 2	EOL	Z2		x					
STORAGE ROOM ZONE 5 :									

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
INNER EXHIBIT ROOM	S	Z5	✓	x	✓	✓			D1
OUTER EXHIBIT ROOM	S	Z5	✓	x	✓	✓			D1
BY JANITORS ROOM	EOL	Z5	✓		✓	✓			
FR2 DUCT SMOKE ZONE 8:									
SUPPLY	DS	Z8	✓		✓	✓	✓		
RETURN	DS	Z8	✓		✓	✓	✓		
IN SUPPLY DEVICE	EOL	Z8	✓		✓	✓			
FR1 DUCT SMOKE ZONE 7:									
SUPPLY	DS	Z7	✓		✓	✓	✓		
RETURN	DS	Z7	✓		✓	✓	✓		
IN SUPPLY DEVICE	EOL	Z7	✓		✓	✓			
BASEMENT & CRAWLSPACE ZONE 6:									
WORKOUT ROOM	M	Z6	✓		✓	✓	✓		
SOUTH WORKOUT ROOM	RHT	Z6	✓		✓	✓	✓		
MECHANICAL ROOM NORTH	HT	Z6	✓		✓	✓	✓		O1
MECHANICAL ROOM SOUTH	HT	Z6	✓		✓	✓	✓		O1
S/E CRAWLSPACE	HT	Z6	✓		✓	✓	✓		O1
N/W CRAWLSPACE	HT	Z6	✓		✓	✓	✓		O1
STORAGE ROOM	EOL	Z6	✓		✓	✓			
BOTTOM OF BASEMENT STAIRS	S	Z6	✓	x	✓	✓	✓		D1
SIGNALS :									
GENERAL OFFICE	B	NAC1	✓		✓	✓			
GENERAL OFFICE HALL	B	NAC1	✓		✓	✓			
GENERAL OFFICE CELL HALL	B	NAC1	✓		✓	✓			
MECHANICAL ROOM	B	NAC2	✓		✓	✓			
GYM	B	NAC2	✓		✓	✓			
MECHANICAL ROOM	EOL	NAC2	✓		✓	✓			
GENERAL OFFICE	EOL	NAC1	✓		✓	✓			

