

### E3. FIELD DEVICE RECORD

(Reference: Clause 5.1 6)

#### E3.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 5.7.4.1.3, 5.7.4.1.4, 5.7.4.1.5, 5.7.4.3.1, 5.7.4.5.1, 5.7.8.1.1, 5.7.8.2.2, 5.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	MIRCOM	MS-710AP
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	MIRCOM	MIX-5251RAPA
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	MIRCOM	MIX-2251APA
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	MIRCOM	
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP THOMPSON AIRPORT HANGER
BUILDING ADDRESS:	122 SELKIRK AVE. THOMPSON MB.
DATE:	JUNE 1,2022

### E3.2 INDIVIDUAL DEVICE RECORD

(Reference Clauses 5.7.1.3, E3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN ENTRANCE	FACP	MIRCOM FX-3500	✓		✓	✓		
SIGNALS :								
LOBBY	H/V	NAC1	✓		✓			
HALL OFFICE ENTRANCE FROM WAITING ROOM	H/V	NAC1	✓		✓			
LOBBY WASHROOM	H/V	NAC1	✓		✓			
PILOTS OFFICE	H/V	NAC1	✓		✓			
OFFICE WASHROOM/CHANGE ROOM	H/V	NAC1	✓		✓			
OFFICE HALL BY WASHROOM/CHANGE ROOM	H/V	NAC1	✓		✓			
BREAK ROOM	H/V	NAC1	✓		✓			
SHOP	H/V	NAC1	✓		✓			
SHOP OFFICE	H/V	NAC1	✓		✓			
GARAGE	H/V	NAC1	✓		✓			
MAIN ELECTRICAL ROOM	H/V	NAC1	✓		✓			
IT ROOM	H/V	NAC1	✓		✓			
GENERATOR ROOM	H/V	NAC1	✓		✓			
MEZZANINE NORTH	H/V	NAC1	✓		✓			
MEZZANINE SOUTH	H/V	NAC1	✓		✓			
HANGER: NAC2								
S/E	H/V	NAC2	✓		✓			
CENTRE SOUTH	H/V	NAC2	✓		✓			
S/W	H/V	NAC2	✓		✓			
N/W	H/V	NAC2	✓		✓			
N/E	H/V	NAC2	✓		✓			
DEVICES:								
MEZZANINE NORTH	RHT	1-031	✓		✓	✓		
MEZZANINE CENTRE NORTH	RHT	1-030	✓		✓	✓		
MEZZANINE CENTRE SOUTH	RHT	1-029	✓		✓	✓		
MEZZANINE SOUTH	RHT	1-028	✓		✓	✓		
GENERATOR ROOM	RHT	1-009	✓		✓	✓		
IT ROOM	RHT	1-008	✓		✓	✓		
MAIN ELECTRICAL ROOM	RHT	1-005	✓		✓	✓		
GARAGE	RHT	1-007	✓		✓	✓		
GARAGE	M	1-205	✓		✓	✓		
GARAGE S/W	M	1-203	✓		✓	✓		
GARAGE S/E	M	1-204	✓		✓	✓		
SHOP	RHT	1-006	✓		✓	✓		
BREAK ROOM	RHT	1-004	✓		✓	✓		
HALL BY OFFICE WASHROOM/CHANGE ROOM	S	1-003	✓		✓	✓		

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
HALL BY PILOTS ROOM	S	1-002	✓		✓	✓		
HALL BY LOBBY/OFFICE	S	1-001	✓		✓	✓		
TARMAC EXIT DOOR	M	1-201	✓		✓	✓		
MAIN ENTRANCE BY FACP	M	1-202	✓		✓	✓		
HANGER:								
ROW 1 S/E	RHT	1-012	✓		✓	✓		
CENTRE S/E	RHT	1-019	✓		✓	✓		
CENTRE S/W	RHT	1-020	✓		✓	✓		
S/W EXIT	RHT	1-027	✓		✓	✓		
ROW 2 S/E	RHT	1-013	✓		✓	✓		
CENTRE S/E	RHT	1-018	✓		✓	✓		
CENTRE S/W	RHT	1-021	✓		✓	✓		
S/W	RHT	1-026	✓		✓	✓		
ROW 3 S/W	RHT	1-025	✓		✓	✓		
CENTRE S/W	RHT	1-022	✓		✓	✓		
CENTRE S/E	RHT	1-017	✓		✓	✓		
S/E	RHT	1-014	✓		✓	✓		
ROW 4 S/W	RHT	1-015	✓		✓	✓		
CENTRE S/W	RHT	1-016	✓		✓	✓		
CENTRE S/E	RHT	1-023	✓		✓	✓		
S/E	RHT	1-024	✓		✓	✓		
S/W EXIT	M	1-209	✓		✓	✓		
N/E EXIT	M	1-206	✓		✓	✓		
S/E CORNER	M	1-208	✓		✓	✓		
EAST EXIT	M	1-207	✓		✓	✓		
GARAGE OVERHEAD DOOR	RHT	1-011	✓		✓	✓		O3
HANGER OVERHEAD DOOR	RHT	1-010	✓		✓	✓		O3
AUX.								
SHUTTER DOOR	AD		✓		✓	✓		O3
GENERATOR	AD							O4

BUILDING NAME:	RCMP THOMPSON AIRPORT HANGER	
BUILDING ADDRESS:	122 SELKIRK AVE. THOMPSON MB.	
DATE:	JUNE 1,2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

**EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD**

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor, or light battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
MEZZANINE NORTH	2BP	120	6V	36W		✓	✓		30	✓	LUMACELL. BATTERY 6V 7AH.
MEZZANINE SOUTH	2BP	120	6V	36W		✓	✓		30	✓	LUMACELL. BATTERY 6V 7AH.
MEZZANINE CENTRE	CP	120	6V	36W		✓	✓	✓	30	✓	LUMACELL. BATTERY 6V 5AH.
SHOP	2BP	120	12V	360W		✓	✓	✓	30	✓	BEGHELLI NV12380-2BTMR7WLED-ADTB. BATTERY 12V 32AH.
HANGER	2BP	120	12V	360W		✓	✓	✓	30	✓	BEGHELLI NV12380-2BTMR7WLED-ADTB. BATTERY 12V 32AH.
											BREAKER MAIN ELECTRICAL ROOM
											PANEL 600 CCT#18-20-30-43.