

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	SIGA-270
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	EDWARDS	SIGA-HRS
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector	EDWARDS	284B-PL
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EDWARDS	SIGA-PS
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor	EDWARDS	SIGA-CT2
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker	EDWARDS	CG4-S7
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor	EDWARDS	EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP Churchill
BUILDING ADDRESS:	381 Kelsey Blvd, Churchill MB
DATE:	Tuesday, November 30, 2021

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
PANEL									
Front Entrance	FACP								
DETECTION									
Main Entrance	M	01 03 148	✓		✓	✓	✓		
Main Entrance	S	01 03 044	✓		✓	✓	✓		
Public Washroom	S	01 03 045	✓		✓	✓	✓		
Interview Room	S	01 03 046	✓		✓	✓	✓		
Reception Area (by Landing)	S	01 03 047	✓		✓	✓	✓		
Multipurpose Room	S	01 03 048	✓		✓	✓	✓		
General Office Area (high ceiling)	S	01 03 005	✓		✓	✓	✓		
Main Office	S	01 03 055	✓		✓	✓	✓		
Telephone Room	S	01 03 050	✓		✓	✓	✓		
LAN Room	S	01 03 051	✓		✓	✓	✓		
Corridor by Locker Room	S	01 03 052	✓		✓	✓	✓		
Exercise Room	RHT	01 03 001	✓		✓	✓	✓		
Womens Locker Room	RHT	01 03 002	✓		✓	✓	✓		
Womens Washroom	RHT	01 03 003	✓		✓	✓	✓		
Mens Locker Room	RHT	01 03 053	✓		✓	✓	✓		
Mens Washroom	RHT	01 03 054	✓		✓	✓	✓		
General Storage Room	S	01 03 049	✓		✓	✓	✓		
Hall by Mech Room	RHT	01 03 056	✓		✓	✓	✓		
Rear Exit (North)	M	01 03 127	✓		✓	✓	✓		
Mech Room	RHT	01 03 057	✓		✓	✓	✓		
Secure Room Exhibit	S	01 03 058	✓		✓	✓	✓		
Over Night Exhibit	S	01 03 059	✓		✓	✓	✓		
Secure Interview Room	S	01 03 004	✓		✓	✓	✓		
Guard Area	S	01 03 062	✓		✓	✓	✓		
Guard Washroom	S	01 03 064	✓		✓	✓	✓		
Janitor Room	RHT	01 03 065	✓		✓	✓	✓		
Holding Cell Corridor	S	01 03 061	✓		✓	✓	✓		
Holding Cell by Exit	S	01 03 063	✓		✓	✓	✓		
Holding Cell by Exit	M	01 03 153	✓		✓	✓	✓		
General Holding Cell	S	01 03 069	✓		✓	✓	✓		
Male Holding Cell	S	01 03 068	✓		✓	✓	✓		
Female Holding Cell	S	01 03 067	✓		✓	✓	✓		
Attic	SFD	01 03 152	✓		✓	✓	✓		
Room 26 Shower	HT		✓		✓	✓	✓		
Breath Room	S	01 03 066	✓		✓	✓	✓		
Secure Bay Exit	M	01 03 155	✓		✓	✓	✓		

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
Garage By Exit	M	01 03 154	✓		✓	✓	✓		
Attic	SFD	01 03 149	✓		✓	✓	✓		
Attic over Garage Bay	HT		✓		✓	✓	✓		
Room 30s	HT		✓		✓	✓	✓		
Attic	SFD	01 03 150	✓		✓	✓	✓		
Garage Bay	HT		✓		✓	✓	✓		
Attic Heats	HT		✓		✓	✓	✓		
Attic	EOL		✓						
Crawl Space									
By Hatch	M	01 03 126	✓		✓	✓	✓		
Mezzanine Attic	SFD	01 03 128	✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	HT		✓		✓	✓	✓		
Crawlspace	EOL		✓						
ISOATORS									
Mul ipurpose Room	IM	01 03 006	✓						
Mul ipurpose Room	IM	01 03 007	✓						
RM 31	IM	01 03 008	✓						
Crawlspace	IM	01 03 009	✓						
SIGNALS									
Reception Area	SP		✓			✓			
Rm 32	SP		✓			✓			
Rm 33	SP		✓			✓			
Garage Bay	SP		✓			✓			
Rm 34	SP		✓			✓			
Rm 35	SP		✓			✓			
Center Crawlspace	SP		✓			✓			
East Crawlspace	SP		✓			✓			
West Crawlspace	SP		✓			✓			
Rm 36	SP		✓			✓			
Outside N.W,	SP		✓			✓			

BUILDING NAME:	RCMP Churchill	
BUILDING ADDRESS:	381 Kelsey Blvd, Churchill MB	
DATE:	Tuesday, November 30, 2021	
TEST NG PERFORMED BY:		
	Printed Name	Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x = Fail	Remarks / Deficiencies / Corrective Action
Womens Washroom	2BP	120	12	72		✓	✓		30	✓	12ESL-72, 2X 6V 7AH
Room 1	2BP	120	12	72		✓	✓		30	✓	12ESL-72, 2X 6V 7AH
Room 2	2BP	120	12	72		✓	✓		30	✓	12ESL-72, 2X 6V 7AH
Mech Room	2BP	120	24	550		✓	✓		30	✓	24ESL-550, 2X 12V 35AH
Lunch Room	2BP	120	12	72		✓	✓		30	✓	12ESL-72, 2X 6V 7AH
Garage	2BP	120	24	550		✓	✓		30	✓	24ESL-550, 2X 12V 35AH
CRAWLSPACE											
by Access Hatch	CP	120	6			✓	✓	✓	30	✓	LPEX52-P, 6V 5AH
Section 1A	CP	120	6			✓	✓	✓	30	✓	LPEX52-P, 6V 5AH
Section 4	CP	120	6			✓	✓	✓	30	✓	LPEX52-P, 6V 5AH
Section 4A	CP	120	6		x	x	✓		0	x	LPEX52-P, 6V 5AH, D1
Crawlspace	2BP	120	24		x	x	✓		0	x	4X 6V12AH, D1