

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

| DEVICE | DESCRIPTION | MANUFACTURER | MODEL NO. |
|--------|-----------------------------------|--------------|------------|
| M | Manual Station | MIRCOM | 73303 |
| M2 | Manual Station | | |
| M3 | Manual Station | | |
| RHT | Rate of Rise Heat Detector | | 281A |
| RHT2 | Rate of Rise Heat Detector | | |
| RHT3 | Rate of Rise Heat Detector | | |
| HT | Fixed Temperature Heat Detector | | |
| HT2 | Fixed Temperature Heat Detector | | |
| HT3 | Fixed Temperature Heat Detector | | |
| S | Smoke Detector | | 1400A |
| | Sensitivity Test Method: | | |
| | Sensitivity Range: | | |
| S2 | Smoke Detector | | C2W-BA |
| | Sensitivity Test Method: | | |
| | Sensitivity Range: | | |
| S3 | Smoke Detector | | |
| | Sensitivity Test Method: | | |
| | Sensitivity Range: | | |
| RI | Remote Indicator | | |
| DS | Duct Smoke Detector | | |
| SFD | Supporting Field Device - Monitor | | |
| SFD2 | Supporting Field Device - Monitor | | |
| FD | Sprinkler Flow Switch | | |
| SS | Sprinkler Supervisory Device | | |
| PS | Sprinkler Pressure Device | | |
| IM | Isolation Module | | |
| B | Bell | | 439D-10AWC |
| B2 | Bell | | |
| H/V | Horn/Visual | | |
| H/V2 | Horn/Visual | | |
| H | Horn | | |
| H2 | Horn | | |
| V | Visual Signal Device | | |
| V2 | Visual Signal Device | | |
| SP | Cone Type Speaker | | |
| SP2 | Cone Type Speaker | | |
| HSP | Horn Type Speaker | | |
| AD | Ancillary Device | | |
| AD2 | Ancillary Device | | |
| ET | Emergency Telephone | | |
| EOL | End of Line Resistor/Capacitor | | |
| EOL2 | End of Line Resistor/Capacitor | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| | |
|-------------------|----------------------------|
| BUILDING NAME: | RCMP South Indian Lake |
| BUILDING ADDRESS: | South Indian Lake, MB |
| DATE: | Friday, September 24, 2021 |

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

| Location | Device (See Legend) | Zone Circuit Number or Address | Correctly Installed | Requires Service | Alarm Operation Confirmed | Output Circuit Operation Confirmed | Annunciation Indication Confirmed | Reading / Measurement (Sensitivity, Pressure, Time Delay, etc) | Remarks / Required Additional Notes |
|---------------------|------------------------|--------------------------------|---------------------|------------------|---------------------------|------------------------------------|-----------------------------------|---|-------------------------------------|
| OFFICE REAR EXIT | FACP | | ✓ | | ✓ | ✓ | ✓ | | |
| DEVICES : | | | | | | | | | |
| GENERAL OFFICE | S2 | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| INTERVIEW ROOM | RHT | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| OFFICE STORAGE ROOM | S2 | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| ABOVE CELL DESK | S | 1 | ✓ | x | ✓ | ✓ | ✓ | | D1 |
| HALL BY CELLS | S2 | 1 | | x | | | | | D3 |
| MAIN ENTRANCE | M | 1 | | x | | | | | D4 |
| FURNACE ROOM | RHT | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| WASHROOM | RHT | 1 | ✓ | x | ✓ | ✓ | ✓ | | D2 |
| REAR EXIT | M | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| REAR EXIT | EOL | 1 | ✓ | | ✓ | ✓ | ✓ | | |
| CELL 1 | S | 2 | ✓ | x | ✓ | ✓ | ✓ | | D1,01 |
| BY CELL 1 | EOL | 2 | ✓ | | ✓ | ✓ | ✓ | | |
| CELL 2 | S | 3 | ✓ | x | ✓ | ✓ | ✓ | | D1,01 |
| BY CELL 2 | EOL | 3 | ✓ | | ✓ | ✓ | ✓ | | |
| CELL 3 | S | 4 | ✓ | x | ✓ | ✓ | ✓ | | D1,01 |
| BY CELL 3 | EOL | 4 | ✓ | | ✓ | ✓ | ✓ | | |
| SIGNALS : | | | | | | | | | |
| OFFICE AREA | B | NAC 1 | ✓ | | ✓ | ✓ | ✓ | | |
| BY CELL AREA DESK | B | NAC 1 | ✓ | | ✓ | ✓ | ✓ | | |
| BY CELL AREA DESK | EOL | NAC 1 | ✓ | | ✓ | ✓ | ✓ | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

