

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	SIMPLEX	4099-9001
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	SIMPLEX	4098-9714
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell	EDWARDS	439D-10AWC
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor	EDWARDS	EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP BLOODVEIN DETACHMENT
BUILDING ADDRESS:	BLOODVEIN MB.
DATE:	WEDNESDAY APRIL 20,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN ENTRANCE VESTIBULE	FACP	SIMPLEX 4008	✓		✓	✓	✓		O3
DEVICES:									
MAIN ENTRANCE	M	M1-1	✓		✓	✓	✓		
MAIN ENTRANCE	S	M1-2	✓		✓	✓	✓		
INNER EXHIBIT ROOM	S	M1-4	✓		✓	✓	✓		
OUTER EXHIBIT ROOM	S	M1-3	✓		✓	✓	✓		
HALL BY ADMIN.	S	M1-6	✓		✓	✓	✓		
CELL AREA HALL	S	M1-7	✓		✓	✓	✓		
CELL AREA EXIT	M	M1-11	✓		✓	✓	✓		
CELL 1	S	M1-8	✓		✓	✓	✓		O2
CELL 2	S	M1-9	✓		✓	✓	✓		O2
CELL 3	S	M1-10	✓		✓	✓	✓		O2
GARAGE	M	M1-12	✓		✓	✓	✓		
BREATHALIZER/FINGERPRINT ROOM	S	M1-5	✓		✓	✓	✓		
SIGNALS :									
OFFICE AREA	B	NAC1	✓			✓	✓		
CELL AREA	B	NAC1	✓			✓	✓		
GARAGE	B	NAC1	✓			✓	✓		
CELL AREA	EOL	NAC1	✓						
SPRINKLERS:									
SHUTOFF VALVE	TS	M1-16							O1
LEFT BACKFLOW SHUT OFF	TS	M1-13							O1
RIGHT BACKFLOW SHUT OFF	TS	M1-14							O1
MAIN FLOW	FS	M1-15							O1
ANCILLARY DEVICES:									
FAN SHUT DOWN	AD	M1-17	✓		✓	✓	✓		
HRV SHUT DOWN	AD	M1-18	✓		✓	✓	✓		

BUILDING NAME:	RCMP BLOODVEIN DETACHMENT	
BUILDING ADDRESS:	BLOODVEIN MB.	
DATE:	WEDNESDAY APRIL 20,2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
OFFICE	2BP	12V		72W		✓	✓	✓	30	✓	BEGHELLI NV12-72-2. BATTERIES 2-6V5AH.
CELL HALL	2BP	12V		72W	x					x	D1. BEGHELLI NV12-72-2. BATTERIES 2-6V5AH.
GARAGE	2BP	12V		72W	x					x	D1. BEGHELLI NV12-72-2. BATTERIES 2-6V5AH.